



Project No: PS-339

Study on the Need for Modernization of Large Combustion Plants
in the Contracting Parties of the Energy Community
in the context of the implementation of Directive 2001/80/EC




FINAL REPORT



SOUTH EAST EUROPE CONSULTANTS Ltd.

November 21st, 2013

COVER PAGE

| | |
|-----------------------------------|---|
| Investor: | EnergyCommunity Secretariat Am Hof 4, 5 th floor, A-1010 Vienna / Austria Phone: +43 1 535 2222 Fax: +43 1 535 2222 11 Web: www.energy-community.org |
| Project Title: | Study on the Need for Modernization of Large Combustion Plants in the Contracting Parties of the Energy Community in the context of the implementation of Directive 2001/80/EC |
| Countries: | Albania, Bosnia and Herzegovina, Croatia, FYR Macedonia, Serbia, Moldova, Montenegro, Ukraine and Kosovo * |
| Document Title: | Final Report |
| Contractor: | South East Europe Consultants, Ltd. Makenzijeva 53, 11000 Belgrade / Republic of Serbia Phone: +381 11 20 40 310 Website: www.seec-bg.com |
| Official Representative of ECS | Mr Janez Kopač Director of the Energy Community Secretariat |
| Official Representative of SEEC | Dr Ljubo Miskin Managing Director |
| EnC Project Manager | Peter Vajda Environmental Expert Phone: +43 1 535 2222 50 Fax: +43 1 535 2222 11 email: peter.vajda@energy-community.org |
| SEEC Project Manager | Milan Jovanic, Dipl.E.Eng., M.Sc.(Eng.), DIC Energy and Environmental Consultant Phone:+381 11 2040 382 E-mail: milan.jovanic@seec-bg.com |
| Authors of the Report | Milan Jovanic; Milan Gavrilovic; Jadranko Simic |
| Project start date: | December 12 th , 2012 |
| Date of issuance: | November 21 st , 2013 |
| Signature of EnC Project Manager | |
| Signature of SEEC Project Manager |  |

* This designation is without prejudice to positions on status, and is in line with UNSCR 1244 and the ICJ Opinion on the Kosovo declaration of independence.

Table of Contents

| | |
|---|-----------|
| Glossary of Abbreviations and Acronyms | 4 |
| Executive Summary | 6 |
| 1. Introduction | 17 |
| 2. Inventory of LCPs in the EnC Contracting Parties | 25 |
| 2.1. Large combustion plants in Albania..... | 25 |
| 2.2. Large combustion plants in Bosnia and Herzegovina | 25 |
| 2.3. Large combustion plants in Croatia..... | 26 |
| 2.4. Large combustion plants in FYR Macedonia | 27 |
| 2.5. Large combustion plants in Moldova | 28 |
| 2.6. Large combustion plants in Montenegro | 29 |
| 2.7. Large combustion plants in Serbia | 30 |
| 2.8. Large combustion plants in Ukraine..... | 31 |
| 2.9. Large combustion plants in Kosovo* | 36 |
| 3. External cost of electricity and heat production in LCPs | 37 |
| 4. Estimated investment cost of the environmental upgrade scenarios | 49 |
| 4.1. Scenarios for environmental upgrading of LCPs in Albania..... | 50 |
| 4.2. Scenarios for environmental upgrading of LCPs in Bosnia and Herzegovina | 50 |
| 4.2.1. Scenario 1 - Installation of emission reduction measures in compliance with the LCPD..... | 51 |
| 4.2.2. Scenario 2 - Emission reduction measures in compliance with the IED | 51 |
| 4.2.3. Scenario 3 - Emission reduction measures and replacement of some TPP units for reaching ELV in compliance with the LCPD | 52 |
| 4.3. Scenarios for environmental upgrading of TPPs in Croatia | 52 |
| 4.3.1. Scenario 1 - Emission reduction measures for reaching compliance with the LCPD | 53 |
| 4.3.2. Scenario 2 - Emission reduction measures for reaching compliance with IED | 53 |
| 4.3.3. Scenario 3 - Emission reduction measures, replacement of some TPP units and change of fuel for reaching compliance with the LCPD, Croatia | 53 |
| 4.4. Scenarios for environmental upgrading of LCPs in FYR Macedonia..... | 54 |
| 4.4.1. Scenario 1 - Emission reduction measures in compliance with the LCPD | 54 |
| 4.4.2. Scenarios 2 - Emission reduction measures for reaching compliance with the IED | 54 |
| 4.4.3. Scenario 3 - Replacement of TPP units for reaching compliance with the LCPD | 54 |
| 4.5. Scenarios for environmental upgrading of LCPs in Moldova | 55 |
| 4.6. Scenarios for environmental upgrading of TPPs in Montenegro | 55 |
| 4.6.1. Scenario 1 - Emission reduction measures in compliance with the LCPD | 55 |
| 4.6.2. Scenario 2 - Emission reduction measures for reaching compliance with IED | 55 |
| 4.6.3. Scenario 3 - Replacement of TPP for reaching ELV in compliance with the LCPD | 56 |
| 4.7. Scenarios for environmental upgrading of LCPs in Serbia | 56 |
| 4.7.1. Scenario 2 - Emission reduction costs in accordance with the requirements of the IED | 56 |
| 4.7.2. Scenario 3 - Installation of emission reduction measures in accordance with the ELVs of the LCPD and replacement of existing, low efficiency units | 57 |

| | | |
|----------------|---|-----------|
| 4.8. | Scenarios for environmental upgrading of LCPs in Ukraine | 58 |
| 4.8.1. | Scenario 1 - Emission reduction measures in compliance with the LCPD | 58 |
| 4.8.2. | Scenario 2 - Emission reduction in compliance with IED..... | 59 |
| 4.8.3. | Scenario 3 - Emission reduction in compliance with LCPD | 59 |
| 4.9. | Scenarios for environmental upgrading of LCPs in Kosovo* | 60 |
| 4.9.1. | Scenario 1 - Emission reduction measures in compliance with the LCPD | 61 |
| 4.9.2. | Scenario 2 - Emission reduction measures in compliance with the IED..... | 61 |
| 4.9.3. | Scenario 3 - Replacement of TPP units for reaching compliance with the LCPD | 61 |
| 5. | Cost-benefit analysis of environmental upgrade scenarios for LCPs..... | 62 |
| 5.1. | Basic assumptions and input data for analysing costs and benefits..... | 62 |
| 5.2. | CBA for Albania | 64 |
| 5.3. | CBA for Bosnia and Herzegovina..... | 64 |
| 5.4. | CBA for Croatia | 66 |
| 5.5. | CBA for FYR Macedonia..... | 68 |
| 5.6. | CBA for Moldova..... | 69 |
| 5.7. | CBA for Montenegro..... | 70 |
| 5.8. | CBA for Serbia..... | 71 |
| 5.9. | CBA for Ukraine | 73 |
| 5.10. | CBA for Kosovo*..... | 80 |
| 6. | Conclusions | 82 |
| 7. | Recommendations | 88 |
| ANNEXES | | 93 |
| Annex 1 | Description of BAT for the environmental upgrade of LCPs | 93 |
| Annex 2 | Methodology for the investment cost estimate for environmental upgrade techniques | 100 |
| Annex 3 | European Union Directives - Environmental compliance costs | 112 |
| Annex 4 | Ranking of LCPs in accordance to the impact to the environment | 120 |
| Annex 5 | Requirements of LCP Directive and IE Directive | 132 |

The findings of the present report represent the views of the consultants contracted by the Energy Community Secretariat and are without prejudice to calculations, cost estimates and/or cost-benefit analyses of other entities or institutions.

Glossary of Abbreviations and Acronyms

| | |
|-------------------|--|
| AL | Albania |
| B | Benefit |
| BiH | Bosnia and Herzegovina |
| BAT | Best available techniques |
| BAU | Business as usual - existing status, “do nothing” scenario |
| BC | Brown coal |
| BF | Bag filter |
| C | Cost |
| CAFE | Clean Air for Europe |
| CBA | Cost-benefit analysis |
| CCGT | Combined Cycle Gas Turbine |
| CHP | Combined Heat and Power Plant |
| DCF | Discounted cash flow |
| DeNO _x | De-nitrification process |
| DO | Distillate oil |
| ECT | Energy Community Treaty |
| ELV | Emission limit value |
| EnC | Energy Community |
| ECS | Energy Community Secretariat |
| ESP | Electrostatic precipitator |
| EU | European Union |
| FGD | Flue gas desulphurization |
| FO | Fuel oil |
| FR | Final Report |
| GT | Gas turbine |
| HC | Hard coal |
| HR | Croatia |
| IED | Industrial Emissions Directive |
| IR | Inception Report |
| KO* | Kosovo* |
| L | Lignite |
| LCP | Large combustion plant |
| LCPD | Large Combustion Plants Directive |
| LNB | Low-NO _x burner |
| ME | Montenegro |
| MD | Moldova |
| MK | The former Yugoslav Republic of Macedonia |
| NID | Novel Innovation De-acidification |
| NG | Natural gas |
| NPV | Net present value |
| OFA | Over-fire air |
| PM | Particulate matter |
| RG | Refinery gas |
| PV | Present value |
| RS | Serbia |
| SCR | Selective catalytic reduction |
| SD | Spray drying |
| SNCR | Selective non-catalytic reduction |

| | |
|------|---------------------------|
| TPP | Thermal power plant |
| UA | Ukraine |
| VSL | Value of statistical life |
| VOLY | Value of life year |
| WL | Wet lime |
| WLS | Wet limestone scrubber |

Executive Summary

Electricity and heat generation are major sources of air pollution all around Europe. To deal with the main air pollutants such as sulphur dioxide (SO₂), nitrogen oxides (NO_x), dust - particulate matter (PM), the European Union (EU) had adopted Directive 2001/80/EC on the limitation of emissions of certain pollutants into the air from large combustion plants (LCP Directive) which entered into force on 27 November 2001. This Directive applies to combustion plants with a rated thermal input equal to or greater than 50 MW, irrespective of the type of fuel used (solid, liquid or gaseous). In December 2010, the EU adopted Directive 2010/75/EU on industrial emissions (Industrial Emissions Directive - IED) which entered into force on 6 January 2011 and had to be transposed into the national legislation of EU Member States by 7 January 2013.

All Contracting Parties to the Energy Community Treaty have undertaken to implement the LCP Directive by 31 December 2017, as it is set out by Article 16 and Annex II of the Energy Community Treaty. Implementing the LCP Directive in the Energy Community is a high priority politically and technically for all beneficiary parties as well as the EU. The main requirements of the LCPD and the IED are presented in Tables ES-1 and ES-2.

Table ES-1: Emission limit values for existing LCPs, LCPD

| Pollutant | Rated thermal input /MWth/ | Emission limit values /mg/m ³ / per fuel used | | |
|-----------------|----------------------------|--|-----------------------------|---------|
| | | Solid | Liquid | Gaseous |
| Dust (PM) | <500 | 100 | 50 | 5 |
| | ≥500 | 50 | | |
| NO _x | 50-500 | 600 | 450 | 300 |
| | >500 | 200 | 400 | 200 |
| SO ₂ | 50-100 | 2000 | 1700 | 35 |
| | 100-300 | 2000-400 Linear decrease | 1700 | |
| | 300-500 | | 1700-400 Linear decrease | |
| | >500 | 400 | 400 | |

Table ES-2: Emission limit values for existing LCPs, IED


| Pollutant | Rated thermal input /MWth/ | Emission limit values /mg/m ³ / per fuel used | | |
|-----------------|----------------------------|--|--------|---------|
| | | Solid | Liquid | Gaseous |
| Dust (PM) | 50-100 | 30 | 30 | 5 |
| | 100-300 | 25 | 25 | |
| | >300 | 20 | 20 | |
| NO _x | 50-100 | 450 | 450 | 100 |
| | 100-300 | 200 | 200 | |
| | >300 | 200 | 150 | |
| SO ₂ | 50-100 | 400 | 350 | 35 |
| | 100-300 | 250 | 250 | |
| | >300 | 200 | 200 | |

During the inception phase of this project, an inventory of LCPs with a rated thermal input equal to or greater than 50 MW for each Contracting Party had been established. This inventory contains a list and general information on LCPs with a rated furnace capacity equal to or greater than 50 MW, as well as technical data on the LCP units. Also, additional information on measures needed to meet the requirements of the LCPD and the IED related to the emission limit values (ELVs) for the existing and the associated costs had been collected.

The summary of these data are presented in Table ES-3 and Graph ES-1. There are 183 LCP units, with a total power capacity of 40,807 MW and with a net power output of 38 GW. The largest capacity of TPPs is installed in Ukraine, with 113 units and a total power output of 29.4 GW. The total furnace inputs for all Contracting Parties are nearly 108 GW and the total yearly power output is 149 TWh/year.

Table ES-3: Total capacities in EnC Contracting Parties

| No | EnC Contracting Party | Number of units | Power gross MW | Power net MW | Furnace capacity MW | Energy production GW/year |
|-------|------------------------|-----------------|----------------|--------------|---------------------|---------------------------|
| 1 | Albania | 1 | 100 | 97 | 193 | 722 |
| 2 | Bosnia and Herzegovina | 9 | 1,775 | 1,616 | 5,130 | 10,044 |
| 3 | Croatia | 17 | 1,782 | 1,682 | 4,701 | 10,464 |
| 4 | FYR Macedonia | 7 | 1,291 | 1,194 | 3,408 | 6,364 |
| 5 | Moldova | 8 | 330 | 285 | 1,294 | 1,463 |
| 6 | Montenegro | 1 | 219 | 200 | 516 | 1,489 |
| 7 | Serbia | 22 | 4,679 | 4,247 | 13,943 | 26,605 |
| 8 | Ukraine | 113 | 29,368 | 27,493 | 75,874 | 88,669 |
| 9 | Kosovo* | 5 | 1,288 | 1,169 | 3,350 | 3,951 |
| Total | | 183 | 40,807 | 37,982 | 108,409 | 149,405 |



Graph ES-1: LCP capacities in EnC Contracting Parties

Environmental protection measures have only been applied in certain units. Since with a few exceptions, the LCP units are over 30 years old, a large majority of them would need to undergo significant environmental improvements to meet the emission limit values of either the LCPD or the IED.

To estimate the investment costs for the measures proposed according to the different scenarios for each Contracting Party for the period 2014–2018, appropriate cost-benefit tools had been used¹.

Furthermore, impacts of electricity and heat production on human health and the environment has been estimated as external costs having in mind that they are not included in the current pricing system. The external costs have been calculated by using software tools that had been developed in the framework of the Externe² and NEEDS³ projects.

The ranking of the average estimated external costs of SO₂, NO_x and dust emissions in the Contracting Parties in 2014 is presented in Table ES-4 and Graph ES-2. The calculation is based on the pollutants emission concentration, flue gas volume and fuel consumption for the present power production (in 2012), while the external costs have been estimated for the year 2014.

Table ES-4: Average estimated external costs of SO₂, NO_x and dust emissions in 2014

| Rank | EnC Contracting Party | Power MW | Energy GWh/a | Emission - BAU | | | External costs - BAU | | | | |
|------|------------------------|----------|--------------------|------------------------------|-----------------|-----------------|-----------------------------|-----------------|-----------------|-----------------|------|
| | | | | Pollutants emissions, t/year | | | Total costs, million €/year | | | Unit cost €/kWh | |
| | | | | Dust (PM) | NO _x | SO ₂ | Dust (PM) | NO _x | SO ₂ | | Sum |
| 1 | Montenegro | 219 | 1,489 | 221 | 3,322 | 44,295 | 0.2 | 28.8 | 369.4 | 398.3 | 26.7 |
| 2 | Bosnia and Herzegovina | 1,775 | 10,044 | 6,407 | 24,334 | 296,060 | 3.1 | 187.0 | 2,054.7 | 2,244.7 | 22.3 |
| 3 | FYR Macedonia | 1,291 | 6,362 | 13,222 | 18,642 | 99,953 | 18.4 | 480.9 | 3,052.6 | 3,551.9 | 13.5 |
| 4 | Serbia | 4,679 | 26,240 | 22,551 | 55,536 | 366,060 | 6.1 | 89.2 | 566.8 | 662.1 | 10.4 |
| 5 | Ukraine | 29,368 | 88,669 | 336,517 | 291,830 | 996,765 | 435.9 | 1,555.8 | 7,062.9 | 9,054.6 | 10.2 |
| 6 | Kosovo* | 1,288 | 3,951 ⁴ | 8,582 | 17,952 | 14,768 | 7.0 | 155.5 | 123.2 | 285.6 | 7.2 |
| 7 | Croatia | 1,782 | 10,464 | 1,977 | 16,747 | 61,090 | 1.7 | 176.9 | 524.9 | 703.5 | 6.7 |
| 8 | Moldova | 330 | 1,580 | 0 | 734 | 0 | 0.0 | 5.3 | 0.0 | 5.3 | 0.4 |
| 9 | Albania | 100 | 722 | 2 | 98 | 70 | 0.0 | 0.5 | 0.5 | 1.0 | 0.1 |
| | Energy Community | 40,807 | 149,405 | 388,262 | 427,551 | 1,869,566 | 472.4 | 2,679.9 | 13,754.9 | 16,907.2 | 11.3 |

It appears that in the present status of TPPs (BAU status), the emission rate is very high namely 388,000 t/year of dust, 428,000 t/year of NO_x and 1,870,000 t/year of SO₂ (Table ES- 3). Therefore, it appears that the external costs of power production are very high, ranging from 0.1 €/kWh, which is rather low, to the extremely high value of 26.7 €/kWh. The average amount of external costs in Energy Community parties is 11.3 €/kWh, which can be considered as a very high value.


The estimated average external costs are different in the EnC Contracting Parties (Graph ES 2). For all EnC Contracting Parties, with the exception of Albania and Moldova, the biggest shares of external costs are those related to SO₂ emissions.

¹ Methodology for the Cost-Benefit analysis for CAFE Programme - Volume 1: Overview of Methodology (2005): <http://europa.eu.int/comm/environment/air/cale/> and www.cafe-cba.org

² http://www.externe.info/externe_2006

³ <http://www.needs-project.org>

⁴ The latest statistics show that total power output for both Kosovo A and B was 5,384 GWh in 2012, within which 36% comes out of Kosovo A and 74% was produced in Kosovo B



Graph ES-2: External costs per unit of power generation in BAU status

A very high level of external costs has been estimated in Montenegro mostly because of the environmentally complex situation related to the production of electricity and heat from lignite, which is the energy source used in the TPP Pljevlja. This is also the case in Bosnia and Herzegovina's TPPs Ugljevik and Kakanj which also resulted in high estimated external costs. The level of external costs in FYR Macedonia is high because of the conditions of lignite usage in TPP Bitola and TPP Oslomej. A similar situation can be observed in Serbia due to the conditions of lignite usage in TPPs Kostolac A and Kostolac B as well as in TPP Kolubara A. In Ukraine, high external costs are related to almost all TPPs which are using coal for electricity and heat production. In Kosovo*, average external costs are relatively smaller due to the better conditions of lignite usage for electricity production. In Croatia, external costs are high related to electricity and heat production from oil fuel and in some cases by a combined use of oil and natural gas in the vicinity of urban areas. In Moldova and Albania, external costs are low, the main reason of which is the dominant use of natural gas for electricity production.

External costs related to the emissions of SO₂, NO_x and dust are not internalised in the power and heat generation systems of any EnC Contracting Party. Moreover, these external costs are still not adequately reflected in energy and heat prices.

Internalisation of external costs in the power and heat generation sector has to be an important policy instrument towards the sustainable development of energy production in all EnC Contracting Parties. The emissions generated in the process of electricity and heat production can cause substantial damages to human health and the

environment, which may vary widely depending on the fuels used, the location of the generation capacities as well as the technology used. Our objective is therefore to assess the external costs associated with electricity and heat production and to combine them with environmental taxes and economic instruments. This is relevant in assessing progress towards internalising external costs or, in other words, to define indicative prices that would reflect those external costs.

The investment costs of the environmental upgrade systems for thermal power plants in the case of the different scenarios (reaching compliance with the LCPD and IED, respectively) are estimated for each Contracting Party. Having in mind that there are many different techniques offering a wide range of solutions for emission reduction and with a large variation in their respective investment costs, the Consultant made a separate review of best available techniques (BAT) and their costs, which are presented in the annexes to the study. The investment cost estimates for the environmental upgrade systems are based primarily on data obtained from the Contracting Parties on already completed projects as well as on their feasibility studies for some TPPs and also on separate studies of international consultants for TPPs in the region, performed within the last decade. The investment costs are used with the same level in all beneficiary countries, taking into account the variations in fuel characteristics, pollutants emission, plant capacity, fuel consumption, etc.


The common characteristics of all EnC Contracting Parties are that they have only one type of domestic fuel appropriate for electricity production. Albania does not have its own fuel sources and uses distillate oil with low sulphur content. Moldova does not have domestic sources of primary energy and it produces electricity in several gas-fired CHPs and imports electricity for the most of its needs. Ukraine is one of the biggest exporters of high quality coal. It has a developed system for gas transport, but due to the major difference between gas and coal prices it uses presently only coal as a fuel in TPPs and all its gas-fired TPPs are temporarily in reserve. In Bosnia and Herzegovina, Montenegro and Serbia lignite is the main source for electricity and heat production. In Croatia, the main sources are gas, oil and coal.

Apart from the prime environmental compliance scenarios with the LCPD and the IED, alternative scenarios have been considered, aiming to achieve the same emission standards as it is required by the LCPD, albeit with different technical solutions. In that respect, the absence of fuel diversity in the Contracting Parties undermines the possibility to choose alternative scenarios which would include a change of fuel. Small power systems in most beneficiary countries also limit the options for different scenarios. In scenarios which include the replacement of existing TPP units, the new TPP units will use the same kind of fuel and the only characteristic to achieve their financial viability is high plant efficiency. The evidence of such options can be approved by analysing their long-term operation results and financial feasibility.

Compliance with LCPD in the EnC Contracting Parties has been analyzed unit by unit. According to the obtained information, regarding the technical parameters and emission concentrations, the best available techniques have been determined for every LCP unit. For these techniques the investment cost is estimated, which is summarized in Table ES-5 and in Graph ES-3.

Table ES-5: Investment costs of TPPs/CHPs for compliance with LCPD (million €)

| No | EnC Contracting Party | Pollutant | | | Total |
|-------|------------------------|-----------|-----------------|-----------------|---------|
| | | Dust (PM) | NO _x | SO ₂ | |
| 1 | Albania | 0 | 0 | 0 | 0 |
| 2 | Bosnia and Herzegovina | 31.9 | 45.8 | 259.5 | 337.2 |
| 3 | Croatia | 20.4 | 43.6 | 164.0 | 228.0 |
| 4 | FYR Macedonia | 41.8 | 36.0 | 151.9 | 229.7 |
| 5 | Moldova | | | | |
| 6 | Montenegro | 0.0 | 4.9 | 42.0 | 46.9 |
| 7 | Serbia | 58.6 | 95.4 | 486.4 | 640.4 |
| 8 | Ukraine | 709.5 | 1,871.2 | 2,557.9 | 5,138.5 |
| 9 | Kosovo* | 20.0 | 26.0 | 32.0 | 78.0 |
| Total | | 882.1 | 2,122.9 | 3,693.7 | 6,698.7 |




Graph ES-3: Investment cost estimate for the compliance with LCPD

The total required investment costs of the environmental upgrade systems amount to 6.7 billion €, out of which Ukraine has the largest share with 5.14 billion € (77%). Regarding the investment cost expenditure per pollutant, SO₂ abatement techniques account for 55%, NO_x reduction for 32% and dust reduction for 13% out of the total estimated amount of costs.

Similar analyses are performed for the second scenario. The results of the investment assessment concerning the environmental upgrading of LCPs with a view to reach compliance with the requirements of the IED are presented in Table ES-6 and Graph ES-4 per Contracting Party.

Table ES-6: Investment cost of TPPs/CHPs for compliance with IED (million €)

| No | EnC Contracting Party | Pollutant | | | Total |
|-------|------------------------|-----------|-----------------|-----------------|---------|
| | | Dust (PM) | NO _x | SO ₂ | |
| 1 | Albania | 0.0 | 0.0 | 0.0 | 0.0 |
| 2 | Bosnia and Herzegovina | 33.5 | 52.9 | 288.3 | 374.7 |
| 3 | Croatia | 22.7 | 110.6 | 184.9 | 318.2 |
| 4 | FYR Macedonia | 47.0 | 57.6 | 167.0 | 271.6 |
| 5 | Moldova | 0.0 | 1.9 | 0.0 | 1.9 |
| 6 | Montenegro | 0.0 | 4.9 | 46.0 | 50.9 |
| 7 | Serbia | 64.7 | 109.5 | 536.5 | 710.7 |
| 8 | Ukraine | 811.7 | 2,300.9 | 2,920.6 | 6,033.2 |
| 9 | Kosovo* | 23.0 | 26.0 | 35.2 | 84.2 |
| Total | | 1,002.6 | 2,664.3 | 4,178.5 | 7,845.4 |



Graph ES-4: Investment cost estimate for the compliance with IED

As the IED requires lower emission limit values for pollutants, the investment cost requirements will be increased to 7.85 billion €, which is 17% higher from the LCPD scenario. Ukraine has also the largest part in it, with a budget sum of over 6 billion €. The other EC beneficiary countries have much lower investment needs, with the exception of Albania, which has already complied with IED standards. Within the required investment cost estimates, the desulphurization plants need 53%, while the nitrogen oxides reduction and dust removal systems require 34% and 13%, respectively.

The third scenario, an alternative scenario to Scenario 1 (with LCPD requirements), includes the replacement of some old TPP units and the environmental upgrading for the rest in the case of need. The main characteristics of this scenario is that the new TPP units, apart from the required environmental standards, will have higher energy efficiency factors, fuel savings, O&M cost reduction and lower green-house gases emissions. The rest of the TPP units would have to implement technical measures for the compliance with the LCPD standards. For this scenario the following investment costs are estimated:

| | |
|--------------------------|-----------------|
| • Bosnia and Herzegovina | 945 million € |
| • Croatia | 704 million € |
| • FYR Macedonia | 1,367 million € |
| • Montenegro | 370 million € |
| • Serbia | 2,776 million € |
| • Kosovo* | 1,090 million € |


These scenarios would have to be analysed on a plant by plant basis, taking into account fixed assets of the existing TPP units, the technical characteristics of new units, fuel savings, revenue, etc. in order to obtain conclusions on the financial viability of the proposed projects.

Ukrainian thermal power plants generally operate at a very low load factor (36.8%) and capacity use (3,224 h/year). Therefore, the power system has a major surplus of generating capacity. One of the possible scenarios analysed in this study, is the temporary conservation of all gas fired TPP units along with the mothballing of the oldest coal fired units (with a total capacity of 9,441 MW). Following this scenario, the average load factor could be increased up to 54.2 %. The necessary investment for the environmental upgrade of the remaining TPPs would amount to 3,843 million €, which is a temporary reduction in investment costs of 1,277 million €. The cost savings for the environmental upgrading for this scenario shall be reinvested later on, if and when the electricity demand increases.

The valuation of different scenarios of the environmental upgrade of LCPs is performed by the use of the Cost-Benefit Analysis (CBA) methodology, which is undertaken from the point of view of the society. The CBA is the economic quantification of all costs and benefits, with regard to compliance with LCP and IE Directives, for every unit for which an environmental upgrade is required. The benefits are accounted as the monetization of the avoidance of external costs of pollutants emission, for each particular pollutant and for each TPP unit, for each EnC Contracting Party. The benefits are summarized by the appropriate social discount rate of 3% to the year of 2017, which is the implementation deadline for the LCPD. Similarly, the present values of all incurred costs are evaluated for the same year (2017). The costs comprise the investment costs for the environmental upgrade as well as the sum of discounted O&M costs for the environmental upgrade systems, over the period up to 2030.

The O&M yearly costs for the Contracting Parties are presented in Graph ES-5. The costs cover maintenance costs, material and power consumption costs, labour costs, insurance costs and waste disposal costs. Due to the characteristics of the O&M costs, they have a fixed part and a part proportional to the energy production. Generally speaking, O&M costs are very large. For all EnC Contracting Parties, they amount to 446 million €/year for LCPD and about 473 million €/year for IED. Within these figures Ukraine has the largest portion of that of 302 and 323 million €/year (see Graph ES-5), followed by Serbia with 69 million €/year, Bosnia and

Herzegovina with 36 to 39 million €/year, Croatia with 16-18 million €/year, FYR Macedonia with 12 to 17 million €/year, Kosovo* with 7 million €/year and Montenegro with 4 million €/year. Moldova will have about 0.4 million €/year for the IED scenario, while Albania will not have any of these expenses.



Graph ES-5: O&M costs of the LCPD and IED compliance systems

The Cost-Benefit analysis has been performed for every single TPP or CHP unit. The results of the CBA show that in most cases benefits significantly outweigh the costs and consequently the B/C ratio is far greater than 1. In the case of a few units, however, the B/C ratio drops down to 4.3 for LCPD scenario and as low as 1.4 for IED scenario. This justifies compliance with the emission limit values of both directives from an economic point of view, with regards to the interest of the society as a whole. The aggregated results per Contracting Party are presented in Tables ES-7 and ES-8.

Within the framework of this study, appropriate environmental abatement techniques are assessed for all LCPs in the EnC Contracting Parties, with a total capacity of 40,807 MW. Compliance with the standards of the **LCP Directive** will require 6,699 million €, amounting to an average of 164 €/kW. In addition, the O&M costs of the environmental upgrade systems will amount to 446 million €/year. The present value of all estimated costs is 11.4 billion € while the present value of all benefits is estimated at a level of 193 billion €. Although there is a variation of B/C Ratio from unit to unit in all considered cases the present value of benefits are much higher than the present value of costs.

Table ES-7: Cost-benefit analysis for compliance with the LCPD


| Code | EnC Contracting Party | MW | Costs | | NPV | | | B/C |
|------|------------------------|--------|---------|----------|--------|---------|---------|-----|
| | | | Invest. | O&M | C | B | B-C | |
| | | | Mil. € | Mil. €/y | Mil. € | Mil. € | Mil. € | |
| 1 | Albania | 100 | N/A | N/A | N/A | N/A | N/A | N/A |
| 2 | Bosnia and Herzegovina | 1,775 | 337.2 | 36 | 720 | 25,974 | 25,254 | 36 |
| 3 | Croatia | 1,782 | 228 | 16 | 396 | 6,497 | 6,101 | 16 |
| 4 | FYR Macedonia | 1,291 | 230 | 12 | 358 | 9,350 | 8,992 | 26 |
| 5 | Moldova | 330 | N/A | N/A | N/A | N/A | N/A | N/A |
| 6 | Montenegro | 219 | 46.9 | 4.3 | 93 | 4,725 | 4,632 | 51 |
| 7 | Serbia | 4,679 | 640 | 68 | 1,368 | 36,825 | 35,458 | 27 |
| 8 | Ukraine | 29,368 | 5,138.5 | 302.1 | 8,351 | 108,243 | 101,448 | 13 |
| 9 | Kosovo* | 1,288 | 78 | 7 | 156 | 1194 | 1,038 | 8 |
| | EnC | 40,807 | 6,699 | 446 | 11,442 | 192,808 | 182,923 | 17 |

Table ES-8: Cost-benefit analysis for compliance with the IED

| Code | EnC Contracting Party | MW | Costs | | NPV | | | B/C |
|------|------------------------|--------|---------|----------|--------|---------|---------|-----|
| | | | Invest. | O&M | C | B | B-C | |
| | | | Mil. € | Mil. €/y | Mil. € | Mil. € | Mil. € | |
| 1 | Albania | 100 | N/A | N/A | N/A | N/A | N/A | N/A |
| 2 | Bosnia and Herzegovina | 1,775 | 375 | 38.0 | 779 | 27205 | 26426 | 35 |
| 3 | Croatia | 1,782 | 318 | 18 | 508 | 7,524.9 | 7,017.1 | 15 |
| 4 | FYR Macedonia | 1,291 | 272 | 17 | 456 | 10,035 | 9,579 | 22 |
| 5 | Moldova | 330 | 2.1 | 0.4 | 6.5 | 22.7 | 16.2 | 4 |
| 6 | Montenegro | 219 | 51 | 4.3 | 96.8 | 4,886 | 4,789 | 50 |
| 7 | Serbia | 4,679 | 704 | 67 | 1,419 | 40,668 | 39,248 | 29 |
| 8 | Ukraine | 29,368 | 6,033 | 323 | 9,467 | 114,860 | 107,283 | 12 |
| 9 | Kosovo* | 1,288 | 84 | 7 | 163 | 1,462 | 1,299 | 9 |
| | EnC | 40,807 | 7,846 | 473 | 12,836 | 205,432 | 194,487 | 16 |

Compliance with the **IED** requires higher investment costs amounting to 7,845 million € which results in an average of specific investments of 192 €/kW. The present value of all estimated costs is 12.8 billion € while the present value of all benefits is estimated to be over 205 billion €. The B/C ratio is very high in the case of IED, which justifies the environmental upgrading, from the point of view of the society as a whole.

The average B/C ratio per Contracting Party is in the range of 8 to 51 for the LCPD, with an EnC average value of 17. In case of IED, the B/C ratio varies from 4 to 50, with an average value of 16 (see Graph 6).



Graph ES-6: Benefit/cost ratio of compliance with the LCPD and IED

The EnC Contracting Parties, with the exception of Croatia, who joined the European Union on 1 July 2013, do not apply adequate measures to reduce emissions of NO_x, SO₂ and dust from large combustion plants. Taking into account fuel characteristics, Albania is already ready to implement both the LCPD and the IED and Moldova only has to carry out minor additional efforts in order to implement the requirements of the IED. Other Contracting Parties, namely Bosnia and Herzegovina, the Former Yugoslav Republic of Macedonia, Montenegro, Serbia, Ukraine and Kosovo* face serious challenges to implement the two directives.

In the past two decades major changes have occurred in the social and economy sectors in the Energy Community Contracting Parties. As a consequence of those changes, a steady decline of industrial production could have been observed resulting in the decline of electricity demand as well. As a consequence, in most of the Contracting Parties no new power generation sources have been constructed for more than twenty years. Therefore, it can be concluded that there is a strong general need for the modernization of this sector as a whole.

1. Introduction

Electricity and heat generation are main sources of air pollution in the EnC Contracting Parties together with transport, industry and agriculture. All these sectors emit a variety of air pollutants – sulphur dioxide (SO₂), nitrogen oxides (NO_x), dust - particulate matter (PM), ammonia (NH₃) and volatile organic compounds (VOCs). Many of these pollutants interact with others or with each other to form new pollutants. These are eventually deposited and have a whole range of adverse effects on human health and environment.

Air pollution results in a high number of premature deaths of citizens in the EnC Contracting Parties each year, as well as increased hospitalization costs, the costs of additional medication and millions of lost working days. Furthermore, environmental damages caused by the acidification of ecosystems and damage to crops and forests are substantial.

Dust (particulate matter) consists of “primary” particles emitted directly into the atmosphere from certain processes and “secondary” particles (or “aerosol”). Particulates in the ambient air are classified according to their size: PM₁₀ and PM_{2.5} refer to all particles with diameter less than 10 micrometres (the “coarse” fraction) and 2.5 micrometres (the “fine” fraction) respectively. Fine particles tend to originate more from human activities than coarse particles. The scope of this study covers particulate matter between 2.5 and 10 micrometres (PM₁₀), referred to as dust throughout this document. The emissions of gaseous pollutants, such as sulphur dioxide (SO₂) and nitrogen oxides (NO_x), which are altered through chemical reaction in the atmosphere, are increasing particulate mass.

Ground-level ozone is formed in the atmosphere by a reaction between volatile organic compounds (VOC) and NO_x in the presence of sunlight. Ozone occurs naturally in the stratosphere and in the troposphere, but in those areas, it is formed by different chemical processes. Ozone in the stratosphere is valuable as it protects the ecosystem from ultraviolet radiation; however, tropospheric ozone near ground level is harmful to ecosystems and human health. Damage caused directly and indirectly by ground-level ozone is one of the most serious regional air pollution problems affecting agriculture in the EnC Contracting Parties.

Acidification of rains and, as a consequence, the contamination of lakes, rivers, forests and other ecosystems is mainly caused by emissions of SO₂, and NO_x. After a significant loss in fauna and flora, it may take several decades for an ecosystem to recover, even when acidifying inputs are reduced to sustainable levels.

Eutrophication is the response of the ecosystem to the addition of artificial or natural substances, such as nitrogen from NO_x. These substances which are also emitted from LCPs can lead to eutrophication further to their contribution of the formation of ground-level ozone that can damage forests, crops and vegetation.

Apart from harmful effects on human life and the environment, air pollution also has an impact on materials,

buildings and cultural heritage. The major effects on human health and the environment of the pollutants emitted by power and heat generation are presented in the table below.

Table 1: Multi-pollution/multi-effect review of air pollution from LCPs

| Effects | Pollutants | | |
|----------------------|------------|-----------------|-----------------|
| | Dust (PM) | SO ₂ | NO _x |
| Health effects: | | | |
| - Particulate matter | √ | √ | √ |
| - Ground-level ozone | | | √ |
| Vegetation effects: | | | |
| - Ground-level ozone | | | √ |
| - Acidification | | √ | √ |
| - Eutrophication | | | √ |

The Terms of Reference (ToR) for this study⁵ have highlighted that the implementation of the LCP Directive in the Energy Community is a high priority both politically and technically. As Contracting Parties to the Energy Community Treaty, all signatories have undertaken to implement the LCP Directive by 31 December 2017 as set out by Article 16 and Annex II of the Energy Community Treaty. It is important to note that the LCP Directive covers plants with a rated thermal input equal to or greater than 50 MW.

Implementation of the LCP Directive by the Contracting Parties, in compliance with the above-mentioned deadline, has to be supported by the Energy Community Secretariat (ECS) and its Task Force on Environment as the main body through which efforts are being coordinated. Contracting Parties have already provided information regarding their status of transposition and implementation of the LCP Directive which, however, fails short to demonstrate, on a number of occasions, that the deadline of the Treaty will be met.

At the Second and Third meetings of the Task Force on Environment (20 October 2011 and 23 May 2012, Vienna), a number of Contracting Parties reported that they are facing major challenges regarding the future implementation of the LCP Directive due to the investments needed for modernization and given existing inefficiencies. Furthermore, the Secretariat was invited to seek support for a preliminary compliance assessment regarding the current state of play in the Contracting Parties. The Secretariat reached the conclusion that such a preliminary compliance assessment could be harmonized with a structured analysis on the Contracting Parties' respective LCP sectors and the need for modernization of individual plants.

Having in mind the above, it can be concluded that the preparation of the Study on the Need for Modernization of Large Combustion Plants in the Contracting Parties of the Energy Community in the context of the implementation of the LCP Directive of high importance for all Contracting Parties and would serve as a point of reference for setting priorities.

⁵ Energy Community – Tender Documents for the Selection of a Consultant for the Study on the Need for Modernization of Large Combustion Plants in the Contracting Parties of the Energy Community in the context of the implementation of Directive 2001/80/EC, Vienna, 22 October 2012

Objectives and Scope of the Study

The Terms of Reference of this Study have defined the main and specific project objectives as follows.

Main objective

The main objective is to support governments, decision-makers, privately and publicly owned energy companies, private and public investors in their efforts to make Contracting Parties capable to meet their commitments under the Energy Community Treaty within the foreseen deadline. This can be achieved either by the modernization of large combustion plants, by changing fuels or by replacing plants by new capacities. The Consultant has developed a scenario for each of these options.

Specific objectives

The specific objectives of this study are as follows:

- To provide governments, companies and private and public investors with an accurate assessment of the investment needs on a plant-by-plant basis in order to meet the requirements of the LCP Directive in all Contracting Parties.
- To develop different scenarios for the individual plants in order to achieve compliance with the emission limit values of the LCP Directive. In this respect, possible measures (e.g. change of fuels, use of different abatement techniques, etc.); their technical feasibility/limitations and their costs (at a generic level, i.e. by using cost ranges or factors) shall be identified. For each of the plants concerned, these measures and combinations thereof can then be considered and their costs can be assessed in more detail. Measures affecting overall emissions that do not have an impact on meeting the emission limits (e.g. plant efficiency gains) shall also be considered in this respect.
- To develop a realistic investment need scenario at plant and Contracting Party level, taking into account the different modernization options explored as well as the alternative scenario of replacing capacity (by either fossil fuel fired plants or renewable energy sources).
- To examine the potential and the costs involved for achieving compliance with the emission limit values of Annex V of Directive 2010/75/EU on industrial emissions.

The objectives of this assignment had been clearly defined as providing assistance to the Energy Community Secretariat in order to achieve their commitments under the Energy Community Treaty taking into consideration a cost-effective and efficient implementation of the project.

To perform the assignment, in the inception phase the Consultant's experts have developed appropriate

questionnaires for data collection which have been approved by the Secretariat. The data lists have contained general technical data on the TPP and CHP units, the data on fuel used in the plants and the current emission values of the required pollutants (SO₂, NO_x and dust). The data lists included the main characteristics of the environmental upgrade systems, as well as the financial data of their implementation.

The approach and methodology was outlined in an Inception Report which was submitted to the Secretariat in January 2013. The choice of the environmental upgrade systems as well as the investment cost estimates has been based on the available national development and investment plans. However, in case there are neither national plans nor feasibility studies, the Consultant had used data on investment costs of the TPP environmental upgrade systems performed within the last decade. These data have been used for the range of thermal capacity, type of fuel, sulphur content, etc.

Scope of the Study

The services carried out within the framework of this project are divided into four main parts, as follows:

Inventory of combustion plants

During the inception phase of the project, the Consultant identified the different categories of combustion plants in each Contracting Party of the Energy Community, taking into consideration currently available data, based on their function and geographical location. Accordingly, the Consultant created a list of LCPs with a rated thermal input equal to or greater than 50 MW for each Contracting Party. These lists were sent to the Contracting Parties' authorities along with the questionnaire in order to have them peer-reviewed.

Data gathering

In order to verify and improve existing data, the Consultant prepared a questionnaire for each Contracting Party, asking for an update on the following information:

- General information on TPPs and CHPs;
- List of TPPs and CHPs with a rated thermal input equal to or greater than 50 MW;
- Technical data on TPP and CHP units.

Also, the Consultant gathered additional information on measures that would be needed to meet the requirements of the LCP Directive and the IED and the associated costs. These have been carried out by collecting information from existing literature and by carrying out interviews with relevant stakeholders (government officials, operators of large combustion plants, suppliers of abatement equipment and consultants in the region).

Estimation of costs and benefits

The Consultant delivered an estimate of the investment costs needed for the measures proposed according to the different scenarios and for each beneficiary for the period 2014-2018. Impacts of electricity and heat production on human health and the environment have been estimated as external costs.

Requirements of the LCPD and the IED

Requirements of Directive 2001/80/EC (LCPD)

Directive 2001/80/EC on the limitation of emissions of certain pollutants into the air from large combustion plants (LCP Directive) applies to combustion plants with a rated thermal input equal to or greater than 50 MW, irrespective of the type of fuel used (solid, liquid or gaseous). The Directive entered into force on 27 November 2001 in the EU.

The overall aim of the **LCP Directive** is to reduce emissions of acidifying pollutants, particles, and ozone precursors. Control of emissions from large combustion plants -- those whose rated thermal input is equal to or greater than 50 MW -- plays an important role in the European Union's efforts to combat acidification, eutrophication and ground-level ozone as part of the overall strategy to reduce air pollution.

The LCP Directive contains the following provisions (presented in Annex 5):

1. Plants licensed after 26 November 2002 have to comply with the (stricter) emission limit values for SO₂, NO_x and dust fixed in part B of the Annexes III to VII.
2. Plants licensed on or after 1 July 1987 and before 27 November 2002 have to comply with the (less strict) emission limit values fixed in part A of the Annexes III to VII.
3. Significant emission reductions from "existing plants" (licensed before 1 July 1987) are required to be achieved by 1 January 2008:
 - a) by individual compliance with the same emission limit values as established for the plants referred to in point 2 above or
 - b) through a national emission reduction plan (NERP) that achieves overall reductions calculated on the basis of those emission limit values.

The Commission considers that it is possible to adopt a "combined approach", i.e. combination of points a) and b) for these "existing plants". A NERP must address all three pollutants covered by the Directive for all the plants covered by the plan.⁶

⁶ <http://ec.europa.eu/environment/air/pollutants/stationary/lcp/legislation.htm>

To assist those Member States that choose the national emission reduction plan option as a means of compliance with the requirements for existing plants, the Commission has developed guidance⁷ for the preparation of these plans.

According to Annex VIII.B of the LCP Directive, Member States shall establish, starting in 2004 and for each subsequent year, an inventory of SO₂, NO_x and dust emissions from all combustion plants covered by the Directive with a rated thermal input of 50 MW or more. The inventory should include information on a plant-by-plant basis concerning the total annual emissions of SO₂, NO_x and dust (as total suspended particles) and the total annual amount of energy input, related to the net calorific value, broken down in terms of the five categories of fuel: biomass, other solid fuels, liquid fuels, natural gas, other gases. The yearly plant-by-plant data shall be made available to the Commission upon request.⁸

Under Article 4(4) of the LCP Directive, existing combustion plants may be exempted from compliance with the emission limit values and from their inclusion in the national emission reduction plan if they are not operated for more than 20,000 hours starting from 1 January 2008 and ending no later than 31 December 2015. A record of the used and unused time allowed for the plants' remaining operational life has to be submitted each year to the competent authority and Member States have to report this to the Commission.

In January 2006, the European Commission's Directorate-General for Environment informed all Member States about the interpretation of certain important aspects of the LCP Directive⁹:

- **Interpretation of the term "existing combustion plant"**. The Directive is clear that new combustion plants which share a common stack, or in the judgement of the competent authority could share a common stack, are to be regarded as a single plant for the purposes of the Directive. This means that their capacities are aggregated for the purpose of determining whether they fall under the scope of the Directive as well as the applicable emission limit values. Similarly, existing plants whose waste gases are de facto discharged through a common stack should be considered as a single plant. Therefore, when a group of boilers discharge their waste gases through a common stack, the term "existing combustion plant" should be interpreted as that group of boilers. However, this aggregation approach does not apply to existing plants which potentially could share a common stack, but as a matter of fact do not. In other words the requirement to consider the possibility of sharing a common stack where one is not currently used, taking technical and economic factors into account, only applies to new plant.

⁷ <http://eur-lex.europa.eu/LexUriServ/LexUriServ.do?uri=OJ:L:2003:016:0059:0067:EN:PDF>

⁸ A summary of inventories can be found at the European Environmental Agency's website:
<http://www.eea.europa.eu/data-and-maps/data/plant-by-plant-emissions-of-so2-nox-and-dust-and-energy-input-of-large-combustion-plants-covered-by-directive-2001-80-ec-1>

⁹ http://ec.europa.eu/environment/air/pollutants/stationary/lcp_interpretation.htm

- **Interpretation of the term "stack"**. The Directive uses the term "stack" which should not be confused with the term "flue". A "flue" is a compartment or division of a stack (or chimney) for conveying combustion gases to the outer air. A "stack" refers to the structure (providing a conduit for combustion gases) rising above roof level which may embody one or more "flues". As a result, a "common stack" cannot be interpreted as a "common flue".
- **Interpretation of the derogation in Article 4(4) of the Directive**. Article 4(4) allows a plant to be exempted from compliance with the emission limit values of the Directive or inclusion in a national emission reduction plan, provided that the operator undertakes not to operate the plant for more than 20,000 operational hours starting from 1 January 2008 and ending no later than 31 December 2015. After this time the plant must close. A plant is considered to be operating for the purposes of this derogation when any part of it operates, irrespective of the load factor. Therefore, when several boilers discharge their waste gases through a common stack, and any of these boilers operates at any load factor for, say, one hour, it will be considered that the whole plant is operating for one hour for the purposes of the derogation.
- **Conditions for combined approaches**. If a Member State decides to use a "combined approach", in view of the added complexity that this entails the Commission will request two lists of plants from the Member State: those that would be subject to ELVs; and those included in the plan. In addition, in order to ensure compliance with the emission limit values, the Commission will ask to receive every year from 2008 (or the year when the ELVs begin to apply) the inventory of emissions from those existing plants to which they apply. In order to confirm compliance with the targets of the plan, Member States are also strongly recommended to set up the annual national reporting system foreseen in the Commission Recommendation 2003/47/EC.

Requirements of Directive 2010/75/EU (IED)

The IED entered into force on 6 January 2011 and had to be transposed into national legislation by EU Member States by 7 January 2013.

The aim of IED is to achieve significant benefits to the environment and human health by reducing industrial emissions (including those emitted by installations from the energy sector) across the EU, in particular through a better use of the best available techniques (BAT).

The IED is based on several principles, namely: (1) an integrated approach, (2) best available techniques, (3) flexibility, (4) inspections and (5) public participation.

1. The **integrated approach** means that permits must take into account the whole environmental performance of the plant, covering its emissions to air, water and land, generation of waste, use of raw materials, energy efficiency, noise, prevention of and dealing with accidents and incidents as well as restoration of the site upon closure. The purpose of the Directive is to ensure a high level of protection of the environment as a whole.
2. The emission limit values (ELVs), must be based on the **best available techniques (BAT)**. BAT conclusions (documents containing information on the emission levels associated with the best available techniques) shall be the reference for setting permit conditions. To assist the licensing authorities and companies to determine BAT, the Commission organises an exchange of information between experts from the EU Member States, industry and environmental organisations.
3. The IED contains certain **elements of flexibility** by allowing the competent authorities to set less strict emission limit values in specific cases. Such measures are only applicable where an assessment shows that the achievement of emission levels associated with BAT, as described in the BAT conclusions, would lead to disproportionately higher costs compared to the environmental benefits due to (a) geographical location or the local environmental conditions or (b) the technical characteristics of the installation. The competent authority shall always document the reasons for the application of the flexibility measures in the permit including the result of the cost-benefit assessment. Moreover, Chapter III on large combustion plants includes certain flexibility instruments (Transitional National Plan, limited lifetime derogation, etc.)
4. The IED contains mandatory requirements on **environmental inspections**. Member States shall set up a system of environmental inspections and draw up inspection plans accordingly. The IED requires a site visit shall take place at least every 1 to 3 years, using risk-based criteria.
5. The **public has a right to participate** in the decision-making process, and to be informed of its consequences, by having access to:
 - (a) Permit applications in order to give opinions,
 - (b) Permits,
 - (c) Results of the monitoring of releases and
 - (d) The European Pollutant Release and Transfer Register (E-PRTR).

In E-PRTR, emission data reported by Member States are made accessible in a public register, which is intended to provide environmental information on major industrial activities. E-PRTR has replaced the previous EU-wide pollutant inventory, the so-called European Pollutant Emission Register (EPER).¹⁰

¹⁰ <http://ec.europa.eu/environment/air/pollutants/stationary/ied/legislation.htm>

2. Inventory of LCPs in the EnC Contracting Parties

2.1. Large combustion plants in Albania

There is only one thermal power plant in Albania after the closure and decommissioning of TPP Fier due to the fact that it was already beyond its planned operational lifetime as well as its inefficiency and its incapability to comply with emission standards.

The new TPP in Vlora is a 100 MW combined cycle gas turbine (CCGT) that uses natural gas or distillate fuel oil as a fuel. The plant had been in operation for a short period of time in 2012, after which it was closed down due to some technical failures in the cooling water offshore pipeline. It is planned that the plant will be put back in operation by the end of 2014.

The basic plant characteristics are high net power plant efficiency of 50.5 %, with the net specific heat consumption of 7,135 kJ/kWh. The plant is equipped with continuous emission monitoring system, which, during the short period of time in which the plant has been in operation so far, shows the following emission concentrations:

- Dust (PM) 1.3 mg/m³
- NO_x 67 mg/m³
- SO₂ 48 mg/m³.

The plant is designed according to the IED's emission standards and in case of the use of distillate oil as a fuel, it is required that it has a sulphur content of less than 0.1%.

2.2. Large combustion plants in Bosnia and Herzegovina

There are four large thermal power plants in Bosnia and Herzegovina, consisting of a total of 9 units. The total installed capacity is 1,775 MW. All units use lignite as a fuel. TPP Ugljevik, one of the LCPs located in Bosnia and Herzegovina, has the highest sulphur dioxide emission concentration in the EnC Contracting Parties. The basic data on the TPP units are presented in Table 2-1, together with the most important dates for TPP units (start-up, performed or planned rehabilitation, retirement plans), performed service time and load factor. Most units are over 30 years old, with service time in the range of 97,000–312,000 hours.

The pollutant emission concentrations in flue gases, at the present status of combustion chamber characteristics (BAU) are presented in Table 2-2, together with the furnace capacity and the requirements of the LCP and the IE Directives.

Measures to prevent emissions of particulate matter have been undertaken in most of the units of TPPs Tuzla and Kakanj and in some cases they satisfy not only LCPD but also the stronger IED emission standards. Regarding the reduction of NO_x, primary measures have been applied in all units of TPPs Tuzla and Kakanj. To date, no desulphurization measures have been implemented. Furthermore, TPP Tuzla 3 is scheduled for retirement in 2015 as well as TPP Kakanj 5 in 2019 and TPP Tuzla 4 and 5 in 2022 and 2024, respectively. TPP Ugljevik has started the implementation work for the desulfurization process.

Table 2-1: Basic characteristics of LCPs in Bosnia and Herzegovina

| Code | Plant name | Fuel type | Power MW | Energy GWh/a | Key dates | | | | | Service time /000h/ | Load factor /%/ | |
|-------|------------|-----------|----------|--------------|-----------|--------|----------------|-------|------|---------------------|-----------------|-----------------|
| | | | | | Start up | Rehab. | Env. upgrading | | | | | Retirement plan |
| | | | | | | | Dust | DeNox | FGD | | | |
| 1 | Gacko | L | 300 | 1,934 | 1983 | 2017 | 2000 | | | 2030 | 145 | 80 |
| 2 | Ugljevik | L | 300 | 2,176 | 1985 | 2015 | | | 2017 | 2025 | 145 | 90 |
| 3 | Tuzla 3 | L | 110 | 473 | 1966 | 2000 | | | | 2015 | 312 | 54 |
| 4 | Tuzla 4 | L | 200 | 1,196 | 1971 | 2002 | | | | 2018 | 199 | 75 |
| 5 | Tuzla 5 | L | 200 | 1,004 | 1974 | 2008 | | | | 2024 | 196 | 63 |
| 6 | Tuzla 6 | L | 215 | 1,008 | 1978 | 2013 | | | | 2030 | 186 | 59 |
| 7 | Kakanj 5 | L | 110 | 598 | 1969 | 2003 | | | | 2019 | 235 | 69 |
| 8 | Kakanj 6 | L | 110 | 312 | 1977 | 2012 | | | | 2027 | 177 | 36 |
| 9 | Kakanj 7 | L | 230 | 1,342 | 1988 | 2007 | | | | 2030 | 97 | 74 |
| Total | | | 1,775 | 10,044 | | | | | | | | |

Table 2-2: Emission concentrations of LCPs in Bosnia and Herzegovina

| Code | Plant name | Fuel type | Furnace input MW | Emission - BAU | | | Requirements LCPD | | | Requirements IED | | |
|-------|------------|-----------|------------------|----------------------------------|-----------------|-----------------|----------------------------------|-----------------|-----------------|----------------------------------|-----------------|-----------------|
| | | | | Concentration, mg/m ³ | | | Concentration, mg/m ³ | | | Concentration, mg/m ³ | | |
| | | | | Dust | NO _x | SO ₂ | Dust | NO _x | SO ₂ | Dust | NO _x | SO ₂ |
| 1 | Gacko | L | 770 | 250 | 600 | 1,500 | 50 | 200 | 400 | 20 | 200 | 200 |
| 2 | Ugljevik | L | 830 | 210 | 500 | 16,200 | 50 | 200 | 400 | 20 | 200 | 200 |
| 3 | Tuzla 3 | L | 310 | 25 | 312 | 1,594 | 100 | 600 | 1,160 | 20 | 200 | 200 |
| 4 | Tuzla 4 | L | 620 | 78 | 344 | 2,170 | 50 | 200 | 400 | 20 | 200 | 200 |
| 5 | Tuzla 5 | L | 620 | 56 | 180 | 1,895 | 50 | 200 | 400 | 20 | 200 | 200 |
| 6 | Tuzla 6 | L | 650 | 30 | 350 | 3,946 | 50 | 200 | 400 | 20 | 200 | 200 |
| 7 | Kakanj 5 | L | 330 | 11 | 1,036 | 7,831 | 100 | 600 | 1,080 | 20 | 200 | 200 |
| 8 | Kakanj 6 | L | 330 | 20 | 747 | 7,733 | 100 | 600 | 1,080 | 20 | 200 | 200 |
| 9 | Kakanj 7 | L | 670 | 173 | 794 | 7,833 | 50 | 200 | 400 | 20 | 200 | 200 |
| Total | | | 5,130 | | | | | | | | | |

2.3. Large combustion plants in Croatia

There are 9 thermal power plants in Croatia, with 17 TPP units (Table 2-3). The total installed capacity is 1,782 MW. The Plomin TPP, located at the Adriatic coast is a coal-fired plant using imported hard coal. Two plants (TPPs Rijeka and Sisak) are fired by fuel oil while all other TPPs use natural gas as a basic fuel. Environmental upgrading was carried out for several units and some are planned to be implemented before the end of 2017. One unit (TPP Plomin 1) shall be retired in 2017. No information has been provided on the number of hours spent in operation on a plant-by-plant basis.

Table 2-3: Basic characteristics of LCPs in Croatia

| Code | Plant name | Fuel type | Power MW | Energy GWh/a | Key dates | | | | | Service time /000h/ | Load factor /%/ | |
|------|--------------|-----------|----------|--------------|-----------|--------|----------------|-------|------|---------------------|-----------------|-----------------|
| | | | | | Start up | Rehab. | Env. upgrading | | | | | Retirement plan |
| | | | | | | | Dust | DeNox | FGD | | | |
| 1 | TPP Plomin 1 | HC | 125 | 915 | 1970 | | 1999 | | | 2017 | | 87 |
| 2 | TPP Plomin 2 | HC | 210 | 1,631 | 1999 | 2017 | | 2017 | 1999 | 2032 | | 97 |
| 3 | TPP Rijeka | FO | 320 | 1,725 | 1979 | 2017 | | 2005 | | 2028 | | 65 |

| Code | Plant name | Fuel type | Power MW | Energy GWh/a | Key dates | | | | | Service time /000h/ | Load factor /%/ | |
|-------|--------------------|-----------|----------|--------------|-----------|-------|----------------|-------|-----|---------------------|-----------------|-----------------|
| | | | | | Start up | Rehab | Env. upgrading | | | | | Retirement plan |
| | | | | | | | Dust | DeNox | FGD | | | |
| 4 | TPP Sisak A | FO | 210 | 1,214 | 1970 | | | 2003 | | 2020 | | 70 |
| 5 | TPP Sisak B | FO | 210 | 1,214 | 1976 | 2017 | | 2001 | | 2026 | | 70 |
| 6 | TPP Jertovac 1 | NG | 40 | 47 | 1975 | | | | | 2021 | | 17 |
| 7 | TPP Jertovac 2 | NG | 40 | 47 | 1975 | | | | | 2021 | | 17 |
| 8 | CHP Zagreb C | NG | 120 | 469 | 1979 | 2017 | | | | 2028 | | 46 |
| 9 | CHP Zagreb K | NG | 208 | 1,591 | 2001 | 2017 | | | | 2030 | | 90 |
| 10 | CHP Zagreb L | NG | 112 | 866 | 2011 | | | | | 2040 | | 91 |
| 11 | CHP Zagreb EL-TOK6 | NG | 11 | 21 | 1971 | 2017 | | 2015 | | 2020 | | 23 |
| 12 | CHP Zagreb EL-TOK8 | NG | 30 | 82 | 1980 | 2017 | | 2008 | | 2035 | | 32 |
| 13 | CHP Zagreb EL-TOH | NG | 25 | 161 | 1994 | 2017 | | | | 2025 | | 76 |
| 14 | CHP Zagreb EL-TOJ | NG | 25 | 161 | 1994 | 2017 | | | | 2025 | | 76 |
| 15 | CHP Osijek A | NG | 46 | 256 | 1985 | 2017 | | 2015 | | 2035 | | 65 |
| 16 | CHP Osijek B | NG | 25 | 42 | 1976 | | | | | 2020 | | 20 |
| 17 | CHP Osijek C | NG | 25 | 21 | 1976 | | | | | 2020 | | 10 |
| Total | | | 1,782 | 10,464 | | | | | | | | |

The emission concentrations in the flue gases are presented in Table 2-4, together with the furnace capacity and the requirements of the LCPD and the IED. The emission concentration of certain types of TPP units that use fuel oil as additional fuel shall be presented as fuel oil-fired units.

Table 2-4: Emission concentrations of LCPs in Croatia

| Code | Plant name | Fuel type | Furnace input MW | Emission - BAU | | | Requirements LCPD | | | Requirements IED | | | Notes |
|-------|---------------------|-----------|------------------|----------------------------------|-----------------|-----------------|----------------------------------|-----------------|-----------------|----------------------------------|-----------------|-----------------|--------|
| | | | | Concentration, mg/m ³ | | | Concentration, mg/m ³ | | | Concentration, mg/m ³ | | | |
| | | | | Dust | NO _x | SO ₂ | Dust | NO _x | SO ₂ | Dust | NO _x | SO ₂ | |
| 1 | TPP Plomin 1 | HC | 338 | 39 | 597 | 1,719 | 100 | 600 | 1,048 | 20 | 200 | 200 | |
| 2 | TPP Plomin 2 | HC | 544 | 22 | 357 | 165 | 50 | 200 | 400 | 20 | 200 | 200 | |
| 3 | TPP Rijeka | FO | 800 | 125 | 1,011 | 4,070 | 50 | 400 | 400 | 20 | 150 | 200 | |
| 4 | TPP Sisak A | FO | 548 | 112 | 751 | 3,701 | 50 | 400 | 400 | 20 | 150 | 200 | |
| 5 | TPP Sisak B | FO | 548 | 112 | 751 | 3,701 | 50 | 400 | 400 | 20 | 150 | 200 | |
| 6 | TPP Jertovac 1 | NG | 123 | | 257 | 7 | 5 | 300 | 35 | 5 | 100 | 35 | |
| 7 | TPP Jertovac 2 | NG | 123 | | 262 | 4 | 5 | 300 | 35 | 5 | 100 | 35 | |
| 8 | CHP Zagreb C | NG | 384 | 113 | 924 | 3,689 | 50 | 450 | 1,154 | 20 | 150 | 200 | For FO |
| 9 | CHP Zagreb K | NG | 410 | 5 | 31 | 5 | 5 | 300 | 35 | 5 | 100 | 35 | |
| 10 | CHP Zagreb L | NG | 214 | 5 | 22 | 2 | 5 | 300 | 35 | 5 | 100 | 35 | |
| 11 | CHP Zagreb EL-TOK6 | NG | 86 | 76 | 704 | 3,497 | 50 | 450 | 1,700 | 30 | 450 | 350 | For FO |
| 12 | CHP Zagreb EL-TO K8 | NG | 86 | 266 | 596 | 3,657 | 50 | 450 | 1,700 | 30 | 450 | 350 | For FO |
| 13 | CHP Zagreb EL-TO H | NG | 91 | | 272 | 7 | 5 | 300 | 35 | 5 | 100 | 35 | |
| 14 | CHP Zagreb EL-TO J | NG | 91 | | 237 | 12 | 5 | 300 | 35 | 5 | 100 | 35 | |
| 15 | CHP Osijek A | NG | 139 | 5 | 260 | 18 | 5 | 300 | 35 | 5 | 100 | 35 | |
| 16 | CHP Osijek B | NG | 88 | 0 | 234 | 17 | 5 | 300 | 35 | 5 | 100 | 35 | |
| 17 | CHP Osijek C | NG | 88 | 0 | 234 | 17 | 5 | 300 | 35 | 5 | 100 | 35 | |
| Total | | | 4,701 | | | | | | | | | | |

2.4. Large combustion plants in FYR Macedonia

FYR Macedonia has three thermal power plants (two lignite-fired and one fuel oil-fired plant), installed between 1978 and 1988 and two CHP units fired by natural gas that were installed in 2011 (Table 2-5). The total installed capacity is 1,291 MW. While plant and main equipment rehabilitation is in progress, environmental upgrading for TPP Bitola and Oslomej is planned for the period 2012-2016. The plants have been in service for 150,000–190,000 hours, with the exception of TPP Negotino which has only been in operation for 30,000 hours so far, mainly due to high fuel costs that reduce its load factor nearly to zero. The new CHPs have been in operation for a short period of time in the course of 2012.

Table 2-5: Basic characteristics of LCPs in FYR Macedonia

| Code | Plant name | Fuel type | Power MW | Energy GWh/a | Key dates | | | | | | Service time /000h/ | Load factor %/ |
|-------|------------|-----------|----------|--------------|-----------|--------|----------------|-------|-----|-----------------|---------------------|----------------|
| | | | | | Start up | Rehab. | Env. upgrading | | | Retirement plan | | |
| | | | | | | | Dust | DeNox | FGD | | | |
| 1 | Bitola 1 | L | 233 | 1,387 | 1982 | 2013 | | 2014 | | 2027 | 190 | 74 |
| 2 | Bitola 2 | L | 233 | 1,387 | 1984 | 2014 | | 2013 | | 2028 | 180 | 74 |
| 3 | Bitola 3 | L | 233 | 1,387 | 1988 | 2012 | | 2012 | | 2029 | 150 | 74 |
| 4 | Oslomej | L | 125 | 604 | 1980 | 2012 | | 2012 | | 2027 | 170 | 60 |
| 5 | Negotino | FO | 210 | 17 | 1978 | | | | | 2020 | 30 | 1 |
| 6 | Skopje CHP | NG | 227 | 1,394 | 2011 | | | | | | 3 | 74 |
| 7 | Kogel CHP | NG | 30 | 185 | 2011 | | | | | | 3 | 74 |
| Total | | | | 1,291 | 6,362 | | | | | | | |

The emission concentrations in the flue gases are presented in Table 2-6. All plants have excessive emissions of pollutants, with the exception of TPP Negotino, which is not in regular service due to a lower power demand and a lack of fuel oil. The emission of dust is between 400 and 640 mg/m³, the emission of NO_x is over 800 mg/m³, while the emission of SO₂ is between 4,000 and 5,000 mg/m³. The new gas-fired CHP units should satisfy both LCP and IE Directives; however, no measurements have been performed with the use of natural gas so far.

Table 2-6: Emission concentrations of LCPs in FYR Macedonia

| Code | Plant name | Fuel type | Furnace input MW | Emission - BAU | | | Requirements LCPD | | | Requirements IED | | |
|-------|--------------------------|-----------|------------------|----------------------------------|-----------------|-----------------|----------------------------------|-----------------|-----------------|----------------------------------|-----------------|-----------------|
| | | | | Concentration, mg/m ³ | | | Concentration, mg/m ³ | | | Concentration, mg/m ³ | | |
| | | | | Dust | NO _x | SO ₂ | Dust | NO _x | SO ₂ | DUST | NO _x | SO ₂ |
| 1 | Bitola 1 | L | 647 | 370 | 810 | 4,800 | 50 | 200 | 400 | 20 | 200 | 200 |
| 2 | Bitola 2 | L | 647 | 640 | 820 | 3,900 | 50 | 200 | 400 | 20 | 200 | 200 |
| 3 | Bitola 3 | L | 647 | 640 | 820 | 3,900 | 50 | 200 | 400 | 20 | 200 | 200 |
| 4 | Oslomej | L | 334 | 570 | 360 | 4,100 | 100 | 600 | 1,064 | 20 | 200 | 200 |
| 5 | Negotino | FO | 656 | | | | 50 | 400 | 400 | 20 | 150 | 200 |
| 6 | Skopje CHP ¹⁾ | NG | 412 | 10 | 160 | 1 | 5 | 300 | 35 | 5 | 100 | 35 |
| 7 | Kogel CHP ¹⁾ | NG | 65 | 10 | 160 | 1 | 5 | 300 | 35 | 5 | 100 | 35 |
| Total | | | | 3,408 | | | | | | | | |

¹⁾ Emission concentration have been measured in case of HFO use

2.5. Large combustion plants in Moldova

Thermal power plants in Moldova use natural gas as the main fuel. There are two LCPs, containing eight units, with a total installed capacity of 306 MW (Table 2-7). The first plant (CET-1) consists of five TPP units with capacities between 5 and 27 MW that are connected to a common stack. Therefore, their combined rated thermal input will be above 50 MW and would fall under the scope of the LCP and IE Directives. All units are designed for the combined generation of heat and power (CHP). The oldest unit was commissioned in 1951 and the last one was started up in 1977. All units have operated between 180,000 and 250,000 hours.

Apart from these units, there are some TPPs in the Transnistrian region that has an uncertain administrative status. The plants have a total installed capacity of 2,520 MW and produce electricity, which is imported to the main part of Moldova.

The emission concentrations in the flue gases are presented in Table 2-8, together with the EU emission standards. It appears that the current emission levels meet the requirements of the LCPD, while in some units it

slightly exceeds the IED requirements. The furnace inputs for CET-1 are estimated, as there were no precise data available. The CHP-1 has one common stack, while the CHP-2 has two stacks, which is taken into account when the ELVs are applied.

Table 2-7: Basic characteristics of LCPs in Moldova

| Code | Plant name | Fuel type | Pow. MW | Energy GWh/a | Key dates | | | | | Service time /000h/ | Load factor %/ | Notes | |
|-------|------------|-----------|---------|--------------|-----------|--------|----------------|-----------------|-----|---------------------|-----------------|---------------------|-----------------|
| | | | | | Start up | Rehab. | Env. upgrading | | | | | | Retirement plan |
| | | | | | | | Dust | NO _x | FGD | | | | |
| 1 | CET-1, No1 | NG | 12 | 59 | 1951 | 2008 | | | | 249 | 60 ¹ | ¹ Estim. | |
| 2 | CET-1, No2 | NG | 12 | 59 | 1956 | 2004 | | | | 227 | 60 ¹ | ¹ Estim. | |
| 3 | CET-1, No3 | NG | 10 | 49 | 1959 | 2005 | | | | 239 | 60 ¹ | ¹ Estim. | |
| 4 | CET-1, No4 | NG | 27 | 132 | 1961 | 2006 | | | | 190 | 60 ¹ | ¹ Estim | |
| 5 | CET-1, No5 | NG | 5 | 24 | 1961 | 2007 | | | | 191 | 60 ¹ | ¹ Estim | |
| 6 | CET-2, No1 | NG | 80 | 398 | 1977 | 2015 | | | | 198 | 61 | | |
| 7 | CET-2, No2 | NG | 80 | 371 | 1977 | 2014 | | | | 187 | 57 | | |
| 8 | CET-2, No3 | NG | 80 | 371 | 1977 | 2013 | | | | 179 | 57 | | |
| Total | | | 306 | 1,463 | | | | | | | | | |

Table 2-8: Emission Concentrations of LCPs in Moldova

| Code | Plant name | Fuel type | Furnace input ^{*)} MW | Emission - BAU | | | Requirements LCPD | | | Requirements IED | | |
|-------|------------|-----------|--------------------------------|----------------------------------|-----------------|-----------------|----------------------------------|-----------------|-----------------|----------------------------------|-----------------|-----------------|
| | | | | Concentration, mg/m ³ | | | Concentration, mg/m ³ | | | Concentration, mg/m ³ | | |
| | | | | Dust | NO _x | SO ₂ | Dust | NO _x | SO ₂ | Dust | NO _x | SO ₂ |
| 1 | CET-1, No1 | NG | 40 | | 96 | | 5 | 300 | 35 | 5 | 100 | 35 |
| 2 | CET-1, No2 | NG | 40 | | 113 | | 5 | 300 | 35 | 5 | 100 | 35 |
| 3 | CET-1, No3 | NG | 34 | | 115 | | 5 | 300 | 35 | 5 | 100 | 35 |
| 4 | CET-1, No4 | NG | 91 | | 97 | | 5 | 300 | 35 | 5 | 100 | 35 |
| 5 | CET-1, No5 | NG | 18 | | 72 | | 5 | 300 | 35 | 5 | 100 | 35 |
| 6 | CET-2, No1 | NG | 357 | | 137 | | 5 | 300 | 35 | 5 | 100 | 35 |
| 7 | CET-2, No2 | NG | 357 | | 155 | | 5 | 200 | 35 | 5 | 100 | 35 |
| 8 | CET-2, No3 | NG | 357 | | 142 | | 5 | 200 | 35 | 5 | 100 | 35 |
| Total | | | 1,294 | | | | | | | | | |

^{*)} CET-1 with one common stack, CET-2 No2 and No3 with one common stack

2.6. Large combustion plants in Montenegro

Montenegro has one 219 MW coal-fired TPP unit, commissioned in 1982 and rehabilitated in 2009. Its decommissioning is envisaged for 2025. Despite the fact that its electrostatic precipitators were retrofitted in 2009, it still has emission concentrations of NO_x and SO₂ that exceed the ELVs of the LCPD (Table 2-10).

Table 2-9: Basic characteristics of LCPs in Montenegro

| Code | Plant name | Fuel type | Power MW | Energy GWh/a | Key dates | | | | | Service time /000h/ | Load factor %/ | |
|-------|------------|-----------|----------|--------------|-----------|--------|----------------|-------|-----|---------------------|----------------|-----------------|
| | | | | | Start up | Rehab. | Env. upgrading | | | | | Retirement plan |
| | | | | | | | Dust | DeNox | FGD | | | |
| 1 | Pljevlja | L | 219 | 1,489 | 1982 | 2009 | | 2001 | | 2025 | | 85 |
| Total | | | 219 | 1,489 | | | | | | | | |

Table 2-10: Emission concentrations of LCPs in Montenegro

| Code | Plant name | Fuel type | Furnace input MW | Emission - BAU | | | Requirements LCPD | | | Requirements IED | | |
|-------|------------|-----------|------------------|----------------------------------|-----------------|-----------------|----------------------------------|-----------------|-----------------|----------------------------------|-----------------|-----------------|
| | | | | Concentration, mg/m ³ | | | Concentration, mg/m ³ | | | Concentration, mg/m ³ | | |
| | | | | Dust | NO _x | SO ₂ | Dust | NO _x | SO ₂ | Dust | NO _x | SO ₂ |
| 1 | Pljevlja | L | 516 | 30 | 450 | 6,000 | 50 | 200 | 400 | 20 | 200 | 200 |
| Total | | | 516 | | | | | | | | | |

2.7. Large combustion plants in Serbia

There are 9 thermal power plants in Serbia, consisting of 22 units. Eighteen units are coal-fired and four units are fired by natural gas. The total installed capacity is 4,679 MW and the power production is 26,240 GWh/year (see Table 2-11). Some units are in operation from 1957 and the newest one was put into operation in 1991. The coal-fired units have operated between 113,000 and 378,000 hours, while the natural gas-/oil-fired units have spent considerably less time in operation, primarily due to the shortage of fuel and lower electricity demand.

Table 2-11: Basic characteristics of LCPs in Serbia

| Code | Plant name | Fuel type | Power MW | Energy GWh/a | Key dates | | | | | Service time /000h/ | Load factor %/ | |
|-------|-----------------|-----------|----------|--------------|-----------|--------|----------------|-----------------|------|---------------------|----------------|-----------------|
| | | | | | Start up | Rehab. | Env. upgrading | | | | | Retirement plan |
| | | | | | | | Dust | NO _x | FGD | | | |
| 1 | Nikola Tesla A1 | L | 210 | 1,231 | 1970 | | 2006 | | | 2020 | 274 | 73.6 |
| 2 | Nikola Tesla A2 | L | 210 | 1,198 | 1970 | | 2005 | | | 2022 | 288 | 71.6 |
| 3 | Nikola Tesla A3 | L | 305 | 1,923 | 1976 | | 2014 | | 2018 | | 225 | 78.4 |
| 4 | Nikola Tesla A4 | L | 309 | 1,989 | 1978 | | 2007 | 2012 | 2017 | | 226 | 81.1 |
| 5 | Nikola Tesla A5 | L | 309 | 1,999 | 1979 | | 2004 | | | | 221 | 81.5 |
| 6 | Nikola Tesla A6 | L | 309 | 1,987 | 1979 | | 2010 | | | | 195 | 81.0 |
| 7 | Nikola Tesla B1 | L | 620 | 4,151 | 1983 | | 2012 | | 2018 | | 218 | 81.7 |
| 8 | Nikola Tesla B2 | L | 620 | 4,004 | 1985 | | 2011 | | 2019 | | 203 | 78.8 |
| 9 | Kolubara 1 | L | 32 | 175 | 1956 | | | | | 2017 | 378 | 68.9 |
| 10 | Kolubara 2 | L | 32 | 116 | 1957 | | | | | 2017 | 330 | 45.5 |
| 11 | Kolubara 3 | L | 64 | 135 | 1961 | | | | | 2018 | 296 | 26.5 |
| 12 | Kolubara 4 | L | 32 | 0 | 1961 | | | | | 2009 | 281 | 0.0 |
| 13 | Kolubara 5 | L | 110 | 626 | 1979 | | 2009 | | | 2019 | 150 | 71.5 |
| 14 | Morava | L | 125 | 566 | 1969 | | 2015 | | | 2020 | 214 | 59.8 |
| 15 | Kostolac A1 | L | 100 | 560 | 1967 | | 2006 | | | 2020 | 275 | 71 |
| 16 | Kostolac A2 | L | 210 | 1,196 | 1980 | | 2006 | | | 2024 | 168 | 71.5 |
| 17 | Kostolac B1 | L | 348 | 1,937 | 1987 | | 2014 | | 2014 | | 141 | 69.1 |
| 18 | Kostolac B2 | L | 348 | 1,895 | 1991 | | 2012 | | 2014 | | 113 | 67.6 |
| 19 | Novi Sad 1 | NG | 135 | 189 | 1981 | | | | | | 98 | 20 |
| 20 | Novi Sad 2 | NG | 110 | 175 | 1984 | | | | | | 63 | 20 |
| 21 | Zrenjanin | NG | 110 | 66 | 1989 | 2010 | | | | | 30 | 10 |
| 22 | Sr. Mitrovica 1 | NG | 32 | 123 | 1979 | | | | | | 118 | 50 |
| Total | | | 4,679 | 26,240 | | | | | | | | |

Within the above table, the retirement plan is given approximately and in view of larger investments for the rehabilitation of TPP units, the closure date can be significantly postponed. Also, the retirement dates will strongly depend on the investments plan for the constructions of new LCPs.

The emission concentrations in the flue gases are presented in Table 2-12. In certain TPP units, emissions of particulate matter have been reduced by replacing the electrostatic precipitators, in accordance with the LCPD standards. Other TPPs are planned to be retrofitted in the coming years. Regarding the reduction of NO_x and SO₂, certain preparatory works are ongoing for installing new equipment based on the best available techniques.

Table 2-12: Emission concentrations of LCPs in Serbia

| Code | Plant name | Fuel type | Furnace input MW | Emission - BAU | | | Requirements LCPD | | | Requirements IED | | |
|------|-----------------|-----------|------------------|----------------------------------|-----------------|-----------------|----------------------------------|-----------------|-----------------|----------------------------------|-----------------|-----------------|
| | | | | Concentration, mg/m ³ | | | Concentration, mg/m ³ | | | Concentration, mg/m ³ | | |
| | | | | Dust | NO _x | SO ₂ | Dust | NO _x | SO ₂ | Dust | NO _x | SO ₂ |
| 1 | Nikola Tesla A1 | L | 638 | 143 | 392 | 1,997 | 50 | 200 | 400 | 20 | 200 | 200 |
| 2 | Nikola Tesla A2 | L | 638 | 143 | 392 | 1,997 | 50 | 200 | 400 | 20 | 200 | 200 |
| 3 | Nikola Tesla A3 | L | 907 | 143 | 392 | 1,997 | 50 | 200 | 400 | 20 | 200 | 200 |
| 4 | Nikola Tesla A4 | L | 907 | 38 | 428 | 2,031 | 50 | 200 | 400 | 20 | 200 | 200 |
| 5 | Nikola Tesla A5 | L | 907 | 38 | 428 | 2,031 | 50 | 200 | 400 | 20 | 200 | 200 |

| Code | Plant name | Fuel type | Furnace input MW | Emission - BAU | | | Requirements LCPD | | | Requirements IED | | |
|-------|-----------------|-----------|------------------|----------------------------------|-----------------|-----------------|----------------------------------|-----------------|-----------------|----------------------------------|-----------------|-----------------|
| | | | | Concentration, mg/m ³ | | | Concentration, mg/m ³ | | | Concentration, mg/m ³ | | |
| | | | | Dust | NO _x | SO ₂ | Dust | NO _x | SO ₂ | Dust | NO _x | SO ₂ |
| 6 | Nikola Tesla A6 | L | 907 | 38 | 428 | 2,031 | 50 | 200 | 400 | 20 | 200 | 200 |
| 7 | Nikola Tesla B1 | L | 1,755 | 41 | 450 | 2,081 | 50 | 200 | 400 | 20 | 200 | 200 |
| 8 | Nikola Tesla B2 | L | 1,755 | 41 | 450 | 2,081 | 50 | 200 | 400 | 20 | 200 | 200 |
| 9 | Kolubara 1 | L | 126 | 1,243 | 399 | 2,423 | | | | | | |
| 10 | Kolubara 2 | L | 126 | 1,243 | 399 | 2,423 | | | | | | |
| 11 | Kolubara 3 | L | 251 | 1,243 | 399 | 2,423 | 100 | 600 | 2,000 | 30 | 450 | 400 |
| 12 | Kolubara 4 | L | 126 | | | | | | | | | |
| 13 | Kolubara 5 | L | 373 | 58 | 409 | 2,376 | 100 | 600 | 907 | 20 | 200 | 200 |
| 14 | Morava | L | 382 | 1,161 | 535 | 3,897 | 100 | 600 | 870 | 20 | 200 | 200 |
| 15 | Kostolac A1 | L | 303 | 418 | 397 | 6,211 | 100 | 600 | 1,187 | 20 | 200 | 200 |
| 16 | Kostolac A2 | L | 643 | 112 | 381 | 6,183 | 50 | 200 | 400 | 20 | 200 | 200 |
| 17 | Kostolac B1 | L | 1,037 | 600 | 561 | 6,329 | 50 | 200 | 400 | 20 | 200 | 200 |
| 18 | Kostolac B2 | L | 1,037 | 265 | 511 | 5,758 | 50 | 200 | 400 | 20 | 200 | 200 |
| 19 | Novi Sad 1 | NG | 372 | 6 | 933 | 154 | 5 | 300 | 35 | 5 | 100 | 35 |
| 20 | Novi Sad 2 | NG | 341 | 6 | 933 | 154 | 5 | 300 | 35 | 5 | 100 | 35 |
| 21 | Zrenjanin | NG | 385 | 6 | 933 | 154 | 5 | 300 | 35 | 5 | 100 | 35 |
| 22 | Sr. Mitrovica 1 | NG | 26 | 0 | 418 | 0 | 5 | 300 | 35 | 5 | 100 | 35 |
| Total | | | 13,943 | | | | | | | | | |

2.8. Large combustion plants in Ukraine

There are 15 thermal power plants in Ukraine consisting of 101 units and 9 CHP plants with a total of 12 units. The TPP plants have 93 coal-fired units, with a total capacity of 21,853 MW and 8 gas-fired units, with a total capacity of 5,400 MW. The CHP plants have 4 coal-fired units, with a total capacity of 404 MW and 8 gas-fired units, with a total capacity of 1,711 MW. The total installed capacity is 29,368 MW and electricity production is 88,669 GWh/year. The TPP units are generally old, with operational time of more than 200,000 hours (in certain cases, more than 300,000 hours). The oldest TPP unit was commissioned in 1959 while the newest one was commissioned in 1988. In several TPP units, emissions of dust (particulate matter) have been reduced and there are similar plans for other units as well. Furthermore, there are plans for construction of pilot projects for the reduction of NO_x and SO₂ according to the requirements of the LCPD. After gaining experience from the pilot projects, the necessary plans shall be made for the implementation of BAT in other TPP and CHP units.

Table 2-13 Basic characteristics of LCPs in Ukraine

| Code | Plant name | Fuel type | Power MW | Energy GWh/a | Key dates | | | | | Service time /000h/ | Load factor %/ | |
|------|-----------------|-----------|----------|--------------|-----------|--------|----------------|-----------------|-----|---------------------|----------------|-----------------|
| | | | | | Start up | Rehab. | Env. upgrading | | | | | Retirement plan |
| | | | | | | | Dust | NO _x | FGD | | | |
| 1 | Prydniprovsk 7 | HC | 150 | 439 | 1959 | | | | | 320 | 38 | |
| 2 | Prydniprovsk 8 | HC | 150 | 682 | 1960 | | | | | 340 | 59 | |
| 3 | Prydniprovsk 9 | HC | 150 | 0 | 1060 | 2012 | | | | 306 | | |
| 4 | Prydniprovsk 10 | HC | 150 | 590 | 1961 | | | | | 318 | 51 | |
| 5 | Prydniprovsk 11 | HC | 310 | 1,186 | 1963 | 2017 | | | | 255 | 48 | |
| 6 | Prydniprovsk 12 | HC | 285 | 0 | 1964 | | | | | | | |
| 7 | Prydniprovsk 13 | HC | 285 | 774 | 1964 | 2016 | | | | 222 | 34 | |
| 8 | Prydniprovsk 14 | HC | 285 | 0 | 1965 | 2015 | | | | 290 | | |
| 9 | Kryvorizka 1 | HC | 282 | 1,106 | 1965 | 2013 | | | | 296 | 48 | |
| 10 | Kryvorizka 2 | HC | 282 | 1,382 | 1966 | 2018 | | | | 296 | 60 | |
| 11 | Kryvorizka 3 | HC | 282 | 0 | 1966 | 2012 | | | | 254 | | |
| 12 | Kryvorizka 4 | HC | 282 | 1,221 | 1968 | 2017 | | | | 233 | 53 | |
| 13 | Kryvorizka 5 | HC | 282 | 1,221 | 1968 | 2015 | | | | 278 | 53 | |
| 14 | Kryvorizka 6 | HC | 282 | 714 | 1969 | 2016 | | | | 240 | 31 | |
| 15 | Kryvorizka 7 | HC | 282 | 0 | 1970 | | | | | | | |
| 16 | Kryvorizka 8 | HC | 282 | 1,014 | 1970 | | | | | 190 | 44 | |

| Code | Plant name | Fuel type | Power MW | Energy GWh/a | Key dates | | | | | Service time /000h/ | Load factor %/ | |
|------|-------------------|-----------|----------|--------------|-----------|--------|----------------|------|------|---------------------|----------------|-----------------|
| | | | | | Start up | Rehab. | Env. upgrading | | | | | Retirement plan |
| | | | | | | | Dust | NOx | FGD | | | |
| 17 | Kryvorizka 9 | HC | 282 | 0 | 1972 | 2014 | | | | 249 | | |
| 18 | Kryvorizka 10 | HC | 282 | 1,198 | 1973 | | | | | 179 | 52 | |
| 19 | Zaporiska 1 | HC | 325 | 1,048 | 1972 | 2012 | 2012 | | | 256 | 40 | |
| 20 | Zaporiska 2 | HC | 300 | 1,277 | 1972 | 2016 | 2016 | | | 251 | 53 | |
| 21 | Zaporiska 3 | HC | 300 | 1,301 | 1972 | 2014 | 2014 | | | 258 | 54 | |
| 22 | Zaporiska 4 | HC | 300 | 1,205 | 1973 | 2015 | 2015 | | | 238 | 50 | |
| 23 | Zaporiska 5 | NG | 800 | 0 | 1975 | | | | | 149 | | |
| 24 | Zaporiska 6 | NG | 800 | 0 | 1976 | | | | | 127 | | |
| 25 | Zaporiska 7 | NG | 800 | 0 | 1977 | | | | | 133 | | |
| 26 | Starobeshivska 4 | HC | 175 | 715 | 1961 | | | | | | | |
| 27 | Starobeshivska 5 | HC | 175 | 715 | 1962 | | | | | | 50 | |
| 28 | Starobeshivska 6 | HC | 175 | 715 | 1962 | | | | | | 50 | |
| 29 | Starobeshivska 7 | HC | 175 | 715 | 1963 | | | | | | | |
| 30 | Starobeshivska 8 | HC | 175 | 715 | 1963 | | | | | | 50 | |
| 31 | Starobeshivska 9 | HC | 175 | 715 | 1964 | | | | | | 50 | |
| 32 | Starobeshivska 10 | HC | 175 | 715 | 1965 | | | | | | 50 | |
| 33 | Starobeshivska 11 | HC | 175 | 715 | 1965 | | | | | | 50 | |
| 34 | Starobeshivska 12 | HC | 175 | 715 | 1966 | | | | | | 50 | |
| 35 | Starobeshivska 13 | HC | 175 | 715 | 1967 | | | | | | 50 | |
| 36 | Slovianska 7 | HC | 800 | 3,269 | 1971 | | | | | | 50 | |
| 37 | Burshtynska 1 | HC | 195 | 915 | 1965 | | | | | 275 | 59 | |
| 38 | Burshtynska 2 | HC | 185 | 397 | 1965 | | | | | 252 | 27 | |
| 39 | Burshtynska 3 | HC | 185 | 662 | 1966 | | | | | 272 | 45 | |
| 40 | Burshtynska 4 | HC | 195 | 884 | 1966 | | | | | 291 | 57 | |
| 41 | Burshtynska 5 | HC | 195 | 465 | 1977 | | 2013 | | | 286 | 30 | |
| 42 | Burshtynska 6 | HC | 185 | 986 | 1977 | | | | | 284 | 67 | |
| 43 | Burshtynska 7 | HC | 185 | 508 | 1988 | | 2012 | | | 268 | 31 | |
| 44 | Burshtynska 8 | HC | 195 | 806 | 1988 | | 2016 | | | 287 | 52 | |
| 45 | Burshtynska 9 | HC | 195 | 961 | 1988 | | 2007 | | | 269 | 62 | |
| 46 | Burshtynska 10 | HC | 195 | 930 | 1969 | | 2006 | | | 281 | 60 | |
| 47 | Burshtynska 11 | HC | 195 | 992 | 1969 | | 2005 | | | 245 | 64 | |
| 48 | Burshtynska 12 | HC | 195 | 667 | 1969 | | 2018 | | | 239 | 43 | |
| 49 | Dobrotvirska 5 | HC | 100 | 402 | 1960 | | | | | 322 | 51 | |
| 50 | Dobrotvirska 6 | HC | 100 | 402 | 1961 | | | | | 315 | 51 | |
| 51 | Dobrotvirska 7 | HC | 150 | 786 | 1963 | 2013 | | | | 326 | 65 | |
| 52 | Dobrotvirska 8 | HC | 150 | 568 | 1964 | 2014 | | | | 304 | 47 | |
| 53 | Ladyzhinska 1 | HC | 300 | 874 | 1970 | | | | | 231 | 36 | |
| 54 | Ladyzhinska 2 | HC | 300 | 1,092 | 1971 | 2018 | 2018 | | | 223 | 45 | |
| 55 | Ladyzhinska 3 | HC | 300 | 1,262 | 1971 | 2019 | 2019 | | | 210 | 52 | |
| 56 | Ladyzhinska 4 | HC | 300 | 752 | 1971 | 2015 | 2015 | | | 225 | 31 | |
| 57 | Ladyzhinska 5 | HC | 300 | 582 | 1971 | 2016 | 2016 | | | 210 | 24 | |
| 58 | Ladyzhinska 6 | HC | 300 | 558 | 1971 | 2017 | 2017 | | | 223 | 23 | |
| 59 | Trypilska 1 | HC | 300 | 1,250 | 1969 | | 2005 | | | 275 | 51 | |
| 60 | Trypilska 2 | HC | 300 | 1,250 | 1970 | 2014 | 2014 | 2014 | 2014 | 276 | 51 | |
| 61 | Trypilska 3 | HC | 300 | 1,250 | 1970 | | | | | 280 | 51 | |
| 62 | Trypilska 4 | HC | 300 | 1,250 | 1970 | | | | | 272 | 51 | |
| 63 | Trypilska 5 | NG | 300 | 0 | 1971 | | | | | | | |
| 64 | Trypilska 6 | NG | 300 | 0 | 1972 | | | | | | | |
| 65 | Zmiiivska 1 | HC | 175 | 548 | 1960 | | 2015 | | 2015 | 312 | 38 | |
| 66 | Zmiiivska 2 | HC | 175 | 548 | 1961 | | | | | 311 | 38 | |
| 67 | Zmiiivska 3 | HC | 175 | 548 | 1962 | | | | | 280 | 38 | |
| 68 | Zmiiivska 4 | HC | 175 | 548 | 1963 | | | | | 295 | 38 | |
| 69 | Zmiiivska 5 | HC | 175 | 548 | 1964 | | | | | 293 | 38 | |
| 70 | Zmiiivska 6 | HC | 175 | 548 | 1965 | | | | | 287 | 38 | |
| 71 | Zmiiivska 7 | HC | 275 | 793 | 1966 | | | | | 252 | 35 | |
| 72 | Zmiiivska 8 | HC | 325 | 937 | 1968 | 2005 | | | | 265 | 35 | |
| 73 | Zmiiivska 9 | HC | 275 | 793 | 1969 | | | | | 239 | 35 | |
| 74 | Zmiiivska 10 | HC | 275 | 793 | 1969 | | | | | 258 | 35 | |
| 75 | Vuglegirska 1 | HC | 300 | 1,359 | 1972 | | | | | | 55 | |
| 76 | Vuglegirska 2 | HC | 300 | 1,359 | 1973 | | | | | | 55 | |
| 77 | Vuglegirska 3 | HC | 300 | 1,359 | 1973 | | | | | | 55 | |
| 78 | Vuglegirska 4 | HC | 300 | 1,359 | 1973 | | | | | | 55 | |
| 79 | Vuglegirska 5 | NG | 800 | 0 | 1975 | | | | | | | |

| Code | Plant name | Fuel type | Power MW | Energy GWh/a | Key dates | | | | | Service time /000h/ | Load factor /%/ | |
|-------|--------------------|-----------|----------|--------------|-----------|--------|----------------|-----|-----|---------------------|-----------------|-----------------|
| | | | | | Start up | Rehab. | Env. upgrading | | | | | Retirement plan |
| | | | | | | | Dust | NOx | FGD | | | |
| 80 | Vuglegirska 6 | NG | 800 | 0 | 1976 | | | | | | | |
| 81 | Vuglegirska 7 | NG | 800 | 0 | 1977 | | | | | | | |
| 82 | Zuevvskaia 1 | HC | 325 | 1,606 | 1982 | 2015 | | | | 179 | 60 | |
| 83 | Zuevvskaia 2 | HC | 320 | 1,660 | 1982 | 2014 | | | | 175 | 63 | |
| 84 | Zuevvskaia 3 | HC | 300 | 1,606 | 1986 | 2013 | | | | 159 | 65 | |
| 85 | Zuevvskaia 4 | HC | 325 | 1,740 | 1988 | 2012 | | | | 144 | 65 | |
| 86 | Kurakhovskaya 3 | HC | 200 | 1,005 | 1972 | 2016 | | | | 264 | 61 | |
| 87 | Kurakhovskaya 4 | HC | 210 | 1,003 | 1973 | 2015 | | | | 244 | 58 | |
| 88 | Kurakhovskaya 5 | HC | 222 | 969 | 1973 | 2015 | | | | 226 | 53 | |
| 89 | Kurakhovskaya 6 | HC | 210 | 640 | 1973 | 2013 | | | | 219 | 37 | |
| 90 | Kurakhovskaya 7 | HC | 225 | 982 | 1974 | 2016 | | | | 232 | 53 | |
| 91 | Kurakhovskaya 8 | HC | 210 | 674 | 1974 | 2012 | | | | 228 | 39 | |
| 92 | Kurakhovskaya 9 | HC | 221 | 1,019 | 1975 | 2014 | | | | 233 | 56 | |
| 93 | Luganskaya 9 | HC | 200 | 1,070 | 1962 | 2017 | | | | 309 | 65 | |
| 94 | Luganskaya 10 | HC | 200 | 642 | 1962 | 2012 | | | | 298 | 39 | |
| 95 | Luganskaya 11 | HC | 200 | 988 | 1963 | 2014 | | | | 307 | 60 | |
| 96 | Luganskaya 12 | HC | 175 | 0 | 1967 | | | | | 200 | | |
| 97 | Luganskaya 13 | HC | 175 | 951 | 1968 | 2013 | | | | 274 | 66 | |
| 98 | Luganskaya 14 | HC | 200 | 1,070 | 1968 | 2016 | | | | 268 | 65 | |
| 99 | Luganskaya 15 | HC | 200 | 988 | 1969 | 2015 | | | | 277 | 60 | |
| 100 | Bilotserkivska CHP | NG | 120 | 494 | | | | | | | 50 | |
| 101 | Darnytska CHP 5,10 | NG | 50 | 212 | | | | | | | 50 | |
| 102 | Darnytska CHP 6-9 | HC | 110 | 453 | | | | | | | 50 | |
| 103 | Kaluska CHP 1, 2 | HC | 100 | 412 | | | | | | | 50 | |
| 104 | Kaluska CHP 3, 4 | NG | 100 | 425 | | | | | | | 50 | |
| 105 | Kyivska CHP-5 | NG | 540 | 1,147 | | | | | | | 25 | |
| 0 | Kyivska CHP-5 | FO | 540 | 1,147 | | | | | | | 25 | |
| 106 | Kyivska CHP-6 | NG | 500 | 1,062 | | | | | | | 25 | |
| 0 | Kyivska CHP-6 | FO | 500 | 1,062 | | | | | | | 25 | |
| 107 | Kramatorska CHP | HC | 120 | 494 | | | | | | | 50 | |
| 108 | Myronivska 4 | HC | 60 | 247 | 1954 | | | | | 335 | 50 | |
| 109 | Myronivska 9 | HC | 115 | 616 | | 2004 | | | | 49 | 65 | |
| 110 | Odeska CHP-2 | NG | 68 | 289 | | | | | | | 50 | |
| 111 | Sevastopolska CHP | NG | 55 | 234 | | | | | | | 50 | |
| 112 | Simferopilska CHP | NG | 278 | 1,181 | | | | | | | 50 | |
| 113 | Kharkivska CHP-2 | HC | 74 | 314 | | | | | | | 50 | |
| Total | | | 29,368 | 88,669 | | | | | | | | |

The emission concentrations in the flue gases accompanied with the emission standards of the LCPD and the IED are presented in Table 2-14. One of the main characteristics is the excess of dust (PM) and NO_x emissions, the latter of which is above 1,000 mg/m³ in most cases which is significantly above the ELVs of the LCPD. SO₂ emissions from the coal fired TPPs are usually in the range between 3,000 and 5,000 mg/m³, which is also considerably above the LCPD's requirements.

Some of the TPP units with common stacks have higher emission standards as they would have in case of separate stack. That is the case for the TPP units of Prydniprovskaya (4x150 MW), Dobrotvirskaya (2x100 MW and 2x150 MW) and for Zmiivska No 1 to No 10 with common stacks for every two units.

Table 2-14: Emission concentrations of LCPs in Ukraine

| Code | Plant name | Fuel type | Furnace input MW | Emission - BAU | | | Requirements LCPD | | | Requirements IED | | |
|------|-------------------|-----------|------------------|----------------------------------|-----------------|-----------------|----------------------------------|-----------------|-----------------|----------------------------------|-----------------|-----------------|
| | | | | Concentration, mg/m ³ | | | Concentration, mg/m ³ | | | Concentration, mg/m ³ | | |
| | | | | Dust | NO _x | SO ₂ | Dust | NO _x | SO ₂ | Dust | NO _x | SO ₂ |
| 1 | Prydniprovsk 7 | HC | 393 | 1,082 | 1,200 | 3,129 | 50 | 200 | 400 | 20 | 200 | 200 |
| 2 | Prydniprovsk 8 | HC | 393 | 1,112 | 1,260 | 3,400 | 50 | 200 | 400 | 20 | 200 | 200 |
| 3 | Prydniprovsk 9 | HC | 393 | 100 | 1,300 | 3,200 | 50 | 200 | 400 | 20 | 200 | 200 |
| 4 | Prydniprovsk 10 | HC | 393 | 955 | 1,180 | 3,055 | 50 | 200 | 400 | 20 | 200 | 200 |
| 5 | Prydniprovsk 11 | HC | 706 | 1,267 | 1,286 | 3,348 | 50 | 200 | 400 | 20 | 200 | 200 |
| 6 | Prydniprovsk 12 | HC | 649 | | | | 50 | 200 | 400 | 20 | 200 | 200 |
| 7 | Prydniprovsk 13 | HC | 649 | 1,410 | 1,315 | 3,159 | 50 | 200 | 400 | 20 | 200 | 200 |
| 8 | Prydniprovsk 14 | HC | 649 | | | | 50 | 200 | 400 | 20 | 200 | 200 |
| 9 | Kryvorizka 1 | HC | 695 | 1,420 | 1,380 | 3,640 | 50 | 200 | 400 | 20 | 200 | 200 |
| 10 | Kryvorizka 2 | HC | 695 | 1,300 | 1,420 | 3,680 | 50 | 200 | 400 | 20 | 200 | 200 |
| 11 | Kryvorizka 3 | HC | 695 | 40 | 1,300 | 4,500 | 50 | 200 | 400 | 20 | 200 | 200 |
| 12 | Kryvorizka 4 | HC | 695 | 293 | 1,470 | 3,620 | 50 | 200 | 400 | 20 | 200 | 200 |
| 13 | Kryvorizka 5 | HC | 695 | 1,570 | 1,510 | 3,790 | 50 | 200 | 400 | 20 | 200 | 200 |
| 14 | Kryvorizka 6 | HC | 695 | 1,590 | 1,590 | 3,840 | 50 | 200 | 400 | 20 | 200 | 200 |
| 15 | Kryvorizka 7 | HC | 695 | | | | 50 | 200 | 400 | 20 | 200 | 200 |
| 16 | Kryvorizka 8 | HC | 695 | 1,400 | 1,603 | 3,850 | 50 | 200 | 400 | 20 | 200 | 200 |
| 17 | Kryvorizka 9 | HC | 695 | | | | 50 | 200 | 400 | 20 | 200 | 200 |
| 18 | Kryvorizka 10 | HC | 695 | 1,500 | 1,603 | 3,850 | 50 | 200 | 400 | 20 | 200 | 200 |
| 19 | Zaporiska 1 | HC | 786 | 986 | 1,550 | 3,840 | 50 | 200 | 400 | 20 | 200 | 200 |
| 20 | Zaporiska 2 | HC | 723 | 860 | 1,490 | 3,939 | 50 | 200 | 400 | 20 | 200 | 200 |
| 21 | Zaporiska 3 | HC | 723 | 848 | 1,484 | 4,089 | 50 | 200 | 400 | 20 | 200 | 200 |
| 22 | Zaporiska 4 | HC | 723 | 842 | 1,600 | 3,939 | 50 | 200 | 400 | 20 | 200 | 200 |
| 23 | Zaporiska 5 | NG | 1,963 | | 598 | | 5 | 200 | 35 | 5 | 100 | 35 |
| 24 | Zaporiska 6 | NG | 2,058 | | | | 5 | 200 | 35 | 5 | 100 | 35 |
| 25 | Zaporiska 7 | NG | 2,133 | | 682 | | 5 | 200 | 35 | 5 | 100 | 35 |
| 26 | Starobeshivska 4 | HC | 480 | | | | 100 | 600 | 470 | 20 | 200 | 200 |
| 27 | Starobeshivska 5 | HC | 480 | | | | 100 | 600 | 470 | 20 | 200 | 200 |
| 28 | Starobeshivska 6 | HC | 480 | | | | 100 | 600 | 470 | 20 | 200 | 200 |
| 29 | Starobeshivska 7 | HC | 480 | | | | 100 | 600 | 470 | 20 | 200 | 200 |
| 30 | Starobeshivska 8 | HC | 480 | | | | 100 | 600 | 470 | 20 | 200 | 200 |
| 31 | Starobeshivska 9 | HC | 480 | | | | 100 | 600 | 470 | 20 | 200 | 200 |
| 32 | Starobeshivska 10 | HC | 480 | | | | 100 | 600 | 470 | 20 | 200 | 200 |
| 33 | Starobeshivska 11 | HC | 480 | | | | 100 | 600 | 470 | 20 | 200 | 200 |
| 34 | Starobeshivska 12 | HC | 480 | | | | 100 | 600 | 470 | 20 | 200 | 200 |
| 35 | Starobeshivska 13 | HC | 480 | | | | 100 | 600 | 470 | 20 | 200 | 200 |
| 36 | Slovianska 7 | HC | 1,993 | | | | 50 | 200 | 400 | 20 | 200 | 200 |
| 37 | Burshtynska 1 | HC | 505 | 1,310 | 590 | 4,326 | 50 | 200 | 400 | 20 | 200 | 200 |
| 38 | Burshtynska 2 | HC | 505 | 1,280 | 585 | 4,286 | 50 | 200 | 400 | 20 | 200 | 200 |
| 39 | Burshtynska 3 | HC | 505 | 1,440 | 560 | 4,318 | 50 | 200 | 400 | 20 | 200 | 200 |
| 40 | Burshtynska 4 | HC | 505 | 1,400 | 575 | 4,402 | 50 | 200 | 400 | 20 | 200 | 200 |
| 41 | Burshtynska 5 | HC | 505 | 1,345 | 560 | 4,617 | 50 | 200 | 400 | 20 | 200 | 200 |
| 42 | Burshtynska 6 | HC | 505 | 1,270 | 540 | 4,405 | 50 | 200 | 400 | 20 | 200 | 200 |
| 43 | Burshtynska 7 | HC | 505 | 1,291 | 590 | 4,691 | 50 | 200 | 400 | 20 | 200 | 200 |
| 44 | Burshtynska 8 | HC | 505 | 760 | 575 | 4,871 | 50 | 200 | 400 | 20 | 200 | 200 |
| 45 | Burshtynska 9 | HC | 505 | 50 | 600 | 4,283 | 50 | 200 | 400 | 20 | 200 | 200 |
| 46 | Burshtynska 10 | HC | 505 | 50 | 610 | 4,337 | 50 | 200 | 400 | 20 | 200 | 200 |
| 47 | Burshtynska 11 | HC | 505 | 50 | 500 | 4,279 | 50 | 200 | 400 | 20 | 200 | 200 |
| 48 | Burshtynska 12 | HC | 505 | 250 | 510 | 4,306 | 50 | 200 | 400 | 20 | 200 | 200 |
| 49 | Dobrotvirska 5 | HC | 183 | 699 | 775 | 4,718 | 100 | 600 | 876 | 25 | 200 | 250 |
| 50 | Dobrotvirska 6 | HC | 183 | 699 | 775 | 4,718 | 100 | 600 | 876 | 25 | 200 | 250 |
| 51 | Dobrotvirska 7 | HC | 383 | 1,300 | 785 | 5,100 | 50 | 200 | 400 | 20 | 200 | 200 |
| 52 | Dobrotvirska 8 | HC | 383 | 1,300 | 785 | 5,100 | 50 | 200 | 400 | 20 | 200 | 200 |
| 53 | Ladyzhinska 1 | HC | 693 | 1,191 | 1,287 | 3,200 | 50 | 200 | 400 | 20 | 200 | 200 |
| 54 | Ladyzhinska 2 | HC | 693 | 398 | 1,284 | 3,300 | 50 | 200 | 400 | 20 | 200 | 200 |
| 55 | Ladyzhinska 3 | HC | 693 | 378 | 1,290 | 3,430 | 50 | 200 | 400 | 20 | 200 | 200 |
| 56 | Ladyzhinska 4 | HC | 693 | 1,191 | 1,276 | 3,270 | 50 | 200 | 400 | 20 | 200 | 200 |
| 57 | Ladyzhinska 5 | HC | 693 | 1,490 | 1,279 | 3,410 | 50 | 200 | 400 | 20 | 200 | 200 |
| 58 | Ladyzhinska 6 | HC | 693 | 1,791 | 1,286 | 3,367 | 50 | 200 | 400 | 20 | 200 | 200 |
| 59 | Trypilska 1 | HC | 767 | 1,118 | 736 | 2,626 | 50 | 200 | 400 | 20 | 200 | 200 |
| 60 | Trypilska 2 | HC | 767 | 1,532 | 1,031 | 2,680 | 50 | 200 | 400 | 20 | 200 | 200 |
| 61 | Trypilska 3 | HC | 767 | 1,449 | 748 | 2,610 | 50 | 200 | 400 | 20 | 200 | 200 |

| Code | Plant name | Fuel type | Furnace input MW | Emission - BAU | | | Requirements LCPD | | | Requirements IED | | |
|-------|--------------------|-----------|------------------|----------------------------------|-----------------|-----------------|----------------------------------|-----------------|-----------------|----------------------------------|-----------------|-----------------|
| | | | | Concentration, mg/m ³ | | | Concentration, mg/m ³ | | | Concentration, mg/m ³ | | |
| | | | | Dust | NO _x | SO ₂ | Dust | NO _x | SO ₂ | Dust | NO _x | SO ₂ |
| 62 | Trypilska 4 | HC | 767 | | | | 50 | 200 | 400 | 20 | 200 | 200 |
| 63 | Trypilska 5 | NG | 767 | | | | 5 | 200 | 35 | 5 | 100 | 35 |
| 64 | Trypilska 6 | NG | 767 | | | | 5 | 200 | 35 | 5 | 100 | 35 |
| 65 | Zmiivska 1 | HC | 492 | 3,506 | 920 | 2,881 | 50 | 200 | 400 | 20 | 200 | 200 |
| 66 | Zmiivska 2 | HC | 490 | 3,557 | 923 | 2,798 | 50 | 200 | 400 | 20 | 200 | 200 |
| 67 | Zmiivska 3 | HC | 480 | 3,483 | 902 | 2,845 | 50 | 200 | 400 | 20 | 200 | 200 |
| 68 | Zmiivska 4 | HC | 483 | 3,374 | 879 | 2,813 | 50 | 200 | 400 | 20 | 200 | 200 |
| 69 | Zmiivska 5 | HC | 478 | 3,261 | 839 | 2,959 | 50 | 200 | 400 | 20 | 200 | 200 |
| 70 | Zmiivska 6 | HC | 483 | 3,118 | 765 | 2,612 | 50 | 200 | 400 | 20 | 200 | 200 |
| 71 | Zmiivska 7 | HC | 773 | 2,425 | 1,661 | 3,728 | 50 | 200 | 400 | 20 | 200 | 200 |
| 72 | Zmiivska 8 | HC | 800 | 289 | 2,215 | 5,307 | 50 | 200 | 400 | 20 | 200 | 200 |
| 73 | Zmiivska 9 | HC | 702 | 2,537 | 1,470 | 3,663 | 50 | 200 | 400 | 20 | 200 | 200 |
| 74 | Zmiivska 10 | HC | 717 | 2,494 | 1,460 | 3,401 | 50 | 200 | 400 | 20 | 200 | 200 |
| 75 | Vuglegirska 1 | HC | 764 | 391 | 1,231 | 4,679 | 50 | 200 | 400 | 20 | 200 | 200 |
| 76 | Vuglegirska 2 | HC | 762 | 391 | 1,231 | 4,679 | 50 | 200 | 400 | 20 | 200 | 200 |
| 77 | Vuglegirska 3 | HC | 767 | 391 | 1,231 | 4,679 | 50 | 200 | 400 | 20 | 200 | 200 |
| 78 | Vuglegirska 4 | HC | 766 | 391 | 1,231 | 4,679 | 50 | 200 | 400 | 20 | 200 | 200 |
| 79 | Vuglegirska 5 | NG | 2,249 | | | | 5 | 200 | 35 | 5 | 100 | 35 |
| 80 | Vuglegirska 6 | NG | 2,249 | | | | 5 | 200 | 35 | 5 | 100 | 35 |
| 81 | Vuglegirska 7 | NG | 2,249 | | | | 5 | 200 | 35 | 5 | 100 | 35 |
| 82 | Zuevskaya 1 | HC | 804 | 190 | 1,872 | 5,092 | 50 | 200 | 400 | 20 | 200 | 200 |
| 83 | Zuevskaya 2 | HC | 788 | 201 | 1,830 | 5,071 | 50 | 200 | 400 | 20 | 200 | 200 |
| 84 | Zuevskaya 3 | HC | 741 | 351 | 1,627 | 4,780 | 50 | 200 | 400 | 20 | 200 | 200 |
| 85 | Zuevskaya 4 | HC | 816 | 46 | 1,672 | 4,810 | 50 | 200 | 400 | 20 | 200 | 200 |
| 86 | Kurakhovskaya 3 | HC | 530 | 2,850 | 667 | 4,750 | 50 | 200 | 400 | 20 | 200 | 200 |
| 87 | Kurakhovskaya 4 | HC | 561 | 2,870 | 673 | 4,860 | 50 | 200 | 400 | 20 | 200 | 200 |
| 88 | Kurakhovskaya 5 | HC | 586 | 2,690 | 649 | 5,040 | 50 | 200 | 400 | 20 | 200 | 200 |
| 89 | Kurakhovskaya 6 | HC | 575 | 3,960 | 608 | 4,860 | 50 | 200 | 400 | 20 | 200 | 200 |
| 90 | Kurakhovskaya 7 | HC | 593 | 1,880 | 651 | 4,630 | 50 | 200 | 400 | 20 | 200 | 200 |
| 91 | Kurakhovskaya 8 | HC | 557 | 2,440 | 631 | 4,900 | 50 | 200 | 400 | 20 | 200 | 200 |
| 92 | Kurakhovskaya 9 | HC | 586 | 2,000 | 597 | 4,860 | 50 | 200 | 400 | 20 | 200 | 200 |
| 93 | Luganskaya 9 | HC | 555 | 2,501 | 1,113 | 3,650 | 50 | 200 | 400 | 20 | 200 | 200 |
| 94 | Luganskaya 10 | HC | 564 | 764 | 1,010 | 3,506 | 50 | 200 | 400 | 20 | 200 | 200 |
| 95 | Luganskaya 11 | HC | 547 | 2,354 | 1,180 | 3,595 | 50 | 200 | 400 | 20 | 200 | 200 |
| 96 | Luganskaya 12 | HC | 494 | | | | 100 | 600 | 420 | 20 | 200 | 200 |
| 97 | Luganskaya 13 | HC | 480 | 2,312 | 1,203 | 3,899 | 100 | 600 | 472 | 20 | 200 | 200 |
| 98 | Luganskaya 14 | HC | 555 | 2,540 | 1,283 | 3,856 | 50 | 200 | 400 | 20 | 200 | 200 |
| 99 | Luganskaya 15 | HC | 561 | 2,343 | 1,208 | 3,960 | 50 | 200 | 400 | 20 | 200 | 200 |
| 100 | Bilotserkivska CHP | NG | 337 | | 298 | | 5 | 300 | 35 | 5 | 100 | 35 |
| 101 | Darnytska CHP 5,10 | NG | 147 | | 300 | | 5 | 300 | 35 | 5 | 100 | 35 |
| 102 | Darnytska CHP 6-9 | HC | 316 | 1,110 | 1,230 | 2,350 | 100 | 600 | 1,054 | 20 | 200 | 200 |
| 103 | Kaluska CHP 1, 2 | HC | 287 | 1,200 | 176 | 2,595 | 100 | 600 | 1,157 | 25 | 200 | 250 |
| 104 | Kaluska CHP 3, 4 | NG | 283 | | 360 | | 5 | 300 | 35 | 5 | 100 | 35 |
| 105 | Kyivska CHP-5 | NG | 1,382 | | | | 5 | 200 | 35 | 5 | 100 | 35 |
| 106 | Kyivska CHP-5 | FO | 1,382 | | | | 50 | 400 | 400 | 20 | 150 | 200 |
| 107 | Kyivska CHP-6 | NG | 1,280 | | 360 | | 5 | 200 | 35 | 5 | 100 | 35 |
| 108 | Kyivska CHP-6 | FO | 1,280 | | 399 | 3001 | 50 | 400 | 400 | 20 | 200 | 200 |
| 109 | Kramatorska CHP | HC | 345 | 468 | 482 | 3,430 | 100 | 600 | 952 | 20 | 200 | 200 |
| 110 | Myronivska 4 | HC | 175 | 228 | 603 | 3,395 | 100 | 600 | 1,554 | 25 | 200 | 250 |
| 111 | Myronivska 9 | HC | 333 | 183 | 687 | 2,776 | 100 | 600 | 993 | 20 | 200 | 200 |
| 112 | Odeska CHP-2 | NG | 198 | | 1,020 | | 5 | 300 | 35 | 5 | 100 | 35 |
| 113 | Sevastopolska CHP | NG | 160 | | 224 | | 5 | 300 | 35 | 5 | 100 | 35 |
| 114 | Simferopilska CHP | NG | 787 | | 125 | | 5 | 200 | 35 | 5 | 100 | 35 |
| 115 | Kharkivska CHP-2 | HC | 215 | 2,525 | 680 | 5,661 | 100 | 600 | 1,412 | 25 | 200 | 250 |
| Total | | | 75,874 | | | | | | | | | |

2.9. Large combustion plants in Kosovo*

At this moment, there are two TPPs in Kosovo*, with the total capacity of 1,288 MW. The first plant is constructed between 1970-1975 while the second plant was started up in 1983-1984 (see Table 2-15). Although the units of TPP Kosovo A have a service time between 150,000 and 200,000 hours it is planned that the plant shall be closed down by the end of the year 2017, mainly due to its poor environmental performance, the deterioration of its technical characteristics and its very low net plant efficiency of 22%.

Table 2-15: Basic characteristics of LCPs in Kosovo*

| Code | Plant name | Fuel type | Powerer MW | Energy GWh/a | Start up | Rehab. | Key dates | | | Service time /000h/ | Load factor /%/ | |
|-------|------------|-----------|------------|--------------|----------|--------|----------------|-------|------|---------------------|-----------------|------------------|
| | | | | | | | Env. upgrading | | | | | Retirement plan |
| | | | | | | | Dust | DeNox | FGD | | | |
| 1 | Kosovo A3 | L | 200 | 590 | 1970 | | 2012 | | | 2017 | 196 | 37 |
| 2 | Kosovo A4 | L | 200 | 590 | 1971 | | 2013 | | | 2017 | 188 | 37 |
| 3 | Kosovo A5 | L | 210 | 606 | 1975 | | 2012 | | | 2017 | 151 | 37 |
| 4 | Kosovo B1 | L | 339 | 1,083 | 1983 | 2017 | 2017 | 2017 | 2017 | 2030 | 152 | 40 ¹⁾ |
| 5 | Kosovo B2 | L | 339 | 1,083 | 1984 | 2017 | 2017 | 2017 | 2017 | 2030 | 147 | 40 ¹⁾ |
| Total | | | 1,288 | 3,951 | | | | | | | | |

¹⁾The latest statistics have shown that the Load factor is increased to 63%. Therefore the energy output from Kosovo B is 3,435 GWh/year

The other plant, TPP Kosovo B, shall be retrofitted by 2017 in order to meet the requirements of the LCPD as presented in Table 2-16.

Table 2-16: Emission concentrations of LCPs in Kosovo*

| Code | Plant name | Fuel type | Furnace input MW | Emission - BAU | | | Requirements LCPD | | | Requirements IED | | |
|-------|------------|-----------|------------------|----------------------|-----------------|-----------------|----------------------|-----------------|-----------------|----------------------|-----------------|-----------------|
| | | | | Concentration, mg/m3 | | | Concentration, mg/m3 | | | Concentration, mg/m3 | | |
| | | | | Dust | NO _x | SO ₂ | Dust | NO _x | SO ₂ | Dust | NO _x | SO ₂ |
| 1 | Kosovo A3 | L | 540 | 49 | 650 | 599 | 50 | 200 | 400 | 20 | 200 | 200 |
| 2 | Kosovo A4 | L | 540 | 728 | 687 | 582 | 50 | 200 | 400 | 20 | 200 | 200 |
| 3 | Kosovo A5 | L | 570 | 45 | 680 | 592 | 50 | 200 | 400 | 20 | 200 | 200 |
| 4 | Kosovo B1 | L | 850 | 419 | 789 | 623 | 50 | 200 | 400 | 20 | 200 | 200 |
| 5 | Kosovo B2 | L | 850 | 444 | 805 | 611 | 50 | 200 | 400 | 20 | 200 | 200 |
| Total | | | 3,350 | | | | | | | | | |

3. External cost of electricity and heat production in LCPs

“Externalities“ are the hidden costs of an activity that are not included in its price – such as the impacts on human health and the environment of gases emitted into the air during power and heat production.

Combustion of any fossil fuel, whether it is solid (coal and lignite), liquid (oil) or gaseous (natural gas) at a thermal power plant (TPP) or a combined heat and power plant (CHP) results in the emission of a number of substances into the atmosphere. These have various effects around the emission point, including an increase in respiratory diseases, deterioration of buildings and lower agricultural production. Impacts vary widely depending on the type of fuel, on the technical characteristics of the plant (with special regard to the combustion methods), as well as the local environmental conditions.

The different impacts on receptors are presented in the below tables in the case of large combustion plants using solid, liquid and gaseous fuels.

Table 3-1: Main negative health and environmental impacts from LCPs using coal and lignite

| Burden | Receptor | Negative impacts |
|-------------------------|---------------------------|--|
| Emissions to atmosphere | | |
| SO ₂ | General public | Health |
| | Ecosystems | Impacts on biodiversity and productivity |
| | Building (etc.) materials | Damage, including to cultural heritage |
| | Agriculture | Productivity |
| | Visibility | Reduction |
| NO _x | General public | Health |
| | Ecosystems | Impacts on biodiversity and productivity |
| | Building (etc.) materials | Damage, including to cultural heritage |
| | Agriculture | Productivity |
| | Visibility | Reduction |
| Dust (PM _x) | General public | Health |
| | Building (etc.) materials | Soiling |
| | Visibility | Amenity |
| Lead | General public | Health |
| | Agriculture, fisheries | Contamination of food |
| Mercury | General public | Health |
| | Agriculture, fisheries | Contamination of food |
| Other heavy metals | General public | Health |
| | Agriculture, fisheries | Contamination of food |
| CO ₂ | Climate | Effects on climate change |
| CH ₄ | Climate | Effects Climate change |
| Cooling tower plumes | General public | Spread of <i>Legionella</i> ? |
| | General public | Spread of enteric pathogens? |
| Other air pollutants | | |

Table 3-2: Main negative health and environmental impacts from LCPs using oil

| Burden | Receptor | Impact |
|-------------------------|---------------------------|--|
| Emissions to atmosphere | | |
| SO ₂ | General public | Health |
| | Ecosystems | Impacts on biodiversity and productivity |
| | Building (etc.) materials | Damage, including to cultural heritage |
| | Agriculture | Productivity |
| | Visibility | Reduction |
| NO _x | General public | Health |
| | Ecosystems | Impacts on biodiversity and productivity |
| | Building (etc.) materials | Damage, including to cultural heritage |
| | Agriculture | Productivity |
| | Visibility | Reduction |
| CO ₂ | Climate | Effects on climate change |
| CH ₄ | Climate | Effects on climate change |
| Cooling tower plumes | General public | Spread of <i>Legionella</i> |
| | General public | Spread of enteric pathogens |
| Other air pollutants | | |

Table 3-3: Main negative health and environmental impacts from LCPs using natural gas

| Burden | Receptor | Impact |
|-------------------------|---------------------------|--|
| Emissions to atmosphere | | |
| SO ₂ | General public | Health |
| | Ecosystems | Impacts on biodiversity and productivity |
| | Building (etc.) materials | Damage, including to cultural heritage |
| | Agriculture | Productivity |
| | Visibility | Reduction |
| NO _x | General public | Health |
| | Ecosystems | Impacts on biodiversity and productivity |
| | Building (etc.) materials | Damage, including to cultural heritage |
| | Agriculture | Productivity |
| | Visibility | Reduction |
| CO ₂ | Climate | Effects on climate change |
| CH ₄ | Climate | Effects on climate change |
| Cooling tower plumes | General public | Spread of <i>Legionella</i> |
| | General public | Spread of enteric pathogens |
| Other air pollutants | | |

External costs for electricity and heat production are those that are not reflected in its price, but which society as a whole must bear. For example, damage to human health is caused by emissions of dust – particulate matter (PM). SO₂ and NO_x emissions also lead to adverse impacts on human health through the formation of secondary pollutants. NO_x emissions have adverse health impacts through the formation of ground-level ozone. SO₂ and NO_x emissions form secondary particles in the atmosphere (which have similar effects to primary PM). There are also costs associated with non-health impacts. SO₂ is the main pollutant of concern for building-related damage,

though ground-level ozone also affects certain materials. The secondary pollutants formed by SO₂ and NO_x also impact crops and terrestrial and aquatic ecosystems.¹¹

Damages from climate change, associated with the high emissions of greenhouse gases from fossil fuel based power production, also have considerable costs; however, this is an issue that goes beyond the subject of this study.

The overall level of these externalities will depend upon a number of factors including:

- the fuel mix for electricity generation (e.g. the use of coal releases far more air pollutants than natural gas);
- the efficiency of electricity production (as the higher this is the less input fuel, and hence output emissions, are required to produce each unit of electricity);
- the use of pollution abatement technology, and;
- the location of the plant itself with respect to population centres, agricultural land, etc.¹²

The damages caused by power and heat production from fossil fuel (hard coal, lignite, oil and natural gas) are, for the most part, not integrated into the current pricing system and so represent external costs. Certain costs are quantifiable in other sectors, such as health care. Others are more of a virtual nature. Nevertheless they can be estimated according to the price and citizens would be prepared to pay in order to avoid them. In the member states of EU, there is a growing urgency to make a precise and rigorous evaluation of all these externalities as they are important decision-making factors when making major political and economic choices in the field of energy policy.

Although the principle may seem obvious, implementation is particularly complex. The ExternE (External Costs of Energy) project was originally launched in 1991 by a consortium of European and American researchers and both the European Commission and the US Department of Energy were involved.¹³ The aim was to define energy externalities – and more precisely electricity production externalities – for each of the available sources: wind, solar, nuclear, biomass, coal, oil, natural gas, and hydroelectric. The project required the co-operation of many specialists from different disciplines: economists, physicists, chemists, epidemiologists and ecologists.

The European Union has made a determined choice towards a policy of sustainable development, involving a review of economic calculations to include previously ignored costs. If these externalities were to be taken into account in the energy field, the price per kWh of fuel of conventional sources origin would increase.

¹¹ <http://www.eea.europa.eu/data-and-maps/indicators/en35-external-costs-of-electricity-production-1/en35>,

¹² <http://www.eea.europa.eu/data-and-maps/indicators/en35-external-costs-of-electricity-production-1/en35>,

¹³ <http://ec.europa.eu/research/news-centre/en/env/02-10-env02.html>

The ExternE study was initiated because of the growing concern that the environmental impacts of energy production were not properly integrated into decision-making processes. Advances in scientific knowledge over recent years have demonstrated that the production and the use of energy cause damage to a wide range of receptors, including human health, natural ecosystems and the built environment. These damages are referred to as external costs, or externalities, to the extent that they are not reflected in the market price of the goods in question (in this case electricity and heat).

Over the years, ExternE has been developing and it turned into a series of projects (ExternE, NewExt and ExternePol), from the early 90s until 2005.

Among other things, specific software systems were developed within the ExternE project:

- EcoSense - the integrated environmental impact assessment model;
- EcoSenseLE - a simplified online version of the EcoSense model.

The ExternE, NewExt and ExternePol projects have developed a remarkable methodology which serves as a reference for this kind of cost calculation.

Also, the so called ExternE-Methodology is very important as an approach of calculating environmental external costs as it was developed during the ExternE project-series, called Impact-Pathway-Approach. The tool and data for calculating environmental external costs according to the Impact-Pathway-Approach have been implemented in the EcoSense model.

All the results of the ExternE project-series have been made available on the ExternE project website (Old version from 2006 and last update on 5th October 2010)¹⁴.

After 2005, there have been many other projects applying the tools but also further developing them towards a more and more integrated assessment. For example, during the NEEDS-project (2004-2009), the EcoSense model has been transferred into the web-based tool EcoSenseWeb¹⁵.

The objective of this study is to assess the external costs associated with the production of electricity and heat by power plants and combined heat and power plants according to the requirements of the Terms of Reference and related to the ELVs and other measures of the LCPD and the IED.

In this study, the assessment of external costs is based upon the sum of components associated with electricity and heat production: damage costs (such as impacts on health, environment, crops etc.) associated with NO_x, SO₂ and dust – PM10. Non-environmental (such as social) costs for non-fossil electricity and heat generating technologies are not taken into account in the scope of the present analysis. Moreover, climate change damage

¹⁴ <http://www.externe.info/externe>

¹⁵ <http://ecosenseweb.ier>

costs associated with emissions of CO₂ and other pollutants (such as NH₃, NMVOC, dust – PM2.5, Cd, As, Ni, Pb, Hg, Cr, Cr-VI, formaldehydes, dioxins) are also not taken into account in the assessment, bearing in mind that they are not subject to the relevant requirements of the LCPD and the IED which are part of the Energy Community environmental *acquis*.

Total external costs (sum of human health regional [north hemispheric model], crops, materials, biodiversity [in € per tonne of pollutant]) were taken from NEEDS software tools as an aggregated scheme (External Costs Euro2000 per tonne) for each year in the period of 2014 up to 2030.

According to the Terms of Reference, external costs estimates had been calculated for the years of release from 2014 up to 2030. Summing up the damage costs of each pollutant gives the total damage costs in the each Contracting Party of the Energy Community for each year. A complete data set for the external costs for Serbia, Montenegro and Kosovo* are the same having in mind that all of them by the time of development of the NEEDS tools, they have been incorporated in the Federal Republic of Yugoslavia.

The level of uncertainties in this external costs calculations are high having in mind that coverage of externalities is not complete (without the emissions of CO₂ and all other pollutants into the air, water, soil or waste production). However, the external costs presented here are sufficient to indicate approximate values of the external costs associated with each unit of electricity and heat overall generation for the period of 2014 up to 2030 year in each Contracting Party of the Energy Community. For more precise calculations of external costs, a closer and more detailed analysis should be carried out at plant level.

The Estimated External Costs (euro per tonne) for emissions of SO₂, NO_x and dust from LCPs from 2014 up to 2030 are presented in the Table 3-4 below and in Graph 3-1 for the year 2014.

Table 3-4: Total estimated external costs per emission unit in the period 2014-2030¹⁶ /€/t/

| Year | Energy Community Contracting Party | | | | | | | | | |
|-----------------|------------------------------------|--------|--------|--------|--------|--------|--------|--------|--------|--------|
| | EU27 | AL | BiH | HR | MK | MD | ME | SR | UA | KO* |
| 2014 | | | | | | | | | | |
| NO _x | 8,836 | 5,132 | 7,683 | 10,562 | 4,786 | 8,130 | 8,660 | 8,660 | 5,360 | 8,660 |
| PM10 | 1,680 | 815 | 485 | 853 | 460 | 1,395 | 817 | 817 | 1,300 | 817 |
| SO ₂ | 8,491 | 6,480 | 6,940 | 8,593 | 5,671 | 7,979 | 8,339 | 8,339 | 7,154 | 8,339 |
| ∑ €/t | 19,007 | 12,427 | 15,108 | 20,008 | 10,916 | 17,503 | 17,816 | 17,816 | 13,815 | 17,816 |
| 2015 | | | | | | | | | | |
| NO _x | 10,365 | 5,316 | 8,651 | 11,804 | 5,250 | 9,082 | 9,736 | 9,736 | 6,211 | 9,736 |
| PM10 | 1,781 | 806 | 491 | 865 | 467 | 1,349 | 830 | 830 | 1,322 | 830 |
| SO ₂ | 9,415 | 6,828 | 7,391 | 9,366 | 6,050 | 8,519 | 8,879 | 8,879 | 7,961 | 8,879 |
| ∑ €/t | 21,561 | 12,950 | 16,532 | 22,036 | 11,767 | 18,950 | 19,445 | 19,445 | 15,493 | 19,445 |
| 2016 | | | | | | | | | | |
| NO _x | 10,533 | 5,400 | 8,786 | 11,991 | 5,332 | 9,233 | 9,893 | 9,893 | 6,314 | 9,893 |
| PM10 | 1,811 | 820 | 499 | 880 | 475 | 1,372 | 844 | 844 | 1,345 | 844 |
| SO ₂ | 9,571 | 6,940 | 7,513 | 9,522 | 6,149 | 8,660 | 9,026 | 9,026 | 8,092 | 9,026 |
| ∑ €/t | 21,916 | 13,160 | 16,798 | 22,393 | 11,957 | 19,265 | 19,763 | 19,763 | 15,751 | 19,763 |
| 2017 | | | | | | | | | | |
| NO _x | 10,703 | 5,485 | 8,925 | 12,182 | 5,416 | 9,387 | 10,053 | 10,053 | 6,419 | 10,053 |
| PM10 | 1,842 | 834 | 507 | 895 | 483 | 1,395 | 858 | 858 | 1,367 | 858 |
| SO ₂ | 9,730 | 7,054 | 7,637 | 9,681 | 6,250 | 8,803 | 9,176 | 9,176 | 8,226 | 9,176 |
| ∑ €/t | 22,276 | 13,373 | 17,069 | 22,757 | 12,149 | 19,585 | 20,087 | 20,087 | 16,012 | 20,087 |
| 2018 | | | | | | | | | | |
| NO _x | 11,087 | 5,572 | 9,065 | 12,375 | 5,501 | 9,544 | 10,215 | 10,215 | 6,526 | 10,215 |
| PM10 | 1,874 | 848 | 516 | 910 | 492 | 1,419 | 873 | 873 | 1,391 | 873 |
| SO ₂ | 9,892 | 7,170 | 7,763 | 9,842 | 6,352 | 8,949 | 9,328 | 9,328 | 8,361 | 9,328 |
| ∑ €/t | 22,853 | 13,590 | 17,344 | 23,127 | 12,345 | 18,494 | 20,416 | 20,416 | 16,278 | 20,416 |
| 2019 | | | | | | | | | | |
| NO _x | 11,053 | 5,660 | 9,208 | 12,572 | 5,588 | 9,703 | 10,380 | 10,380 | 6,635 | 10,380 |
| PM10 | 1,905 | 862 | 525 | 925 | 500 | 1,443 | 888 | 888 | 1,414 | 888 |
| SO ₂ | 10,057 | 7,288 | 7,891 | 10,006 | 6,456 | 9,097 | 9,482 | 9,482 | 8,499 | 9,482 |
| ∑ €/t | 23,015 | 13,810 | 17,624 | 23,503 | 12,544 | 20,243 | 20,750 | 20,750 | 16,548 | 20,750 |
| 2020 | | | | | | | | | | |
| NO _x | 11,232 | 5,750 | 9,353 | 12,772 | 5,677 | 9,865 | 10,548 | 10,548 | 6,746 | 10,548 |
| PM10 | 1,938 | 877 | 534 | 941 | 508 | 1,467 | 903 | 903 | 1,438 | 903 |
| SO ₂ | 10,225 | 7,408 | 8,021 | 10,173 | 6,561 | 9,247 | 9,640 | 9,640 | 8,640 | 9,640 |
| ∑ €/t | 23,395 | 14,035 | 17,908 | 23,886 | 12,746 | 20,579 | 21,091 | 21,091 | 16,824 | 21,091 |
| 2021 | | | | | | | | | | |
| NO _x | 11,415 | 5,841 | 9,501 | 12,975 | 5,766 | 10,029 | 10,719 | 10,719 | 6,858 | 10,719 |
| PM10 | 1,971 | 892 | 543 | 957 | 517 | 1,492 | 918 | 918 | 1,463 | 918 |
| SO ₂ | 10,395 | 7,530 | 8,153 | 10,343 | 6,669 | 9,437 | 9,800 | 9,800 | 8,783 | 9,800 |
| ∑ €/t | 23,781 | 14,263 | 18,197 | 24,275 | 12,952 | 20,952 | 21,437 | 21,437 | 17,104 | 21,437 |
| 2022 | | | | | | | | | | |
| NO _x | 11,600 | 5,934 | 9,652 | 13,182 | 5,858 | 10,197 | 10,893 | 10,893 | 6,973 | 10,893 |
| PM10 | 2,004 | 907 | 552 | 973 | 526 | 1,518 | 934 | 934 | 1,488 | 934 |
| SO ₂ | 10,568 | 7,654 | 8,288 | 10,515 | 6,778 | 9,556 | 9,962 | 9,962 | 8,928 | 9,962 |
| ∑ €/t | 24,172 | 14,495 | 18,492 | 24,670 | 13,162 | 21,271 | 21,789 | 21,789 | 17,389 | 21,789 |
| 2023 | | | | | | | | | | |
| NO _x | 11,789 | 6,028 | 9,805 | 13,393 | 5,951 | 10,367 | 11,069 | 11,069 | 7,089 | 11,069 |
| PM10 | 2,038 | 922 | 561 | 990 | 535 | 1,544 | 950 | 950 | 1,513 | 950 |
| SO ₂ | 10,744 | 7,872 | 8,425 | 10,691 | 6,866 | 9,715 | 10,128 | 10,128 | 9,076 | 10,128 |
| ∑ €/t | 24,571 | 14,822 | 18,791 | 25,074 | 13,252 | 21,626 | 22,147 | 22,147 | 17,678 | 22,147 |
| 2024 | | | | | | | | | | |
| NO _x | 11,980 | 6,124 | 9,960 | 13,607 | 6,045 | 10,540 | 11,249 | 11,249 | 7,208 | 11,249 |
| PM10 | 2,073 | 938 | 571 | 1,007 | 544 | 1,570 | 966 | 966 | 1,539 | 966 |
| SO ₂ | 10,924 | 7,908 | 8,564 | 10,869 | 7,003 | 9,876 | 10,296 | 10,296 | 9,226 | 10,296 |
| ∑ €/t | 24,977 | 14,970 | 19,095 | 25,483 | 13,592 | 21,986 | 22,511 | 22,511 | 17,973 | 22,511 |
| 2025 | | | | | | | | | | |

¹⁶ Estimated external costs are based on aggregation scheme "SIA_E_PPMc" for Human Health (HH) Impacts, based on average meteorology - corresponding to emissions from All SNAP-(Sum of HH regional, crops, materials, biodiversity and HH North Hemispheric model).


| Year | Energy Community Contracting Party | | | | | | | | | |
|-----------------|------------------------------------|--------|--------|--------|--------|--------|--------|--------|--------|--------|
| Pollutant | EU27 | AL | BiH | HR | MK | MD | ME | SR | UA | KO* |
| NO _x | 12,176 | 6,222 | 10,118 | 13,825 | 6,141 | 10,716 | 6,362 | 11,431 | 7,328 | 11,431 |
| PM10 | 2,108 | 954 | 581 | 1,024 | 553 | 1,597 | 1,181 | 982 | 1,565 | 982 |
| SO ₂ | 11,106 | 8,039 | 8,706 | 11,051 | 7,118 | 10,497 | 11,333 | 10,467 | 9,379 | 10,467 |
| Σ €/t | 25,390 | 15,215 | 19,405 | 25,900 | 13,812 | 53,687 | 18,876 | 22,880 | 18,272 | 22,880 |
| 2026 | | | | | | | | | | |
| NO _x | 12,374 | 6,321 | 10,279 | 14,046 | 6,239 | 10,895 | 11,617 | 11,617 | 7,450 | 11,617 |
| PM10 | 2,144 | 970 | 590 | 1,041 | 563 | 1,624 | 999 | 999 | 1,592 | 999 |
| SO ₂ | 11,291 | 8,171 | 8,850 | 11,236 | 7,235 | 10,206 | 10,641 | 10,641 | 9,534 | 10,641 |
| Σ €/t | 25,809 | 15,462 | 19,719 | 26,323 | 14,037 | 22,725 | 23,257 | 23,257 | 18,576 | 23,257 |
| 2027 | | | | | | | | | | |
| NO _x | 12,576 | 6,422 | 10,443 | 14,271 | 6,338 | 11,077 | 11,806 | 11,806 | 7,575 | 11,806 |
| PM10 | 2,181 | 987 | 601 | 1,059 | 572 | 1,651 | 1,016 | 1,016 | 1,619 | 1,016 |
| SO ₂ | 11,480 | 8,306 | 8,997 | 11,423 | 7,353 | 10,376 | 10,818 | 10,818 | 9,692 | 10,818 |
| Σ €/t | 26,237 | 15,715 | 20,041 | 26,753 | 14,263 | 23,104 | 23,640 | 23,640 | 18,886 | 23,640 |
| 2028 | | | | | | | | | | |
| NO _x | 12,781 | 6,525 | 10,609 | 6,688 | 6,439 | 11,263 | 11,998 | 11,998 | 7,702 | 11,998 |
| PM10 | 2,218 | 1,004 | 611 | 1,077 | 582 | 1,679 | 1,033 | 1,033 | 1,646 | 1,033 |
| SO ₂ | 11,671 | 8,444 | 9,146 | 11,614 | 7,474 | 10,548 | 10,998 | 10,998 | 9,853 | 10,998 |
| Σ €/t | 26,670 | 15,973 | 20,366 | 19,379 | 14,495 | 23,490 | 24,029 | 24,029 | 19,201 | 24,029 |
| 2029 | | | | | | | | | | |
| NO _x | 12,990 | 6,629 | 10,778 | 14,733 | 6,542 | 11,451 | 12,193 | 12,193 | 7,831 | 12,193 |
| PM10 | 2,255 | 1,021 | 621 | 1,095 | 592 | 1,708 | 1,051 | 1,051 | 1,674 | 1,051 |
| SO ₂ | 11,866 | 8,583 | 9,297 | 11,808 | 7,597 | 10,723 | 11,181 | 11,181 | 10,016 | 11,181 |
| Σ €/t | 27,111 | 16,233 | 20,696 | 27,636 | 14,731 | 23,882 | 24,425 | 24,425 | 19,521 | 24,425 |
| 2030 | | | | | | | | | | |
| NO _x | 13,202 | 6,735 | 10,950 | 14,970 | 6,646 | 11,643 | 12,392 | 12,392 | 7,962 | 12,392 |
| PM10 | 2,294 | 1,038 | 632 | 1,114 | 602 | 1,737 | 1,068 | 1,068 | 1,703 | 1,068 |
| SO ₂ | 12,064 | 8,725 | 9,451 | 12,006 | 7,723 | 10,902 | 11,367 | 11,367 | 10,183 | 11,367 |
| Σ €/t | 27,560 | 16,498 | 21,033 | 28,090 | 14,971 | 24,282 | 24,827 | 24,827 | 19,848 | 24,827 |

EU27 -
AL -
BiH -
HR -

European Union
Albania
Bosnia and Herzegovina
Croatia

MK -
MD -
ME -
FYR of Macedonia
Moldova
Montenegro

SR -
UA -
KO* -
Serbia
Ukraine
Kosovo*



Graph 1: Total estimated external pollutants emission unit cost in 2014 (€/t)

Environmental and social externalities are highly site specific and thus results may vary widely even within a given country according to the plant's geographical location. The above results show that the highest estimated external costs (euro per tonne) are found in Croatia (higher than the EU average) and the lowest in FYR

Macedonia. This is mainly due to the variation in exposure of people and crops to the pollutants – emissions in the countryside will affect fewer people than emissions in urban areas, due to the degree of urbanization and population density. In other EnC Contracting Parties, the estimated external costs are lower than the EU average.

To calculate the external costs (eurocents/kWh) for each Contracting Party and for each fuel/technology, the following data were necessary:

- pollutant-specific emissions from each fuel/technology used for electricity production;
- average emissions per unit of electricity generation include emissions from the operation of the power plant and the rest of the energy chain;
- pollutant-specific (SO₂, NO_x and dust – PM10) and EnC-average (based on party-specific values) damage cost factors.

The external costs estimates for a particular pollutant are different depending on the fuel because of different average emissions per kWh. The external costs used to calculate this indicator are based upon the sum of next components: damage costs (such as impacts on health, crops etc.) associated with air pollutants (NO_x, SO₂, and dust – PM10). The results of these calculations are presented in Tables 3-5 to 3-13 for the present pollutants emission concentrations and for the expected power generation in 2014.

Table 3-5: Estimated external costs of emissions in 2014 in Albania

| Code | Plant name | Fuel type | Power MW | Energy GWh/a | Emission - BAU | | | External costs – BAU | | | | |
|-------|------------|-----------|----------|--------------|--------------------------|-----------------|-----------------|-----------------------------|-----------------|-----------------|--------------------|-----|
| | | | | | Pollutants emiss, t/year | | | Total costs, million €/year | | | Unit cost €/kWh | |
| | | | | | Dust | NO _x | SO ₂ | Dust | NO _x | SO ₂ | | Sum |
| 1 | Vlora | NG | 100 | 722 | 2 | 98 | 70 | 0.0 | 0.50 | 0.46 | 0.96 | 0.1 |
| Total | | | | 722 | 2 | 98 | 70 | 0.0 | 0.50 | 0.46 | 0.96 | 0.1 |

Table 3-6: Estimated external costs of emissions in 2014 in Bosnia and Herzegovina

| Code | Plant name | Fuel type | Power MW | Energy GWh/a | Emission - BAU | | | External Costs – BAU | | | | |
|-------|------------|-----------|----------|--------------|--------------------------|-----------------|-----------------|-----------------------------|-----------------|-----------------|--------------------|------|
| | | | | | Pollutants emiss, t/year | | | Total costs, million €/year | | | Unit cost €/kWh | |
| | | | | | Dust | NO _x | SO ₂ | Dust | NO _x | SO ₂ | | Sum |
| 1 | Gacko | L | 300 | 1,934 | 2,299 | 5,517 | 13,793 | 1.1 | 42.4 | 95.7 | 139 | 7.2 |
| 2 | Ugljevik | L | 300 | 2,176 | 2,074 | 4,937 | 159,958 | 1.0 | 37.9 | 1,110 | 1,149 | 52.8 |
| 3 | Tuzla 3 | L | 110 | 473 | 71 | 881 | 4,499 | 0.0 | 6.8 | 31.2 | 38 | 8.0 |
| 4 | Tuzla 4 | L | 200 | 1,196 | 460 | 2,030 | 12,807 | 0.2 | 15.6 | 88.9 | 105 | 8.8 |
| 5 | Tuzla 5 | L | 200 | 1,004 | 281 | 903 | 9,505 | 0.1 | 6.9 | 66.0 | 73 | 7.3 |
| 6 | Tuzla 6 | L | 215 | 1,008 | 129 | 1,508 | 17,003 | 0.1 | 11.6 | 118.0 | 130 | 12.9 |
| 7 | Kakanj 5 | L | 110 | 598 | 30 | 2,785 | 21,055 | 0.0 | 21.4 | 146.1 | 168 | 28.0 |
| 8 | Kakanj 6 | L | 110 | 312 | 27 | 1,016 | 10,523 | 0.0 | 7.8 | 73.0 | 81 | 25.9 |
| 9 | Kakanj 7 | L | 230 | 1,342 | 1,036 | 4,756 | 46,917 | 0.5 | 36.5 | 325.6 | 363 | 27.0 |
| Total | | | | 10,044 | 6,407 | 24,334 | 296,060 | 3 | 187 | 2,055 | 2,245 | 22.3 |

Table 3-7: Estimated external costs of emissions in 2014 in Croatia

| Code | Plant name | Fuel type | Power MW | Energy GWh/a | Emission - BAU | | | External Costs – BAU | | | | |
|------|----------------|-----------|----------|--------------|--------------------------|-----------------|-----------------|-----------------------------|-----------------|-----------------|--------------------|------|
| | | | | | Pollutants emiss, t/year | | | Total costs, million €/year | | | Unit cost €/kWh | |
| | | | | | Dust | NO _x | SO ₂ | Dust | NO _x | SO ₂ | | Sum |
| 1 | TPP Plomin 1 | HC | 125 | 915 | 122 | 1,861 | 5,357 | 0.1 | 19.7 | 46.0 | 66 | 7.2 |
| 2 | TPP Plomin 2 | HC | 210 | 1,631 | 116 | 1,888 | 873 | 0.1 | 19.9 | 7.5 | 28 | 1.7 |
| 3 | TPP Rijeka | FO | 320 | 1,725 | 594 | 4,803 | 19,335 | 0.5 | 50.7 | 166.2 | 217 | 12.6 |
| 4 | TPP Sisak A | FO | 210 | 1,214 | 454 | 3,042 | 14,994 | 0.4 | 32.1 | 128.8 | 161 | 13.3 |
| 5 | TPP Sisak B | FO | 210 | 1,214 | 454 | 3,042 | 14,994 | 0.4 | 32.1 | 128.8 | 161 | 13.3 |
| 6 | TPP Jertovac 1 | NG | 40 | 47 | 0 | 32 | 1 | 0.0 | 0.3 | 0.0 | 0 | 0.7 |
| 7 | TPP Jertovac 2 | NG | 40 | 47 | 0 | 33 | 1 | 0.0 | 0.3 | 0.0 | 0 | 0.8 |
| 8 | CHP Zagreb C | NG | 120 | 469 | 129 | 1,056 | 4,218 | 0.1 | 11.2 | 36.2 | 48 | 10.1 |

| Code | Plant name | Fuel type | Power MW | Energy GWh/a | Emission - BAU | | | External Costs – BAU | | | | |
|------|--------------------|-----------|----------|--------------|--------------------------|-----------------|-----------------|-----------------------------|-----------------|-----------------|-----------|-------|
| | | | | | Pollutants emiss, t/year | | | Total costs, million €/year | | | Unit cost | |
| | | | | | Dust | NO _x | SO ₂ | Dust | NO _x | SO ₂ | Sum | €/kWh |
| 9 | CHP Zagreb K | NG | 208 | 1,591 | 20 | 123 | 20 | 0.0 | 1.3 | 0.2 | 1 | 0.1 |
| 10 | CHP Zagreb L | NG | 112 | 866 | 11 | 47 | 4 | 0.0 | 0.5 | 0.0 | 1 | 0.1 |
| 11 | CHP Zagreb EL-TOK6 | NG | 11 | 21 | 8 | 71 | 353 | 0.0 | 0.8 | 3.0 | 4 | 17.6 |
| 12 | CHP Zagreb EL-TOK8 | NG | 30 | 82 | 66 | 148 | 910 | 0.1 | 1.6 | 7.8 | 9 | 11.6 |
| 13 | CHP Zagreb EL-TOH | NG | 25 | 161 | 0 | 174 | 4 | 0.0 | 1.8 | 0.0 | 2 | 1.2 |
| 14 | CHP Zagreb EL-TOJ | NG | 25 | 161 | 0 | 151 | 8 | 0.0 | 1.6 | 0.1 | 2 | 1.0 |
| 15 | CHP Osijek A | NG | 46 | 256 | 4 | 217 | 15 | 0.0 | 2.3 | 0.1 | 2 | 0.9 |
| 16 | CHP Osijek B | NG | 25 | 42 | 0 | 38 | 3 | 0.0 | 0.4 | 0.0 | 0 | 1.0 |
| 17 | CHP Osijek C | NG | 25 | 21 | 0 | 19 | 1 | 0.0 | 0.2 | 0.0 | 0 | 1.0 |
| Sum | | | 1,782 | 10,464 | 1,977 | 16,747 | 61,090 | 2 | 177 | 525 | 704 | 6.7 |

Table 3-8: Estimated external costs of emissions in 2014 in FYR Macedonia

| Code | Plant name | Fuel type | Power MW | Energy GWh/a | Emission - BAU | | | External costs – BAU | | | | |
|-------|------------|-----------|----------|--------------|--------------------------|-----------------|-----------------|-----------------------------|-----------------|-----------------|-----------|-------|
| | | | | | Pollutants emiss, t/year | | | Total costs, million €/year | | | Unit cost | |
| | | | | | Dust | NO _x | SO ₂ | Dust | NO _x | SO ₂ | Sum | €/kWh |
| 1 | Bitola 1 | L | 233 | 1,387 | 2,571 | 5,629 | 33,359 | 1.2 | 26.9 | 189.2 | 217 | 15.7 |
| 2 | Bitola 2 | L | 233 | 1,387 | 4,448 | 5,699 | 27,104 | 2.0 | 27.3 | 153.7 | 183 | 13.2 |
| 3 | Bitola 3 | L | 233 | 1,387 | 4,448 | 5,699 | 27,104 | 2.0 | 27.3 | 153.7 | 183 | 13.2 |
| 4 | Oslomej | L | 125 | 604 | 1,722 | 1,087 | 12,383 | 0.8 | 5.2 | 70.2 | 76 | 12.6 |
| 5 | Negotino | FO | 210 | 17 | 0 | 0 | 0 | 0.0 | 0.0 | 0.0 | 0 | 0.0 |
| 6 | Skopje CHP | NG | 227 | 1394 | 28 | 456 | 2 | 0.0 | 2.2 | 0.0 | 2 | 0.2 |
| 7 | Kogel CHP | NG | 30 | 185 | 4 | 72 | 0 | 0.0 | 0.3 | 0.0 | 0 | 0.2 |
| Total | | | 1,291 | 6,362 | 13,222 | 18,642 | 99,953 | 6 | 89 | 567 | 662 | 10.4 |

Table 3-9: Estimated external costs of emissions in 2014 in Moldova

| Code | Plant name | Fuel type | Power MW | Energy GWh/a | Emission - BAU | | | External costs – BAU | | | | |
|-------|-------------|-----------|----------|--------------|-----------------------------|-----------------|-----------------|-----------------------------|-----------------|-----------------|-----------|-------|
| | | | | | Pollutants emission, t/year | | | Total costs, million €/year | | | Unit cost | |
| | | | | | Dust | NO _x | SO ₂ | Dust | NO _x | SO ₂ | Sum | €/kWh |
| 1 | CET-1, No 1 | NG | 12 | 59 | 0 | 21 | 0 | 0.0 | 0.2 | 0.0 | 0.2 | 0.3 |
| 2 | CET-1, No 2 | NG | 12 | 59 | 0 | 25 | 0 | 0.0 | 0.2 | 0.0 | 0.2 | 0.3 |
| 3 | CET-1, No 3 | NG | 10 | 49 | 0 | 21 | 0 | 0.0 | 0.2 | 0.0 | 0.2 | 0.4 |
| 4 | CET-1, No 4 | NG | 27 | 132 | 0 | 49 | 0 | 0.0 | 0.4 | 0.0 | 0.4 | 0.3 |
| 5 | CET-1, No 5 | NG | 5 | 24 | 0 | 7 | 0 | 0.0 | 0.1 | 0.0 | 0.1 | 0.2 |
| 6 | CET-2, No 1 | NG | 80 | 398 | 0 | 175 | 0 | 0.0 | 1.4 | 0.0 | 1.4 | 0.4 |
| 7 | CET-2, No 2 | NG | 80 | 371 | 0 | 185 | 0 | 0.0 | 1.5 | 0.0 | 1.5 | 0.4 |
| 8 | CET-2, No 3 | NG | 80 | 371 | 0 | 170 | 0 | 0.0 | 1.4 | 0.0 | 1.4 | 0.4 |
| Total | | | 306 | 1,580 | 0 | 734 | 0 | 0 | 6 | 0 | 6 | 0.4 |

Table 3-10: Estimated external costs of emissions in 2014 in Montenegro

| Code | Plant name | Fuel type | Power MW | Energy GWh/a | Emission - BAU | | | External costs - BAU | | | | |
|-------|------------|-----------|----------|--------------|-----------------------------|-----------------|-----------------|-----------------------------|-----------------|-----------------|-----------|------|
| | | | | | Pollutants emission, t/year | | | Total costs, million €/year | | | Unit cost | |
| | | | | | Dust | NO _x | SO ₂ | Dust | NO _x | SO ₂ | Sum | €/kW |
| 1 | Pljevlja | Lignite | 219 | 1,489 | 221 | 3,322 | 44,295 | 0.2 | 28.8 | 369.4 | 398.3 | 26.7 |
| Total | | | 219 | 1,489 | 221 | 3,322 | 44,295 | 0 | 29 | 369 | 398 | 26.7 |

Table 3-11: Estimated external costs of emissions in 2014 in Serbia

| Code | Plant name | Fuel type | Power MW | Energy GWh/a | Emission - BAU | | | External costs - BAU | | | | |
|------|-----------------|-----------|----------|--------------|------------------------------|-----------------|-----------------|-----------------------------|-----------------|-----------------|-----------|------|
| | | | | | Pollutants emissions, t/year | | | Total costs, million €/year | | | Unit cost | |
| | | | | | Dust | NO _x | SO ₂ | Dust | NO _x | SO ₂ | Sum | €/kW |
| 1 | Nikola Tesla A1 | L | 210 | 1,231 | 852 | 2,336 | 11,901 | 0.7 | 20.2 | 99.2 | 120 | 9.8 |
| 2 | Nikola Tesla A2 | L | 210 | 1,198 | 829 | 2,273 | 11,578 | 0.7 | 19.7 | 96.5 | 117 | 9.8 |
| 3 | Nikola Tesla A3 | L | 305 | 1,923 | 1,295 | 3,551 | 18,092 | 1.1 | 30.8 | 150.9 | 183 | 9.5 |
| 4 | Nikola Tesla A4 | L | 309 | 1,989 | 353 | 3,973 | 18,855 | 0.3 | 34.4 | 157.2 | 192 | 9.6 |
| 5 | Nikola Tesla A5 | L | 309 | 1,999 | 351 | 3,957 | 18,776 | 0.3 | 34.3 | 156.6 | 191 | 9.6 |
| 6 | Nikola Tesla A6 | L | 309 | 1,987 | 349 | 3,932 | 18,661 | 0.3 | 34.1 | 155.6 | 190 | 9.6 |
| 7 | Nikola Tesla B1 | L | 620 | 4,151 | 763 | 8,378 | 38,742 | 0.6 | 72.6 | 323.1 | 396 | 9.5 |
| 8 | Nikola Tesla B2 | L | 620 | 4,004 | 743 | 8,157 | 37,723 | 0.6 | 70.6 | 314.6 | 386 | 9.6 |
| 9 | Kolubara 1 | L | 32 | 175 | 1,534 | 492 | 2,990 | 1.3 | 4.3 | 24.9 | 30 | 17.4 |
| 10 | Kolubara 2 | L | 32 | 116 | 1,013 | 325 | 1,974 | 0.8 | 2.8 | 16.5 | 20 | 17.4 |
| 11 | Kolubara 3 | L | 64 | 135 | 1,180 | 379 | 2,300 | 1.0 | 3.3 | 19.2 | 23 | 17.4 |
| 12 | Kolubara 4 | L | 32 | 0 | 0 | 0 | 0 | 0.0 | 0.0 | 0.0 | 0 | |
| 13 | Kolubara 5 | L | 110 | 626 | 192 | 1,356 | 7,876 | 0.2 | 11.7 | 65.7 | 78 | 12.4 |
| 14 | Morava | L | 125 | 566 | 3,283 | 1,513 | 11,018 | 2.7 | 13.1 | 91.9 | 108 | 19.0 |

| Code | Plant name | Fuel type | Power MW | Energy GWh/a | Emission - BAU | | | External costs - BAU | | | | |
|-------|-----------------|-----------|----------|--------------|------------------------------|-----------------|-----------------|-----------------------------|-----------------|-----------------|-----------|------|
| | | | | | Pollutants emissions, t/year | | | Total costs, million €/year | | | Unit cost | |
| | | | | | Dust | NO _x | SO ₂ | Dust | NO _x | SO ₂ | Sum | €/kW |
| 15 | Kostolac A1 | L | 100 | 560 | 1,282 | 1,218 | 19,052 | 1.0 | 10.5 | 158.9 | 170 | 30.5 |
| 16 | Kostolac A2 | L | 210 | 1,196 | 672 | 2,285 | 37,078 | 0.5 | 19.8 | 309.2 | 330 | 27.5 |
| 17 | Kostolac B1 | L | 348 | 1,937 | 5,489 | 5,132 | 57,898 | 4.5 | 44.4 | 482.8 | 532 | 27.5 |
| 18 | Kostolac B2 | L | 348 | 1,895 | 2,361 | 4,553 | 51,300 | 1.9 | 39.4 | 427.8 | 469 | 24.8 |
| 19 | Novi Sad 1 | NG | 135 | 189 | 4 | 649 | 107 | 0.0 | 5.6 | 0.9 | 7 | 3.4 |
| 20 | Novi Sad 2 | NG | 110 | 175 | 4 | 601 | 99 | 0.0 | 5.2 | 0.8 | 6 | 3.4 |
| 21 | Zrenjanin | NG | 110 | 66 | 2 | 248 | 41 | 0.0 | 2.1 | 0.3 | 2 | 3.8 |
| 22 | Sr. Mitrovica 1 | NG | 32 | 123 | 0 | 230 | 0 | 0.0 | 2.0 | 0.0 | 2 | 1.6 |
| Total | | | 4,679 | 26,240 | 22,551 | 55,536 | 366,060 | 18 | 481 | 3,053 | 3,552 | 13.5 |

Table 3-12: Estimated external costs of emissions in 2014 in Ukraine

| Code | Plant name | Fuel type | Power MW | Ener. GWh/a | Emission - BAU | | | External costs - BAU | | | | |
|------|-------------------|-----------|----------|-------------|------------------------------|-----------------|-----------------|-----------------------------|-----------------|-----------------|-----------|-------|
| | | | | | Pollutants emissions, t/year | | | Total costs, million €/year | | | Unit cost | |
| | | | | | Dust | NO _x | SO ₂ | Dust | NO _x | SO ₂ | Sum | €/kWh |
| 1 | Prydniprovsk 7 | HC | 150 | 439 | 1,794 | 1,990 | 5,189 | 2 | 11 | 37 | 50 | 11.4 |
| 2 | Prydniprovsk 8 | HC | 150 | 682 | 2,727 | 3,090 | 8,338 | 4 | 17 | 60 | 80 | 11.7 |
| 3 | Prydniprovsk 9 | HC | 150 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| 4 | Prydniprovsk 10 | HC | 150 | 590 | 2,042 | 2,523 | 6,532 | 3 | 14 | 47 | 63 | 10.7 |
| 5 | Prydniprovsk 11 | HC | 310 | 1,186 | 4,955 | 5,030 | 13,094 | 6 | 27 | 94 | 127 | 10.7 |
| 6 | Prydniprovsk 12 | HC | 285 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| 7 | Prydniprovsk 13 | HC | 285 | 774 | 3,819 | 3,561 | 8,555 | 5 | 19 | 61 | 85 | 11.0 |
| 8 | Prydniprovsk 14 | HC | 285 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| 9 | Kryvorizka 1 | HC | 282 | 1,106 | 5,226 | 5,079 | 13,397 | 7 | 27 | 96 | 130 | 11.7 |
| 10 | Kryvorizka 2 | HC | 282 | 1,382 | 5,800 | 6,336 | 16,420 | 8 | 34 | 117 | 159 | 11.5 |
| 11 | Kryvorizka 3 | HC | 282 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| 12 | Kryvorizka 4 | HC | 282 | 1,221 | 1,144 | 5,741 | 14,139 | 1 | 31 | 101 | 133 | |
| 13 | Kryvorizka 5 | HC | 282 | 1,221 | 6,234 | 5,996 | 15,050 | 8 | 32 | 108 | 148 | |
| 14 | Kryvorizka 6 | HC | 282 | 714 | 3,785 | 3,785 | 9,141 | 5 | 20 | 65 | 91 | |
| 15 | Kryvorizka 7 | HC | 282 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| 16 | Kryvorizka 8 | HC | 282 | 1,014 | 4,684 | 5,364 | 12,882 | 6 | 29 | 92 | 127 | |
| 17 | Kryvorizka 9 | HC | 282 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| 18 | Kryvorizka 10 | HC | 282 | 1,198 | 5,937 | 6,345 | 15,239 | 8 | 34 | 109 | 151 | |
| 19 | Zaporiska 1 | HC | 325 | 1,048 | 3,572 | 5,616 | 13,912 | 5 | 30 | 100 | 134 | |
| 20 | Zaporiska 2 | HC | 300 | 1,277 | 3,799 | 6,583 | 17,402 | 5 | 35 | 125 | 165 | 12.9 |
| 21 | Zaporiska 3 | HC | 300 | 1,301 | 3,817 | 6,680 | 18,406 | 5 | 36 | 132 | 172 | 13.3 |
| 22 | Zaporiska 4 | HC | 300 | 1,205 | 3,509 | 6,669 | 16,417 | 5 | 36 | 117 | 158 | 13.1 |
| 23 | Zaporiska 5 | NG | 800 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 10.9 |
| 24 | Zaporiska 6 | NG | 800 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 12.1 |
| 25 | Zaporiska 7 | NG | 800 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 12.7 |
| 26 | Starobeshivska 4 | HC | 175 | 715 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| 27 | Starobeshivska 5 | HC | 175 | 715 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 12.5 |
| 28 | Starobeshivska 6 | HC | 175 | 715 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| 29 | Starobeshivska 7 | HC | 175 | 715 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 12.6 |
| 30 | Starobeshivska 8 | HC | 175 | 715 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 12.8 |
| 31 | Starobeshivska 9 | HC | 175 | 715 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0.0 |
| 32 | Starobeshivska 10 | HC | 175 | 715 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0.0 |
| 33 | Starobeshivska 11 | HC | 175 | 715 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0.0 |
| 34 | Starobeshivska 12 | HC | 175 | 715 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0.0 |
| 35 | Starobeshivska 13 | HC | 175 | 715 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0.0 |
| 36 | Slovianska 7 | HC | 800 | 3,269 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0.0 |
| 37 | Burshtynska 1 | HC | 195 | 915 | 3,929 | 1,769 | 12,973 | 5 | 9 | 93 | 107 | 11.7 |
| 38 | Burshtynska 2 | HC | 185 | 397 | 1,830 | 836 | 6,128 | 2 | 4 | 44 | 51 | 12.8 |
| 39 | Burshtynska 3 | HC | 185 | 662 | 3,463 | 1,347 | 10,385 | 5 | 7 | 74 | 86 | 13.0 |
| 40 | Burshtynska 4 | HC | 195 | 884 | 4,462 | 1,833 | 14,031 | 6 | 10 | 100 | 116 | 13.1 |
| 41 | Burshtynska 5 | HC | 195 | 465 | 2,262 | 942 | 7,763 | 3 | 5 | 56 | 64 | 13.7 |
| 42 | Burshtynska 6 | HC | 185 | 986 | 4,495 | 1,911 | 15,591 | 6 | 10 | 112 | 128 | 12.9 |
| 43 | Burshtynska 7 | HC | 185 | 508 | 2,362 | 1,079 | 8,582 | 3 | 6 | 61 | 70 | 13.8 |
| 44 | Burshtynska 8 | HC | 195 | 806 | 2,160 | 1,634 | 13,846 | 3 | 9 | 99 | 111 | 13.7 |
| 45 | Burshtynska 9 | HC | 195 | 961 | 170 | 2,038 | 14,551 | 0 | 11 | 104 | 115 | 12.0 |
| 46 | Burshtynska 10 | HC | 195 | 930 | 165 | 2,018 | 14,347 | 0 | 11 | 103 | 114 | 12.2 |
| 47 | Burshtynska 11 | HC | 195 | 992 | 173 | 1,727 | 14,777 | 0 | 9 | 106 | 115 | 11.6 |
| 48 | Burshtynska 12 | HC | 195 | 667 | 590 | 1,205 | 10,170 | 1 | 6 | 73 | 80 | 12.0 |

| Code | Plant name | Fuel type | Power MW | Ener. GWh/a | Emission - BAU | | | External costs - BAU | | | | |
|------|--------------------|-----------|----------|-------------|------------------------------|-----------------|-----------------|-----------------------------|-----------------|-----------------|-----|-----------|
| | | | | | Pollutants emissions, t/year | | | Total costs, million €/year | | | | Unit cost |
| | | | | | Dust | NO _x | SO ₂ | Dust | NO _x | SO ₂ | Sum | €/kWh |
| 49 | Dobrotvirska 5 | HC | 100 | 402 | 1,110 | 1,231 | 7,495 | 1 | 7 | 54 | 62 | 15.3 |
| 50 | Dobrotvirska 6 | HC | 100 | 402 | 1,110 | 1,231 | 7,495 | 1 | 7 | 54 | 62 | 15.3 |
| 51 | Dobrotvirska 7 | HC | 150 | 786 | 3,683 | 2,224 | 14,448 | 5 | 12 | 103 | 120 | 15.3 |
| 52 | Dobrotvirska 8 | HC | 150 | 568 | 2,705 | 1,633 | 10,610 | 4 | 9 | 76 | 88 | 15.5 |
| 53 | Ladyzhinska 1 | HC | 300 | 874 | 3,515 | 3,799 | 9,445 | 5 | 20 | 68 | 93 | 10.6 |
| 54 | Ladyzhinska 2 | HC | 300 | 1,092 | 1,468 | 4,737 | 12,175 | 2 | 25 | 87 | 114 | 10.5 |
| 55 | Ladyzhinska 3 | HC | 300 | 1,262 | 1,612 | 5,500 | 14,624 | 2 | 29 | 105 | 136 | 10.8 |
| 56 | Ladyzhinska 4 | HC | 300 | 752 | 3,027 | 3,243 | 8,311 | 4 | 17 | 59 | 81 | 10.7 |
| 57 | Ladyzhinska 5 | HC | 300 | 582 | 2,932 | 2,517 | 6,710 | 4 | 13 | 48 | 65 | 11.2 |
| 58 | Ladyzhinska 6 | HC | 300 | 558 | 3,377 | 2,425 | 6,349 | 4 | 13 | 45 | 63 | 11.3 |
| 59 | Trypilska 1 | HC | 300 | 1,250 | 5,004 | 3,294 | 3,294 | 7 | 18 | 24 | 48 | 3.8 |
| 60 | Trypilska 2 | HC | 300 | 1,250 | 6,857 | 4,615 | 4,615 | 9 | 25 | 33 | 67 | 5.3 |
| 61 | Trypilska 3 | HC | 300 | 1,250 | 6,486 | 3,348 | 3,348 | 8 | 18 | 24 | 50 | 4.0 |
| 62 | Trypilska 4 | HC | 300 | 1,250 | 6,311 | 3,308 | 3,308 | 8 | 18 | 24 | 50 | 4.0 |
| 63 | Trypilska 5 | NG | 300 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 64 | Trypilska 6 | NG | 300 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 65 | Zmiivska 1 | HC | 175 | 548 | 7,494 | 1,966 | 6,158 | 10 | 11 | 44 | 64 | 11.7 |
| 66 | Zmiivska 2 | HC | 175 | 548 | 7,565 | 1,963 | 5,950 | 10 | 11 | 43 | 63 | 11.5 |
| 67 | Zmiivska 3 | HC | 175 | 548 | 7,265 | 1,881 | 5,934 | 9 | 10 | 42 | 62 | 11.3 |
| 68 | Zmiivska 4 | HC | 175 | 548 | 7,074 | 1,843 | 5,897 | 9 | 10 | 42 | 61 | 11.2 |
| 69 | Zmiivska 5 | HC | 175 | 548 | 6,768 | 1,741 | 6,141 | 9 | 9 | 44 | 62 | 11.3 |
| 70 | Zmiivska 6 | HC | 175 | 548 | 6,547 | 1,606 | 5,484 | 9 | 9 | 39 | 56 | 10.3 |
| 71 | Zmiivska 7 | HC | 275 | 793 | 7,504 | 5,140 | 11,535 | 10 | 28 | 83 | 120 | 15.1 |
| 72 | Zmiivska 8 | HC | 325 | 937 | 925 | 7,093 | 16,995 | 1 | 38 | 122 | 161 | 17.2 |
| 73 | Zmiivska 9 | HC | 275 | 793 | 7,128 | 4,130 | 10,292 | 9 | 22 | 74 | 105 | 13.3 |
| 74 | Zmiivska 10 | HC | 275 | 793 | 7,153 | 4,187 | 9,754 | 9 | 22 | 70 | 102 | 12.8 |
| 75 | Vuglegirska 1 | HC | 300 | 1,359 | 1,882 | 5,925 | 22,520 | 2 | 32 | 161 | 195 | 14.4 |
| 76 | Vuglegirska 2 | HC | 300 | 1,359 | 1,878 | 5,913 | 22,476 | 2 | 32 | 161 | 195 | 14.3 |
| 77 | Vuglegirska 3 | HC | 300 | 1,359 | 1,889 | 5,947 | 22,603 | 2 | 32 | 162 | 196 | 14.4 |
| 78 | Vuglegirska 4 | HC | 300 | 1,359 | 1,887 | 5,941 | 22,580 | 2 | 32 | 162 | 196 | 14.4 |
| 79 | Vuglegirska 5 | NG | 800 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 80 | Vuglegirska 6 | NG | 800 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 81 | Vuglegirska 7 | NG | 800 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 82 | Zuevskaya 1 | HC | 325 | 1,606 | 1,067 | 10,517 | 28,607 | 1 | 56 | 205 | 262 | 16.3 |
| 83 | Zuevskaya 2 | HC | 320 | 1,660 | 1,161 | 10,567 | 29,282 | 2 | 57 | 209 | 268 | 16.1 |
| 84 | Zuevskaya 3 | HC | 300 | 1,606 | 1,967 | 9,117 | 26,786 | 3 | 49 | 192 | 243 | 15.1 |
| 85 | Zuevskaya 4 | HC | 325 | 1,740 | 284 | 10,326 | 29,707 | 0 | 55 | 213 | 268 | 15.4 |
| 86 | Kurakhovskaya 3 | HC | 200 | 1,005 | 10,815 | 2,531 | 18,025 | 14 | 14 | 129 | 157 | 15.6 |
| 87 | Kurakhovskaya 4 | HC | 210 | 1,003 | 10,962 | 2,571 | 18,563 | 14 | 14 | 133 | 161 | 16.0 |
| 88 | Kurakhovskaya 5 | HC | 222 | 969 | 9,818 | 2,369 | 18,395 | 13 | 13 | 132 | 157 | 16.2 |
| 89 | Kurakhovskaya 6 | HC | 210 | 640 | 9,898 | 1,520 | 12,148 | 13 | 8 | 87 | 108 | 16.9 |
| 90 | Kurakhovskaya 7 | HC | 225 | 982 | 6,937 | 2,402 | 17,084 | 9 | 13 | 122 | 144 | 14.7 |
| 91 | Kurakhovskaya 8 | HC | 210 | 674 | 6,228 | 1,611 | 12,507 | 8 | 9 | 89 | 106 | 15.7 |
| 92 | Kurakhovskaya 9 | HC | 221 | 1,019 | 7,711 | 2,302 | 18,738 | 10 | 12 | 134 | 156 | 15.3 |
| 93 | Luganskaya 9 | HC | 200 | 1,070 | 10,262 | 4,567 | 14,977 | 13 | 24 | 107 | 145 | 13.5 |
| 94 | Luganskaya 10 | HC | 200 | 642 | 1,912 | 2,528 | 8,775 | 2 | 14 | 63 | 79 | 12.3 |
| 95 | Luganskaya 11 | HC | 200 | 988 | 8,781 | 4,402 | 13,410 | 11 | 24 | 96 | 131 | 13.3 |
| 96 | Luganskaya 12 | HC | 175 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 97 | Luganskaya 13 | HC | 175 | 951 | 8,324 | 4,331 | 14,037 | 11 | 23 | 100 | 134 | 14.1 |
| 98 | Luganskaya 14 | HC | 200 | 1,070 | 10,424 | 5,265 | 15,825 | 14 | 28 | 113 | 155 | 14.5 |
| 99 | Luganskaya 15 | HC | 200 | 988 | 8,975 | 4,627 | 15,168 | 12 | 25 | 109 | 145 | 14.7 |
| 100 | Bilotserkivska CHP | NG | 120 | 494 | 0 | 470 | 0 | 0 | 3 | 0 | 3 | 0.5 |
| 101 | DarnytskaCHP5,10 | NG | 50 | 212 | 0 | 207 | 0 | 0 | 1 | 0 | 1 | 0.5 |
| 102 | Darnytska CHP6-9 | HC | 110 | 453 | 2,011 | 2,228 | 4,258 | 3 | 12 | 30 | 45 | 9.9 |
| 103 | Kaluska CHP 1,2 | HC | 100 | 412 | 1,982 | 291 | 4,285 | 3 | 2 | 31 | 35 | 8.5 |
| 104 | Kaluska CHP 3, 4 | NG | 100 | 425 | 0 | 476 | 0 | 0 | 3 | 0 | 3 | 0.6 |
| 105 | Kyivska CHP-5 | NG | 540 | 1,147 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0.0 |
| 106 | Kyivska CHP-5 | FO | 540 | 1,147 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0.0 |
| 107 | Kyivska CHP-6 | NG | 500 | 1,062 | 682 | 1,803 | 10,152 | 1 | 10 | 73 | 83 | 7.8 |
| 108 | Kyivska CHP-6 | FO | 500 | 1,062 | 535 | 2,007 | 8,108 | 1 | 11 | 58 | 69 | 6.5 |
| 109 | Kramatorska CHP | HC | 120 | 494 | 918 | 945 | 6,727 | 1 | 5 | 48 | 54 | 11.0 |
| 110 | Myronivska 4 | HC | 60 | 247 | 232 | 613 | 3,453 | 0 | 3 | 25 | 28 | 11.5 |

| Code | Plant name | Fuel type | Power MW | Ener. GWh/a | Emission - BAU | | | External costs - BAU | | | | |
|-------|-------------------|-----------|----------|-------------|------------------------------|-----------------|-----------------|-----------------------------|-----------------|-----------------|-------|-----------|
| | | | | | Pollutants emissions, t/year | | | Total costs, million €/year | | | | Unit cost |
| | | | | | Dust | NO _x | SO ₂ | Dust | NO _x | SO ₂ | Sum | €/kWh |
| 111 | Myronivska 9 | HC | 115 | 616 | 460 | 1,725 | 6,972 | 1 | 9 | 50 | 60 | 9.7 |
| 112 | Odeska CHP-2 | NG | 68 | 289 | 0 | 941 | 0 | 0 | 5 | 0 | 5 | 1.7 |
| 113 | Sevastopolska CHP | NG | 55 | 234 | 0 | 167 | 0 | 0 | 1 | 0 | 1 | 0.4 |
| 114 | Simferopilska CHP | NG | 278 | 1,181 | 0 | 458 | 0 | 0 | 2 | 0 | 2 | 0.2 |
| 115 | Kharkivska CHP-2 | HC | 74 | 314 | 3,108 | 837 | 6,967 | 4 | 4 | 50 | 58 | 18.6 |
| Total | | | 29,368 | 88,669 | 336,517 | 291,830 | 996,765 | 437 | 1,564 | 7,131 | 9,133 | 10.3 |

Table 3-13: Estimated External Costs of Emissions in 2014 on Kosovo*

| Code | Plant name | Fuel Type | Power MW | Energy GWh/a | Emission - BAU | | | External Costs - BAU | | | | |
|-------|------------|-----------|----------|--------------|------------------------------|-----------------|-----------------|-----------------------------|-----------------|-----------------|-----|-----------|
| | | | | | Pollutants emissions, t/year | | | Total costs, million €/year | | | | Unit cost |
| | | | | | Dust | NO _x | SO ₂ | Dust | NO _x | SO ₂ | Sum | €/kWh |
| 1 | Kosovo A3 | L | 200 | 590 | 200 | 2,651 | 2,443 | 0.2 | 23.0 | 20.4 | 43 | 7.4 |
| 2 | Kosovo A4 | L | 200 | 590 | 2,969 | 2,802 | 2,374 | 2.4 | 24.3 | 19.8 | 46 | 7.9 |
| 3 | Kosovo A5 | L | 210 | 606 | 189 | 2,850 | 2,481 | 0.2 | 24.7 | 20.7 | 46 | 7.5 |
| 4 | Kosovo B1 | L | 339 | 1,083 | 2,537 | 4,777 | 3,772 | 2.1 | 41.4 | 31.5 | 75 | 6.9 |
| 5 | Kosovo B2 | L | 339 | 1,083 | 2,688 | 4,873 | 3,699 | 2.2 | 42.2 | 30.8 | 75 | 6.9 |
| Total | | | 1,288 | 3,951 | 8,582 | 17,952 | 14,768 | 7 | 155 | 123 | 286 | 7.2 |

4. Estimated investment cost of the environmental upgrade scenarios

One of the main objectives of this study is to develop different scenarios in order to meet the requirements of the LCPD/IED, which can be achieved either by the modernization of large combustion plants, by changing fuels or by the replacement of existing LCP units with new, more energy efficient units the emissions of which are in compliance with therequirements of the Directives. For each plant at least two scenarios for reaching compliance with the requirements of the LCPD and at least one scenario for reaching compliance with the requirements of the IED should have been developed.

To fulfil the above mentioned objectives, it is necessary to define the best available technologies (BAT), including their technical and economical characteristics, which can be applied for the environmental upgrade of large combustion plants in the Energy Community Contracting Parties.

The description of the assessed technologies for the environmental upgrade of thermal power plants or combined heat and power plants and their technical performances relating to the efficiency of the pollutants removal from flue gas (reliability, energy consumption, etc.) is presented in Annex 1 of this study.

In Annex 2 a description of the methods of environmental upgrading techniques is presented with estimates on the necessary investment and O&M (operation and maintenance) costs.

The elements that have a dominant influence on the costs are:

- Flue gas flow rate or unit size
- Concentration of pollutant in flue gas
- Kind and characteristics of fuel
- Time of emission reduction techniques implementation (index of cost at the market)
- Site conditions.

For each Contracting Party, two scenarios for reaching compliance with the requirements of the LCPD and one for reaching compliance with the requirements of the IED is developed, with the exceptions of Albania and partially for Moldova, as they have very low emission concentrations.

The characteristics of electric power systems represent important elements for the creation of scenarios.

The costs of unit replacement, by use of contemporary technology, are found to be in the ranges of:

- For lignite fired TPPs, depending on the unit size 1.55 – 1.7 mil. €/MW,
- For BC fired TPP, depending on the unit size 1.5 – 1.65 mil. €/MW,

- For HC fired units, depending on the unit size 1.4 – 1.55 mil. €/MW,
- For gas fired units, depending on the unit size 1.3 – 1.4 mil. €/MW,
- For Combined Gas-fired Turbine (CCGT) 1.0 mil. €/MW.

The majority of LCPs include units of different size and some of them include units fired by different fuels. For this reason, each LCP unit had to be analysed individually. The aggregated values of costs for individual LCPs are presented here, in order to concise the study report.

4.1. Scenarios for environmental upgrading of LCPs in Albania

The Albanian power system is almost entirely based on hydro resources. Approximately 98 % of the electricity production is coming from the hydro power plants (with 65 % of hydro potential still unexploited. Nine TPP units have been decommissioned in the past and only TPP Vlora is in operation at present.

TPP Vlora is an oil and gas-fired combined cycle power plant, with one shaft turbine-generator set, consisting of one gas turbine, one steam turbine and a generator in a single shaft arrangement. The plant was commissioned in October 2011 and, due to severe defects, it was stopped and put in reserve operation in January 2012. The current plan is to start its commercial operation by the end of 2014.

The main technical data of TPP Vlora are:

- Installed capacity 100 MW
- Existing emission in air (measuring data)
 - Emission of NO_x 67 mg/Nm³
 - SO₂ 48 mg/Nm³
 - Dust - PM 1.37 mg/Nm³.

Taking into account the results of emission measurements and the ELVs of both directives, it is not necessary to apply any emission reduction measures as the plant is already in line with their requirements.

4.2. Scenarios for environmental upgrading of LCPs in Bosnia and Herzegovina

The existing thermal power system in BiH is based on the use of coal (lignite and brown coal) as a fuel. The characteristic of the coal used results in major differences in sulphur dioxide emissions: at TPP Ugljevik, the concentration of sulphur dioxide in the raw flue gas varies from 12,000 to 20,000 mg/Nm³ (with a representative value of 16,200 mg/Nm³) while TPP Gacko has sulphur dioxide emissions that are about 20 times lower. The country does not have its own natural gas resources, nor has it developed the gas transport system. The reserves

of crude oil are too low to be used for electricity production.

All TPP units are old and a number of them are running beyond their planned operational lifetime. All units have a low energy efficiency rate (their specific heat consumption varies from 11,500 up to 14,500 kJ/kWh) and some are de-rated.

Bearing in mind the above-mentioned facts, it can be concluded that the only logical scenario, besides the two scenarios relating to application of the emission reduction measures, is the replacement of the oldest, low energy efficient LCP units, with new modern coal fired units.

4.2.1. Scenario 1 - Installation of emission reduction measures in compliance with the LCPD

The first emission reduction scenario includes application of the emission reduction measures aimed to bring all TPP units that will be in operation after 31 December 2017, into compliance with the requirements of the LCP Directive. The scenario is presented in Table 4-1.

Retrofitting of electrostatic precipitators of TPP Kakanj 5 and 6 was done before 31/12/2012 to bring the dust - PM emissions into compliance with the LCP Directive. Similarly, the ESP is upgraded in TPP Kakanj 7, but the emission concentrations are still higher than the ELVs of the Directive.

Primary measures for the reduction of NO_x emissions were applied in TPP Tuzla 5 before 31/12/2012 to bring NO_x emissions into compliance with the LCPD. Similar measures have been implemented in other units of TPP Tuzla and Kakanj, but the emissions of NO_x still fail to demonstrate compliance with the ELVs.

The analysis of Scenario 1 has shown that the investments necessary for reaching compliance with the LCPD would be the following:

Table 4-1 Emission reduction cost in compliance with LCPD, Scenario 1, BiH (mil. €)

| No. | Plant name | Pollutant | | | Total for plant |
|-------|------------|-----------|-----------------|-----------------|-----------------|
| | | Dust | NO _x | SO ₂ | |
| 1 | Gacko | 11.4 | 9 | 13 | 33.4 |
| 2 | Ugljevik | 14 | 8.4 | 85.5 | 107.9 |
| 3 | Tuzla | 6.3 | 5.6 | 74 | 85.8 |
| 4 | Kakanj | 0.5 | 22.8 | 87 | 110.3 |
| Total | | 31.9 | 45.8 | 259.5 | 337.2 |

4.2.2. Scenario 2 - Emission reduction measures in compliance with the IED

Scenario 2 includes application of emission reduction measures with a view to bring emissions into compliance with the IED. The retrofitting of the electrostatic precipitators of TPP Kakanj 5 and 6 was done before 31/12/2012 to bring the emissions of dust - PM into compliance with the IED. Primary measures for the reduction of NO_x emissions were applied in TPP Tuzla 5 before 31/12/2012 to bring the emissions of NO_x into compliance with the IED. The results of the analysis are presented in Table 4-2.

Table 4-2 Emission reduction cost, Scenario 2, BiH (mil. €)

| No. | Plant name | Pollutant | | | Total for plant |
|-------|------------|-----------|-----------------|-----------------|-----------------|
| | | Dust | NO _x | SO ₂ | |
| 1 | Gacko | 14 | 9 | 14.3 | 37.3 |
| 2 | Ugljevik | 15 | 8.4 | 95 | 118.4 |
| 3 | Tuzla | 3 | 5.6 | 83 | 91.6 |
| 4 | Kakanj | 1.5 | 29.4 | 96 | 127.4 |
| Total | | 33.5 | 53 | 288.3 | 374.7 |

4.2.3. Scenario 3 - Emission reduction measures and replacement of some TPP units for reaching ELV in compliance with the LCPD

Scenario 3 includes the replacement of TPP Tuzla 4 and TPP Kakanj 5, whose decommissioning are planned for 2018 and 2019, respectively, with modern, high energy efficient (minimum 41 %) units. Furthermore, this scenario includes the application of emission reduction measures in other TPP units. The retrofitting of electrostatic precipitators of units 5 and 6 of TPP Kakanj was done before 31.12.2012 to bring the emissions of dust into compliance with the LCP Directive. Primary measures for the reduction of NO_x emissions were done in TPP Tuzla 5 before 31.12.2012 to bring the emissions of NO_x into compliance with the LCP Directive.

The specific construction costs for new units are assessed to be 1,650,000 €/MW for the lignite-fired TPP Tuzla 4 and 1,600,000 €/MW for the brown coal-fired TPP Tuzla 5.

The results of the analysis of investment costs for Scenario 3 are presented in Table 4-3.

Table 4-3 Emission reduction cost, Scenario 3, BiH (mil. €)

| No. | Plant name | Pollutant | | | Total for reduction measures | Total for other measures | Total for plant |
|-------|------------|-----------|-----------------|-----------------|------------------------------|--------------------------|-----------------|
| | | Dust | NO _x | SO ₂ | | | |
| 1 | Gacko | 11,4 | 9 | 13 | 33.4 | | 33.4 |
| 2 | Ugljevik | 14 | 8,4 | 86 | 107.9 | | 107.9 |
| 3 | Tuzla | 5.2 | 2.6 | 39 | 34.7 | 330 | 364.7 |
| 4 | Kakanj | 0.5 | 22,8 | 87 | 110.3 | 320 | 430.3 |
| Total | | 32.2 | 45,8 | 260 | 297.9 | 650 | 947.9 |

4.3. Scenarios for environmental upgrading of TPPs in Croatia

The Croatian thermal power system has only one coal-fired TPP, TPP Plomin, with two of its units fired with imported hard coal. TPP Plomin 1 will be retired when new unit Plomin 3 started operation. In TPP Plomin 2, during the reconstruction works both electrostatic precipitator and WLS FGD system were installed to bring the emission of dust and SO₂ in compliance with the LCPD and IED.

All other TPP and CHP units are fired by oil, natural gas or a combination of the two.

The current emission concentrations of TPP Jertovac and CHPs Zagreb – (units K, L, H and J) and Osijek are in compliance with the LCPD, while the emission concentrations in CHP Zagreb (units K and L) are in compliance with the IED.

4.3.1. Scenario 1 - Emission reduction measures for reaching compliance with the LCPD

Scenario 1 includes application of emission reduction measures in all TPP and CHP units which will not be retired before 31.12.2017 and whose emissions are not in compliance with the ELVs of the LCPD. The results are presented in Table 4-4.

Table 4-4: Emission reduction costs in compliance with LCPD, Scenario 1, Croatia (mil. €)

| No. | Plant name | Pollutant | | | Total for plant |
|-------|------------|-----------|-----------------|-----------------|-----------------|
| | | Dust | NO _x | SO ₂ | |
| 1 | Plomin | 0 | 20.0 | 0 | 20.0 |
| 2 | Rijeka | 6.0 | 8.2 | 47 | 61.2 |
| 3 | Sisak | 9.6 | 11.8 | 92 | 113.4 |
| 4 | Zagreb | 4.8 | 3.8 | 25 | 33.6 |
| 5 | Osijek | 0 | 0 | 0 | 0 |
| Total | | 20.4 | 43.8 | 164 | 228.2 |

4.3.2. Scenario 2 - Emission reduction measures for reaching compliance with IED

This scenario includes the implementation of appropriate emission abatement measures to bring the emissions of dust, NO_x and SO₂ in compliance with ELVs of the IED.

According to the obtained results, the necessary investments for individual TPPs are presented in Table 4-5.

Table 4-5: Emission reduction cost in compliance with IED, Scenario 2, Croatia (mil. €)

| No. | Plant name | Pollutant | | | Total for plant |
|-------|------------|-----------|-----------------|-----------------|-----------------|
| | | Dust | NO _x | SO ₂ | |
| 1 | Plomin | 0 | 20.0 | 0 | 20.0 |
| 2 | Rijeka | 6.8 | 30.0 | 51.7 | 88.5 |
| 3 | Sisak | 10.6 | 40 | 101.2 | 151.8 |
| 4 | Jertovac | 0 | 2 | 0 | 2.0 |
| 5 | Zagreb | 5.3 | 15.9 | 32 | 53.2 |
| 5 | Osijek | 0 | 2.7 | 0 | 2.7 |
| Total | | 22.7 | 109.6 | 184.9 | 318.2 |

4.3.3. Scenario 3 - Emission reduction measures, replacement of some TPP units and change of fuel for reaching compliance with the LCPD, Croatia

This scenario includes the replacement of TPP Rijeka with a new modern unit of the same capacity, the replacement of units K6, K8, H and J in CHP Zagreb with one unit of 100 MW capacity, the use of natural gas instead of fuel oil in TPP Sisak and implementing emission reduction measures for the remaining TPP and CHP units. The results are presented in Table 4-6.

Table 4-6: Emission reduction cost in compliance with LCPD, Scenario 3, Croatia (mil. €)

| No. | Plant name | Pollutant | | | Total for plant |
|-------|------------|-----------|-----------------|-----------------|-----------------|
| | | Dust | NO _x | SO ₂ | |
| 1 | Plomin | 0 | 20.0 | 0 | 20.0 |
| 2 | Rijeka | | | | 416.0 |
| 3 | Sisak | | 6.6 | | 113.4 |
| 4 | Zagreb | 2.7 | 2.8 | 19.0 | 154.5 |
| 5 | Osijek | 0 | 0 | 0 | 0 |
| Total | | 2.7 | 29.4 | 19.0 | 703.9 |

4.4. Scenarios for environmental upgrading of LCPs in FYR Macedonia

Thermal power plants in FYR Macedonia include two lignite fired TPPs: TPP Bitola, with a capacity of 3x233 MW and TPP Oslomej, with a capacity of 125 MW. TPP Negotino, with a capacity 210 MW, is designed to be an oil-fired thermal power plant. However, due to high oil price, TPP Negotino has been in reserve operation for most of the time. Furthermore, there are two CHP plants: Skopje (227 MW) and Kogel (30 MW). The CHPs are in operation since 2012 and are fully compliant to the LCPD and IED emission standards.

4.4.1. Scenario 1 - Emission reduction measures in compliance with the LCPD

Scenario 1 includes application of emission reduction measures in all TPP units. The results are presented in Table 4-7. The status of TPP Negotino shall be decided in the future.

Table 4-7: Emission reduction cost, Scenario 1, FYR Macedonia (mil. €)

| No. | Plant name | Pollutant | | | Total for plant |
|-------|------------|-----------|-----------------|-----------------|-----------------|
| | | Dust | NO _x | SO ₂ | |
| 1 | Bitola | 34.8 | 30 | 126.9 | 191.7 |
| 2 | Oslomej | 7 | 6 | 25 | 38 |
| 3 | Negotino | | | | 0 |
| Total | | 41.8 | 36 | 151.9 | 229.7 |

4.4.2. Scenarios 2 - Emission reduction measures for reaching compliance with the IED

The assessed investment costs of this scenario are presented in Table 4-8.

Table 4-8: Emission reduction cost, Scenario 2, FYR Macedonia (mil. €)

| No. | Plant name | Pollutant | | | Total for plant |
|-------|------------|-----------|-----------------|-----------------|-----------------|
| | | Dust | NO _x | SO ₂ | |
| 1 | Bitola | 39 | 55.8 | 139.5 | 334.3 |
| 2 | Oslomej | 8 | 1.8 | 27.5 | 37.3 |
| 3 | Negotino | | | | 0 |
| Total | | 47 | 57.6 | 167 | 371.6 |

4.4.3. Scenario 3 - Replacement of TPP units for reaching compliance with the LCPD

Lignite is the only domestic fuel in FYR Macedonia that can be used for electricity production. At the same time, FYR Macedonia has not developed a gas supply system. These facts indicate that a scenario related to the replacement of existing TPP units with modern lignite-fired units can be considered as a possible option. In this case, the assessed investment costs would amount to a level as presented in Table 4-9.

Table 4-9: Emission reduction cost, Scenario 1, FYR Macedonia (mil. €)

| No. | Plant name | Pollutant | | | Total for plant |
|-------|------------|--|-----------------|-----------------|-----------------|
| | | Dust | NO _x | SO ₂ | |
| 1 | Bitola | Replaced units (699 MW x 1.65 mil. €/MW) | | | 1,153.0 |
| 2 | Oslomej | Replaced units (125 MW x 1.7 mil. €/MW) | | | 213.5 |
| 3 | Negotino | | | | |
| Total | | | | | 1,366.5 |

Decommissioning of TPP units is planned between 2027 and 2029, which suggests that all units are in good technical and operational conditions and that this scenario will probably not be financially viable.

4.5. Scenarios for environmental upgrading of LCPs in Moldova

All CHPs in Moldova use natural gas as a fuel. Table 4-10 presents the main data on the CHP units that are relevant to the determination of the costs for emission reduction. As it can be seen from the table, the current level of emissions is already in compliance with the requirements of the LCPD. The results presented in Table 4-10 indicate that five units should be brought into compliance with the IED and that it is necessary to apply measures for the reduction of NO_x emissions.

Table 4-10: Need for emission reduction and its cost

| No | Plant name | Fuel | Capacity | | Emission, BAU | | | ELV, LCPD | | | ELV, IED | | | Putting in compliance with IED, mil € NO _x |
|-------|-------------|------|----------|--------|--------------------|-----------------|-----------------|--------------------|-----------------|-----------------|--------------------|-----------------|-----------------|--|
| | | | El. MW | Th. MW | mg/Nm ³ | | | mg/Nm ³ | | | mg/Nm ³ | | | |
| | | | | | Dust | NO _x | SO ₂ | Dust | NO _x | SO ₂ | Dust | NO _x | SO ₂ | |
| 1 | CET-1, No 1 | G | 12 | | | 96 | | 5 | 300 | 35 | 5 | 100 | 35 | 0,00 |
| 2 | CET-1, No 2 | G | 12 | | | 113 | | 5 | 200 | 35 | 5 | 100 | 35 | 0,053 |
| 3 | CET-1, No 3 | G | 10 | | | 115 | | 5 | 300 | 35 | 5 | 100 | 35 | 0,054 |
| 4 | CET-1, No 4 | G | 27 | | | 97 | | 5 | 300 | 35 | 5 | 100 | 35 | 0,00 |
| 5 | CET-1, No 5 | G | 5 | | | 72 | | 5 | 300 | 35 | 5 | 100 | 35 | 0,00 |
| 6 | CET-2, No 1 | G | 80 | | | 137 | | 5 | 200 | 35 | 5 | 100 | 35 | 0,46 |
| 7 | CET-2, No 2 | G | 80 | | | 155 | | 5 | 200 | 35 | 5 | 100 | 35 | 0,88 |
| 8 | CET-2, No 3 | G | 80 | | | 142 | | 5 | 300 | 35 | 5 | 100 | 35 | 0,48 |
| Total | | | 306 | | | | | | | | | | | 1,93 |

The necessary investments are estimated at:

- for compliance with the LCPD, for all CHPs 0.0 mil. €
- for compliance with IED:
 - for CET – 1 0.107 mil. €
 - for CET-2 1.820 mil. €

4.6. Scenarios for environmental upgrading of TPPs in Montenegro

Montenegro has one TPP unit, TPP Pljevlja, with a capacity of 219 MW and an energy efficiency level of 31 %. According to current plans, it should be decommissioned by 2025 the latest.

4.6.1. Scenario 1 - Emission reduction measures in compliance with the LCPD

The assessed investment cost for achieving compliance with LCPD is 46.9 mil. €. The current dust emission concentration is $\leq 30 \text{ mg/Nm}^3$ which is in line with the ELVs of the LCPD. As regards NO_x emission reduction, primary measures shall be applied (LNB+OFA), which would cost 4.9 mil. €. For the reduction of SO₂ FGD WLS would be the most feasible option, with an estimated investment cost of 42 mil. €.

4.6.2. Scenario 2 - Emission reduction measures for reaching compliance with IED

The necessary investments for reaching compliance with the IED are estimated at 50.9 mil. € (4.9 mil. € for deNO_x and 46 mil. € for applying WLS technology). The current level of dust emissions (30 mg/Nm^3) could be further reduced by FGD reaching a level lower than 20 mg/Nm^3 .

4.6.3. Scenario 3 - Replacement of TPP for reaching ELV in compliance with the LCPD

The replacement of TPP Pljevlja with a modern unit with high efficiency would require an investment of approximately 370 mil. €.

4.7. Scenarios for environmental upgrading of LCPs in Serbia

Lignite is the only domestic fuel in Serbia that can be used for electricity production and it is the source of the large majority of the TPPs operating in the country (Nikola Tesla, Kolubara, Kostolac and Morava). Furthermore, 3 plants (Novi Sad, Zrenjanin and Sremska Mitrovica) are fired by natural gas.

The electric power system of Serbia includes two corporate companies with 6 TPPs. Company Nikola Tesla includes TPP Nikola Tesla A (with a capacity of 2x210 MW+305 MW+ 3x308 MW), TPP Nikola Tesla B (2x620 MW), TPP Kolubara A (3x32 MW+64 MW+110 MW) and TPP Morava (120 MW). Company Kostolac includes TPP Kostolac A (100 MW+210MW) and TPP Kostolac B (2x350 MW).

Scenario 1 includes installation of emission reduction measures in all TPP and CHP units that will not be retired before 31/12/2017 and whose emissions are not in compliance with the ELVs set out in the LCPD. The electrostatic precipitators of units A4, A5, A6 and B2 TPP Nikola Tesla as well as unit A5 of TPP Kolubara are retrofitted thus the existing dust emissions are in compliance with the LCPD.

The results of the analyses for each TPP unit have shown that the necessary investments for bringing emissions into compliance with the LCPD's requirements would amount to those presented in Table 4-11.

Table 4-11: Emission reduction costs in compliance with the LCPD, Scenario 1, Serbia (mil. €)

| No. | Plant name | Pollutant | | | Total for plant |
|-------|-------------------|-----------|-----------------|-----------------|-----------------|
| | | Dust | NO _x | SO ₂ | |
| 1 | Nikola Tesla A | 15.2 | 33.5 | 188 | 236.7 |
| 2 | Nikola Tesla B | 9.4 | 27.2 | 128 | 164.6 |
| 3 | Kolubara A | 3.2 | 0 | 13.6 | 16.8 |
| 4 | Morava | 7.2 | 0 | 9.8 | 17 |
| 5 | Kostolac A | 7.9 | 4.2 | 45 | 57.1 |
| 6 | Kostolac B | 15.7 | 18.9 | 102 | 136.6 |
| 7 | Novi Sad | 0 | 7.3 | 0 | 7.3 |
| 8 | Zrenjanin | 0 | 3.3 | 0 | 3.3 |
| 9 | Sremska Mitrovica | 0 | 1 | 0 | 1 |
| Total | | 58.6 | 95.4 | 486.4 | 640.4 |

4.7.1. Scenario 2 - Emission reduction costs in accordance with the requirements of the IED

This scenario includes the application of emission reduction measures in all units in operation after 01.01.2018 in order to meet the ELVs set out in the IED.

Table 4-12: Emission reduction cost for reaching compliance with the IED, Scenario 2 (mil. €)

| No. | Plant name | Pollutant | | | Total for plant |
|-------|-------------------|-----------|-----------------|-----------------|-----------------|
| | | Dust | NO _x | SO ₂ | |
| 1 | Nikola Tesla A | 17.1 | 33.5 | 207 | 257.6 |
| 2 | Nikola Tesla B | 9.4 | 27.2 | 142 | 178.6 |
| 3 | Kolubara A | 4 | 3 | 16.5 | 23.5 |
| 4 | Morava | 8 | 3.4 | 11 | 22.4 |
| 5 | Kostolac A | 8.7 | 6.2 | 50 | 64.9 |
| 6 | Kostolac B | 17.5 | 18.9 | 110 | 146.4 |
| 7 | Novi Sad | 0 | 10.7 | 0 | 10.7 |
| 8 | Zrenjanin | 0 | 4.8 | 0 | 4.8 |
| 9 | Sremska Mitrovica | 0 | 1.8 | 0 | 1.8 |
| Total | | 64.7 | 109.5 | 536.5 | 710.7 |

4.7.2. Scenario 3 - Installation of emission reduction measures in accordance with the ELVs of the LCPD and replacement of existing, low efficiency units

Scenario 3 includes:

- The replacement of the old lignite-fired TPP units that have low energy efficiency and planned to be retired until 2021 (including Kostolac A2, planned to be retired in 2024) with new, high efficiency TPPs (minimum 41 %, with supercritical steam parameters):
 - Nikola Tesla A1 and A2, efficiency 30 % 420 MW
 - Kolubara A1, A2 and A4, efficiency 25.5 % and A5 efficiency 29.5 % 238 MW
 - Kostolac A1 and A2, efficiencies 33 % and 32.5 % 310 MW
 - Morava, efficiency 30 % 125 MW
- Replacement of the units in CHP Novi Sad with CCGHT units the emissions of which are in compliance with the requirements of the LCPD.
- Replacement of CHP Zrenjanin with CCGHT capacity and transferring it in reserve capacity.
- Switching from natural gas to biomass as a fuel in CHP Sremska Mitrovica with 80 % efficiency.

The results are presented in Table 4-13.

Table 4-13: Emission reduction cost, Scenario 1, Serbia (mil. €)

| No. | Plant name | Pollutant | | | Total for plant |
|-------|-----------------------|---|-----------------|-----------------|-----------------|
| | | Dust | NO _x | SO ₂ | |
| 1 | Nikola Tesla A1&A2 | Replaced by 420 MW unit (420 MWx1.6mil. €/MW) | | | 672 |
| | Nikola Tesla A3 to A6 | 10.5 | 25.5 | 156 | 192 |
| 2 | Nikola Tesla B | 9.4 | 27.2 | 128 | 164.6 |
| 3 | Kolubara A | Replaced by lignite-fired 174 MW unit (174MWx1.7mil. €/MW) | | | 295.8 |
| 4 | Morava | 7.2 | 0 | 9.8 | 17 |
| 5 | Kostolac A | Replaced by lignite-fired 310 MW unit (310MWx1.6mil. €/MW) | | | 496 |
| 6 | Kostolac B | 15.7 | 18.9 | 102 | 136.6 |
| 7 | Novi Sad | Replace by CCGHT (345MWx 1.0 mil. €/MW) | | | 345 |
| 8 | Zrenjanin | 0 | 3.3 | 0 | 3.3 |
| 9 | Sremska Mitrovica | Change of fuel (135 MW _{in} x.43 mil. €/MW _{in}) | | | 58 |
| Total | | 42.8 | 74.9 | 395.8 | 2776.1 |

4.8. Scenarios for environmental upgrading of LCPs in Ukraine

Ukrainian thermal power plants mainly use hard coal as a fuel (some of which can be classified as anthracite). Furthermore, there are eight gas-fired units (Trypilska 2x300 MW, Zaporiska 3x800 MW and Vuglegirska 3x800 MW). All gas-fired units are temporary out of operation and mothballed. The reasons are capacity surplus in the electric power industry of Ukraine and the high price of gas compared to the price of coal. According to the decision of the Ukrainian government, these plants would only be re-introduced in operation if the gas price is reduced to a level concurrent to coal. Ukraine is one of the biggest exporters of coal.

Ukraine has a very large LCP sector with a significant amount of data necessary for the elaboration of the scenarios as requested by the ToR of this study. The authors of this study have been in close contact with the Ukrainian authorities throughout the development of this report, however, it seems that not all possibly available data could have been obtained in the data gathering phase. Therefore, the authors had to base their assessment on the data that was made available which does not impede differing calculations on the estimated investment costs carried out in the framework of other studies.

4.8.1. Scenario 1 - Emission reduction measures in compliance with the LCPD

Since data on the planned retirement date of TPP and CHP units was not available, the necessary environmental upgrade measures for reaching the compliance with LCPD standards have been analysed for each TPP and CHP unit. The investment cost estimates for Scenario 1 are presented in Table 4-14, separately for each unit.

Table 4-14: Emission reduction costs in compliance with LCPD, Scenario 1, Ukraine (mil. €)

| No. | Plant name | Pollutant | | | Total for plant |
|----------|------------------|-----------|-----------------|-----------------|-----------------|
| | | Dust | NO _x | SO ₂ | |
| A | TPPs | | | | |
| 1 | Prydniprovskaya | 57.0 | 146.6 | 203.0 | 406.6 |
| 2 | Kryvorizka | 58.3 | 244.7 | 325.6 | 628.6 |
| 3 | Zaporiska | 24.4 | 181.8/107.8* | 140.9 | 347.1/239.3* |
| 4 | Starobeshivskaya | 126.0 | 33.3 | 200.0 | 359.3 |
| 5 | Slovianskaya | 23.0 | 52.0 | 95.0 | 170.0 |
| 6 | Burshtynskaya | 62.3 | 63.5 | 296.8 | 422.6 |
| 7 | Dobrotvirskaya | 19.7 | 20.6 | 56.0 | 96.3 |
| 8 | Ladyzhinskaya | 42.6 | 144.0 | 198.0 | 384.6 |
| 9 | Trypilska | 40.5 | 134.5/89.9* | 124.0 | 299.0/209.1* |
| 10 | Zmiiivskaya | 68.5 | 251.3 | 248.0 | 567.8 |
| 11 | Vuglegirska | 37.6 | 291.8/96.8* | 140.0 | 469.4/372.6* |
| 12 | Zuevskaya | 28.6 | 107.5 | 149.7 | 285.8 |
| 13 | Kurakhovskaya | 59.2 | 46.3 | 175.0 | 280.5 |
| 14 | Luganskaya | 50.0 | 105.6 | 156.9 | 312.5 |
| 15 | Myronivskaya | 5.7 | 0.3 | 13 | 19.0 |
| B | CHPs | | | | |
| 16 | Bilotserkivskaya | 0 | 0 | 0 | 0.0 |
| 17 | Darnytska | 2.3 | 2.2 | 9 | 13.5 |
| 18 | Kaluska | 3.2 | 0.4 | 7.8 | 11.4 |
| 19 | Kyivskaya | 0 | 34.9 | 0 | 34.9 |
| 20 | Kramatorska | 5.0 | 0 | 10.5 | 15.5 |
| 21 | Odeska | 0 | 2.2 | 0 | 2.2 |
| 22 | Sevastopolska | 0 | 0 | 0 | 0.0 |
| 23 | Simferopilska | 0 | 0 | 0 | 0.0 |
| 24 | Kharkivskaya | 2.3 | 1.7 | 8.6 | 12.6 |
| | Total | 709.6 | 18654/1562.6* | 2557.9 | 5132.9/4819.3* |

Remark: *The second value is without deNO_x of gas fired TPPs, which are currently out of operation

Two options are included: application of the emission reduction measures for all coal- and gas-fired TPP units, with the exception of gas-fired units that are conserved at the time of preparation of this report.

4.8.2. Scenario 2 - Emission reduction in compliance with IED

Results of Scenario 2 include all LCPs presented in Table 4-15 below.

Table 4-15: Emission reduction costs in compliance with IED, Scenario 2, Ukraine (mil. €)

| No. | Plant name | Pollutant | | | Total for plant |
|----------|------------------|-----------|-----------------|-----------------|-----------------|
| | | Dust | NO _x | SO ₂ | |
| A | TPPs | | | | |
| 1 | Prydniprovskaya | 67.9 | 154.8 | 223.0 | 445.7 |
| 2 | Kryvorizka | 70.5 | 244.7 | 356.0 | 671.2 |
| 3 | Zaporiska | 27.4 | 181.8/107.8* | 155.0 | 364.2/290.2* |
| 4 | Starobeshivskaya | 137.2 | 281.5 | 220.0 | 638.7 |
| 5 | Slovianskaya | 24.5 | 52.0 | 325.1 | 457.2 |
| 6 | Burshtynskaya | 68.6 | 63.5 | 61.6 | 129.0 |
| 7 | Dobrotvirskaya | 22.8 | 44.6 | 216 | 421.5 |
| 8 | Ladyzhinskaya | 53.1 | 152.4 | 136.4 | 321.4/276.8* |
| 9 | Trypilska | 50.5 | 134.5/89.9* | 272.7 | 609.2 |
| 10 | Zmiivskaya | 85.2 | 251.3 | 272.7 | 609.2 |
| 11 | Vuglegirskaya | 44.0 | 291.8/96.8* | 154.0 | 489.8/294.8* |
| 12 | Zuevskaya | 44.6 | 107.5 | 164.8 | 316.9 |
| 13 | Kurakhovskaya | 75.0 | 41.4 | 192.6 | 309.0 |
| 14 | Luganskaya | 62.8 | 117.6 | 154.0 | 334.4 |
| B | CHPs | | | | |
| 15 | Bilotserkivskaya | 0 | 3.6 | 0 | 3.6 |
| 16 | Darnytska | 2.9 | 19.3 | 13 | 35.2 |
| 17 | Kaluska | 4.0 | 9.5 | 11.0 | 24.5 |
| 18 | Kyivskaya | 0 | 134.7 | 114.0 | 248.7 |
| 19 | Kramatorska | 6.2 | 0 | 17.0 | 23.2 |
| 20 | Myronivskaya | 6.3 | 5.2 | 20.3 | 31.8 |
| 21 | Odeska | 0 | 7.8 | 0 | 7.8 |
| 22 | Sevastopolska | 0 | 1.2 | 0 | 1.2 |
| 23 | Simferopilska | 0 | 1.4 | 0 | 1.4 |
| 24 | Kharkivskaya | 2.8 | 2.4 | 9.5 | 14.7 |
| | Total | 811.7 | 2,300.9/2,023.3 | 2,920.6 | 6,033.2/5,719.6 |

Remark: * The second value is without DeNO_x of gas fired TPPs, which are currently out of operation

4.8.3. Scenario 3 - Emission reduction in compliance with LCPD

The electric power system of Ukraine has a surplus of installed generation capacity which is one of the main reasons of the very low load factor at which it currently operates (36.8%). The other reason is that the system includes very old units, installed between 1959 and 1963.

This scenario includes:

- Conservation of all gas fired TPP units (Zaporiska 5, 6 and 7, with a capacity of 3x800 MW, Trypilska 5 and 6, with a capacity of 3x300 MW and Vuglegirskaya 5, 6 and 7, with a capacity of 3x800 MW)
- Conservation of all TPP units which are nowadays in lay-up status (Prydniprovskaya 12 and 14, with a capacity of 2x285 MW, Kryvorizka 3, 7 and 9, with a capacity of 3x282 MW and Luganskaya 12, capacity 175 MW)

- Conservation of old units constructed before 1963 (Prydniprovskaya 7, 8, 9 and 10, with a capacity of 4x150 MW, Starobeshivskaya 4, 5 and 6, with a capacity of 3x175 MW, Dobrotvirska 5 and 6, with a capacity of 2x100 MW, Zmiivska 1, 2 and 3, with a capacity of 3x175 MW and Luganskaya 9, 10 and 11, with a capacity of 3x200 MW)

According to this scenario, the total conserved capacity would amount to:

- Gas-fired units 5400 MW
 - In lay-up status 1591 MW
 - Units constructed before 1963 2450 MW
- Total conserved capacity 9441 MW.**

According to the proposed conservation, the average load factor of the LCP units that would remain in operation would increase to 54.2%. The results and cost estimates of this scenario are presented in Table 4-16.

Table 4-16: Emission reduction costs in compliance with LCPD, Scenario 3, Ukraine (mil. €)

| No. | Plant nName | Pollutant | | | Total for plant |
|----------|------------------|-----------|-----------------|-----------------|-----------------|
| | | Dust | NO _x | SO ₂ | |
| A | TPPs | | | | |
| 1 | Prydniprovskaya | 20.9 | 47.9 | 68.5 | 137.3 |
| 2 | Kryvorizka | 44.8 | 171.4 | 226.8 | 443.0 |
| 3 | Zaporiska | 24.4 | 107.8 | 140.9 | 273.1 |
| 4 | Starobeshivskaya | 90.5 | 23.9 | 140.0 | 254.4 |
| 5 | Slovianska | 23.0 | 52.0 | 95.0 | 170.0 |
| 6 | Burshtynska | 47.0 | 63.5 | 296.8 | 407.3 |
| 7 | Dobrotvirska | 13.3 | 19.4 | 34.0 | 66.7 |
| 8 | Ladyzhinska | 42.6 | 144.0 | 198.0 | 384.6 |
| 9 | Trypilska | 40.5 | 89.9 | 124.0 | 254.4 |
| 10 | Zmiivska | 47.5 | 152.9 | 172.0 | 372.4 |
| 11 | Vuglegirska | 37.6 | 96.8 | 140.0 | 274.4 |
| 12 | Zuevskaya | 28.6 | 107.5 | 149.7 | 285.8 |
| 13 | Kurakhovskaya | 59.2 | 46.3 | 175.0 | 280.5 |
| 14 | Luganskaya | 25.0 | 50.4 | 67.2 | 142.6 |
| 15 | Myronivska | 5.7 | 0.3 | 13 | 19.0 |
| B | CHPs | | | | |
| 16 | Bilotserkivskaya | 0 | 0 | 0 | 0.0 |
| 17 | Darnytska | 2.3 | 2.2 | 9 | 13.5 |
| 18 | Kaluska | 3.2 | 0.4 | 7.8 | 11.4 |
| 19 | Kyivska | 0 | 34.9 | 0 | 34.9 |
| 20 | Kramatorska | 5.0 | 0 | 10.5 | 15.5 |
| 21 | Odeska | 0 | 2.2 | 0 | 2.2 |
| 22 | Sevastopolska | 0 | 0 | 0 | 0.0 |
| 23 | Simferopilska | 0 | 0 | 0 | 0.0 |
| 24 | Kharkivska | 2.3 | 1.7 | 8.6 | 12.6 |
| | Total | 563.4 | 1215.4 | 2076.8 | 3855.6 |

4.9. Scenarios for environmental upgrading of LCPs in Kosovo*

The electric power system of Kosovo* is completely based on lignite as there is no gas transmission system developed. The lignite reserve in the territory of Kosovo* amounts to approximately 12.4 billion tonnes. Kosovo* plans to decommission three units of TPP Kosovo A due to their very low efficiency and reliability and to replace

Them by two new, supercritical units with a capacity of 2x300 MW (TPP Kosova e Re). Furthermore, it is planned to upgrade the existing two units of TPP Kosovo B.

4.9.1. Scenario 1 - Emission reduction measures in compliance with the LCPD

Scenario 1 consists of the application of emission reduction measures in two units of TPP Kosovo B (Table 4-17).

Table 4-17: Emission reduction costs in compliance with LCPD, Scenario 1, Kosovo* (mil. €)

| No. | Plant name | Pollutant | | | Total for plant |
|-------|------------|----------------------------------|-----------------|-----------------|-----------------|
| | | Dust | NO _x | SO ₂ | |
| 1 | Kosovo A3 | To be decommissioned before 2018 | | | |
| 2 | Kosovo A4 | To be decommissioned before 2018 | | | |
| 3 | Kosovo A5 | To be decommissioned before 2018 | | | |
| 4 | Kosovo B1 | 10.0 | 13.0 | 16.0 | 39 |
| 5 | Kosovo B2 | 10.9 | 13.0 | 16.0 | 39 |
| Total | | 20.0 | 26.0 | 32.0 | 78 |

4.9.2. Scenario 2 - Emission reduction measures in compliance with the IED

Scenario 2 includes the application of emission reduction measures in two units of TPP Kosovo B (Table 4-18).

Table 4-18: Emission reduction costs in compliance with IED, Scenario 2, Kosovo* (mil. €)

| No. | Plant name | Pollutant | | | Total for plant |
|-------|------------|----------------------------------|-----------------|-----------------|-----------------|
| | | Dust | NO _x | SO ₂ | |
| 1 | Kosovo A3 | To be decommissioned before 2018 | | | |
| 2 | Kosovo A4 | To be decommissioned before 2018 | | | |
| 3 | Kosovo A5 | To be decommissioned before 2018 | | | |
| 4 | Kosovo B1 | 11.5 | 13.0 | 17.6 | 42.1 |
| 5 | Kosovo B2 | 11.5 | 13.0 | 17.6 | 42.1 |
| Total | | 23.0 | 26.0 | 35.2 | 84.2 |

4.9.3. Scenario 3 - Replacement of TPP units for reaching compliance with the IED

This scenario includes the replacement of two existing TPP units with new ones, constructed in compliance with IED.

Table 4-19: Emission reduction costs in compliance with IED, Scenario 3, Kosovo* (mil. €)

| No. | Plant name | Pollutant | | | Total for plant |
|-------|------------|------------------------------------|-----------------|-----------------|-----------------|
| | | Dust | NO _x | SO ₂ | |
| 1 | Kosovo A3 | Will be decommissioned before 2017 | | | |
| 2 | Kosovo A4 | Will be decommissioned before 2017 | | | |
| 3 | Kosovo A5 | Will be decommissioned before 2017 | | | |
| 4 | Kosovo B1 | Replaced by new 339 MW unit | | | 545 |
| 5 | Kosovo B2 | Replaced by new 339 MW unit | | | 545 |
| Total | | 1090 | | | |

5. Cost-benefit analysis of environmental upgrade scenarios for LCPs

5.1. Basic assumptions and input data for analysing costs and benefits

The valuation of different scenarios of the environmental upgrading of thermal power plants and combined heat and power production plants is performed by use of the cost-benefit analysis (CBA) methodology. This methodology represents an economic analysis undertaken from the point of view of the society as a whole, considering also environmental factors.

The CBA used in the present report is an economic quantification of all costs and benefits for thermal power plants and combined heat and power plants in the Energy Community Contracting Parties related to compliance with the requirements of the LCPD and the IED and with regard to emissions of pollutants into the air.

Costs include the following items:

1. Investment costs incurred, which contain all capital expenditures for:
 - The upgrade and/or replacement of electrostatic precipitators and/or fabric filters;
 - The use of necessary primary and secondary measures for NO_x reduction;
 - The construction of a flue gas desulphurization plant for SO₂ reduction.
2. The operation and maintenance (O&M) costs, for the above-mentioned systems and equipment, which include the following: raw material costs, maintenance costs, water and power consumption, labour costs, insurance costs and waste disposal costs. The O&M costs are evaluated on a yearly basis, in proportion to the electricity production.

Benefits consist of the monetization of avoidance of all external costs of emissions, compared to the business as usual (BAU) scenario. Benefits are evaluated by applying the corresponding external cost coefficients per unit of pollutant mass for the emission of all pollutants, presented in Table 3-4 of Chapter 3 for each Contracting Party.

Once the stream of economic costs and benefits is estimated, the standard Discounted Cash Flow (DCF) methodology is applied. Since there is a large variation of costs and benefits during the operational lifetime of a plant, they shall be summarized by the use of an appropriate social discount rate. This rate shall apply after the year of the beginning of the program, which is the start-up year of the post-retrofit plant lifetime. However, as there is a lack of key dates as regards the start-up dates for environmentally upgraded units, the CBA of the present report is carried out with the assumption that environmental upgrades will start at the beginning of 2018 (the final date for implementing the LCPD) and will end by 2030.

The social discount rate has been used according to the new tendency, in relation to social project appraisal in EU countries¹⁷. Therein, based on social time preference (STPR), a standard benchmark European discount rate of 3% is recommended. This result is similar to the real long-term bond rate for the eurozone countries and squares approximately with the current official discount rates set by the German, French and British governments as well as the usual practice in the European Union. Therefore, the discount rate of **3%** is used throughout this study for the CBA.

The Net Present Value (NPV) for each scenario of the environmental upgrade project had been evaluated. The NPV presents the difference of the sum of all discounted benefits and the sum of all discounted incurred costs. In addition, the B/C Ratio is calculated for each TPP unit, which can be used for the ranking of TPP units, separately for the LCPD and IED scenarios.

The scenarios of environmental upgrading are defined in Chapter 4, together with the application of best available techniques (BAT) for the emission reduction of pollutants, as well as with the estimates of the investment costs and also the estimates of the operation and maintenance costs. Following the analysis made in Chapter 4, the CBA is performed for the following scenarios:

- **Scenario 1**, including the implementation of all necessary measures to upgrade the emission abatement equipment in TPP units according to the LCPD standards;
- **Scenario 2**, similar to Scenario 1, but with the requirements of the IED, which have higher emission standards; and
- **Scenario 3**, an alternative technical solution to Scenario 1, aiming to achieve the LCPD standards with no need of applying BAT to the existing TPP units.

The methodology used in the cases of Scenarios 1 and 2 is the following:

- $B = \sum_{k=1}^{k=n} B_k * (1 + r)^{-k}$, and
- $C = I_{eu} + \sum_{k=1}^{k=n} OM_k * (1 + r)^{-k}$,

Where:

- B_k stands for the benefit in the year “k”,
- B stands for the present value of all benefits,
- I_{eu} stands for the investment costs of environmental upgrade systems,
- OM_k stands for the operation and maintenance costs of environmental upgrade systems,
- r stands for the social discount rate,
- C stands for the present value of all costs.

¹⁷Social Discount Rates for the European Union, David J. Evans, J. of Economic Studies, Vol. 321ss:1, pp. 47-59

Scenario 3 has to be in compliance with the LCPD and therefore can be compared with Scenario 1. Scenario 3 is usually defined as a replacement of one or more old TPP units, by new TPP units using the same fuel with modern, contemporary technology. The change of fuels in the existing TPPs is a theoretical possibility as TPPs are generally based on particular coal mines, with the exemption on coal-fired stations running on imported coal. Switching plants to natural gas is more costly and in a number of cases, gas is not available.

The existing thermal power plants are over 30 years old (in some cases over 50 years), with the net plant efficiency between 30-33% (corresponding to specific fuel consumption of 10,900 to 12,000 kJ/kg), in certain cases even below 25% (fuel consumption of 14,400 kJ/kWh). Contemporary thermal power plants using state-of-the-art technologies are designed with supercritical steam boilers of larger capacities, with a net plant efficiency of approximately 42% (specific fuel consumption of 8,570 kJ/kWh). New TPPs will fulfil all requirements of the LCPD and therefore will have the same concentrations of emissions as in the case of Scenario 1. However, due to higher net plant efficiency, there will be fuel savings per each unit of electricity produced. As a consequence of fuel savings, a reduction of total emissions is expected resulting in a reduction of external costs which, at the same time, means an increase of benefits by reducing fuel costs as well as the O&M costs of the emission control systems.

The above-mentioned parameters of certain foreseen alternative solutions are presented within this Chapter. They are to be analysed and used for the preparation of feasibility studies for individual TPP units, which would be chosen as candidates for the units' replacements.

5.2. CBA for Albania

Albania has only one thermal power plant, Vlora, with a combined cycle gas turbine and steam generator as well as a steam turbine. The plant uses light distillate oil with low sulphur content and shall use natural gas once it becomes available. TPP Vlora is a new plant, designed according to contemporary technology, with a net plant efficiency exceeding 50%. The plant is designed to meet the emission standards of the IED. Therefore, there is no need to carry out a cost-benefit analysis. All other thermal power plants in Albania have been decommissioned.

5.3. CBA for Bosnia and Herzegovina

The benefits for avoiding external costs for TPPs in Bosnia and Herzegovina are presented in Table 5-1, both for the LCPD and the IED. These benefits are obtained according to the methodology and data presented in Chapter 3 for the present state of emission control, reduced by the proportion of the required emission concentrations presented in Chapter 2. However, in case that the present emissions are lower than the required ELVs for a certain scenario, emissions for that scenario are as summed at their present levels. The benefits are calculated for

the period of 2018 to 2030 and discounted to the year 2017.

The cost calculation is based on the data presented in Chapter 4. The investment cost estimate for the environmental upgrade of each TPP unit is presented in Annex 3 (Table A3-1 for Scenario 1 and Table A3-2 for Scenario 2). The annual O&M costs are presented in the same tables alongside the investment costs. The value of total investment costs amounts to 337 million € for LCPD and 375 million € for IED, while O&M costs amount up to 36 million € and 38 million € respectively for these scenarios.

The results of the CBA are presented in Table 5-2 for Scenario 1 and in Table 5-3 for Scenario 2. The results show that in all cases, benefits significantly exceed the costs of environmental upgrading. The average B/C ratio is about 36 for the LCPD scenario and 35 for the IED scenario.

Table 5-1: Pollution control benefits for Bosnia and Herzegovina

| Code | Plant name | Fuel type | Power MW | Energy GWh/a | PV for LCPD | | | | PV for IED | | | |
|-------|------------|-----------|----------|--------------|-------------------------------------|-----------------|-----------------|--------|-------------------------------------|-----------------|-----------------|--------|
| | | | | | External costs reduction, million € | | | | External costs reduction, million € | | | |
| | | | | | Dust | NO _x | SO ₂ | Sum | Dust | NO _x | SO ₂ | Sum |
| 1 | Gacko | L | 300 | 1,934 | 11 | 388 | 917 | 1,316 | 13 | 388 | 1,084 | 1,484 |
| 2 | Ugljevik | L | 300 | 2,176 | 10 | 312 | 14,141 | 14,463 | 11 | 312 | 14,320 | 14,643 |
| 3 | Tuzla 3 | L | 110 | 473 | 0 | 0 | 111 | 111 | 0 | 33 | 357 | 390 |
| 4 | Tuzla 4 | L | 200 | 1,196 | 1 | 90 | 947 | 1,038 | 2 | 90 | 1,054 | 1,146 |
| 5 | Tuzla 5 | L | 200 | 1,004 | 0 | 0 | 680 | 680 | 1 | 0 | 771 | 772 |
| 6 | Tuzla 6 | L | 215 | 1,008 | 0 | 68 | 1,385 | 1,453 | 0 | 68 | 1,463 | 1,531 |
| 7 | Kakanj 5 | L | 110 | 598 | 0 | 124 | 1,645 | 1,769 | 0 | 237 | 1,860 | 2,097 |
| 8 | Kakanj 6 | L | 110 | 312 | 0 | 21 | 821 | 842 | 0 | 78 | 929 | 1,008 |
| 9 | Kakanj 7 | L | 230 | 1,342 | 4 | 375 | 4,035 | 4,415 | 6 | 375 | 4,144 | 4,525 |
| Total | | | 1,775 | 10,044 | 26 | 1,378 | 24,681 | 26,085 | 33 | 1,582 | 25,980 | 27,595 |

Table 5-2: Scenario 1 – Cost-benefit analysis for Bosnia and Herzegovina (LCPD)

| Code | Plant name | Fuel type | Power MW | Costs | | PV | | | B/C |
|-------|------------|-----------|----------|-------------|----------|--------|--------|--------|------|
| | | | | Investments | O&M | C | B | B-C | |
| | | | | Mil. € | Mil. €/y | Mil. € | Mil. € | Mil. € | |
| 1 | Gacko | L | 300 | 33.4 | 6.7 | 105 | 1,316 | 1,211 | 12.6 |
| 2 | Ugljevik | L | 300 | 107.9 | 12.7 | 243 | 14,463 | 14,220 | 59.5 |
| 3 | Tuzla 3 | L | 110 | | | | | | |
| 4 | Tuzla 4 | L | 200 | 22.0 | 3.5 | 59 | 1,038 | 979 | 17.6 |
| 5 | Tuzla 5 | L | 200 | 17.0 | 2.2 | 41 | 680 | 639 | 16.7 |
| 6 | Tuzla 6 | L | 215 | 46.6 | 2.8 | 76 | 1,453 | 1,377 | 19.0 |
| 7 | Kakanj 5 | L | 110 | 29.4 | 2.1 | 52 | 1,769 | 1,717 | 33.9 |
| 8 | Kakanj 6 | L | 110 | 22.4 | 1.0 | 33 | 842 | 808 | 25.4 |
| 9 | Kakanj 7 | L | 230 | 58.5 | 5.0 | 111 | 4,415 | 4,304 | 39.6 |
| Total | | | 1,775 | 337.2 | 36.0 | 720 | 25,974 | 25,254 | 36 |

Table 5-3: Scenario 2 - Cost-benefit analysis for Bosnia and Herzegovina (IED)

| Code | Plant name | Fuel type | Power MW | Costs | | PV | | | B/C |
|-------|------------|-----------|----------|-------------|----------|--------|--------|--------|------|
| | | | | Investments | O&M | C | B | B-C | |
| | | | | Mil. € | Mil. €/y | Mil. € | Mil. € | Mil. € | |
| 1 | Gacko | L | 300 | 37.3 | 6.7 | 108 | 1,484 | 1,376 | 13.7 |
| 2 | Ugljevik | L | 300 | 118.4 | 12.7 | 254 | 14,643 | 14,390 | 57.8 |
| 3 | Tuzla 3 | L | 110 | | | | | | |
| 4 | Tuzla 4 | L | 200 | 25.0 | 3.5 | 62 | 1,146 | 1,084 | 18.5 |
| 5 | Tuzla 5 | L | 200 | 20.0 | 2.2 | 44 | 772 | 728 | 17.6 |
| 6 | Tuzla 6 | L | 215 | 46.6 | 2.8 | 76 | 1,531 | 1,455 | 20.0 |
| 7 | Kakanj 5 | L | 110 | 36.2 | 2.7 | 65 | 2,097 | 2,031 | 32.1 |
| 8 | Kakanj 6 | L | 110 | 27.7 | 1.4 | 42 | 1,008 | 965 | 23.8 |
| 9 | Kakanj 7 | L | 230 | 63.5 | 6.0 | 127 | 4,525 | 4,398 | 35.6 |
| Total | | | 1,775 | 375 | 38 | 779 | 27,205 | 26,426 | 35 |

The basic parameters of the alternative scenarios that can be taken into consideration (see Chapter 4) for Tuzla 2x200 MW units, which are presented in Table 5-4. According to Scenario 1, 39 million € shall be necessary for the environmental upgrade. However, in alternative solutions 650 million € are required, thus achieving the annual external benefits of 15.3 million € and direct costs savings (fuel and O&M cost) of 20.8 million € per year.

Table 5-4: Basic differences of scenarios 3 and 1 for Bosnia and Herzegovina

| Code | Plant name | Fuel type | Power MW | LCPD | | | | Alternative Scenario | | Difference Alt-LCPD | |
|-------|------------|-----------|----------|---------|---------|-----------|---------|----------------------|-----------|---------------------|----------|
| | | | | Inv-env | OM-env | Ret. Plan | Fuel C. | Investments | Fuel sav. | Ext. Ben. | Fuel+O&M |
| | | | | Mill. € | Mill. € | | Mill. € | Mill. € | % | Mil€/a | Mil€/a |
| 4 | Tuzla 4 | L | 200 | 22 | 3.5 | 2018 | 36 | 330 | 28 | 8.2 | 11.2 |
| 5 | Tuzla 5 | L | 200 | 17 | 2.2 | 2024 | 31 | 320 | 29 | 7.2 | 9.6 |
| Total | | | 400 | 39 | 5.7 | | | 650 | | 15.3 | 20.8 |

5.4. CBA for Croatia

The benefits for avoiding external costs for TPPs in Croatia are presented in Table 5-5, both for the LCPD and the IED. These benefits are obtained according to the methodology and data presented in Chapter 3 for the present state of emission control, reduced by the proportion of the required emission concentrations presented in Chapter 2. However, in case that the existing emissions are lower than the required ELVs for a certain scenario, emissions for that scenario are assumed at their present levels. The benefits are calculated for the period of 2018 to 2030 and discounted to the year 2017.

The cost calculation is based on the data presented in Chapter 4. The investment cost estimate for the environmental upgrade of each TPP unit is presented in Annex 3 (Table A3-3 for Scenario 1 and Table A3-4 for Scenario 2). The annual O&M costs are presented in the same tables alongside the investment costs. The total value of investment costs is up to 228 million € for LCPD and 318 million € for IED, while O&M costs amount up to 16 million € and 18 million € respectively for these scenarios.

The results of the CBA are presented in Table 5-6 for Scenario 1 and in Table 5-7 for Scenario 2.

The results show that in all cases, benefits significantly exceed the costs of environmental upgrading. The average B/C ratio is about 16 for the LCPD scenario and 15 for the IED scenario.

Table 5-5: Pollution control benefits for Croatia

| Code | Plant name | Fuel type | Power MW | Energy GWh/a | PV for LCPD | | | | PV for IED | | | |
|------|----------------|-----------|----------|--------------|-------------------------------------|-----------------|-----------------|-------|-------------------------------------|-----------------|-----------------|-------|
| | | | | | External costs reduction, million € | | | | External costs reduction, million € | | | |
| | | | | | Dust | NO _x | SO ₂ | Total | Dust | NO _x | SO ₂ | Total |
| 1 | TPP Plomin 1 | HC | 125 | 915 | 0 | 0 | 241 | 241 | 0.6 | 171.2 | 544.6 | 716 |
| 2 | TPP Plomin 2 | HC | 210 | 1,631 | 0 | 115 | 0 | 115 | 0.1 | 114.9 | 0.0 | 115 |
| 3 | TPP Rijeka | FO | 320 | 1,725 | 4 | 402 | 2,006 | 2,411 | 5.3 | 566.0 | 2,114.8 | 2,686 |
| 4 | TPP Sisak A | FO | 210 | 1,214 | 3 | 197 | 1,538 | 1,738 | 4.0 | 336.9 | 1631.5 | 1972 |
| 5 | TPP Sisak B | FO | 210 | 1,214 | 3 | 197 | 1,538 | 1,738 | 4.0 | 336.9 | 1631.5 | 1972 |
| 6 | TPP Jertovac 1 | NG | 40 | 47 | 0 | 0 | 0 | 0 | 0.0 | 2.7 | 0.0 | 3 |
| 7 | TPP Jertovac 2 | NG | 40 | 47 | 0 | 0 | 0 | 0 | 0.0 | 2.8 | 0.0 | 3 |
| 8 | CHP Zagreb C | NG | 120 | 469 | 1 | 75 | 333 | 409 | 1.1 | 122.5 | 458.8 | 582 |
| 9 | CHP Zagreb K | NG | 208 | 1,591 | 0 | 0 | 0 | 0 | 0.0 | 0.0 | 0.0 | 0 |
| 10 | CHP Zagreb L | NG | 112 | 866 | 0 | 0 | 0 | 0 | 0.0 | 0.0 | 0.0 | 0 |

| | | | | | | | | | | | | |
|-------|---------------------|----|------|--------|----|-----|-------|-------|-----|-------|-------|-------|
| 11 | CHP Zagreb EL-TO K6 | NG | 11 | 21 | 0 | 4 | 21 | 24 | 0.0 | 3.5 | 36.5 | 40 |
| 12 | CHP Zagreb EL-TO K8 | NG | 30 | 82 | 1 | 5 | 56 | 62 | 0.6 | 5.0 | 94.7 | 100 |
| 13 | CHP Zagreb EL-TO H | NG | 25 | 161 | 0 | 0 | 0 | 0 | 0.0 | 15.2 | 0.0 | 15 |
| 14 | CHP Zagreb EL-TO J | NG | 25 | 161 | 0 | 0 | 0 | 0 | 0.0 | 12.1 | 0.0 | 12 |
| 15 | CHP Osijek A | NG | 46 | 256 | 0 | 0 | 0 | 0 | 0.0 | 18.5 | 0.0 | 18 |
| 16 | CHP Osijek B | NG | 25 | 42 | 0 | 0 | 0 | 0 | 0.0 | 3.0 | 0.0 | 3 |
| 17 | CHP Osijek C | NG | 25 | 21 | 0 | 0 | 0 | 0 | 0.0 | 1.5 | 0.0 | 2 |
| Total | | | 1782 | 10,464 | 11 | 994 | 5,733 | 6,737 | 16 | 1,713 | 6,512 | 8,241 |

Table 5-6: Scenario 1 - Cost-benefit analysis for Croatia (LCPD)

| Code | Plant name | Fuel type | Power MW | Costs | | NPV | | | B/C |
|-------|---------------------|-----------|----------|---------|----------|--------|--------|--------|-----|
| | | | | Invest. | O&M | C | B | B-C | |
| | | | | Mil. € | Mil. €/y | Mil. € | Mil. € | Mil. € | |
| 1 | TPP Plomin 1 | HC | 125 | | | | | | |
| 2 | TPP Plomin 2 | HC | 210 | 20.0 | 1.6 | 37 | 115 | 78 | 3 |
| 3 | TPP Rijeka | FO | 320 | 61.2 | 5.9 | 124 | 2,411 | 2,287 | 19 |
| 4 | TPP Sisak A | FO | 210 | 56.7 | 3.3 | 92 | 1,738 | 1,646 | 19 |
| 5 | TPP Sisak B | FO | 210 | 56.7 | 3.3 | 92 | 1,738 | 1,646 | 19 |
| 6 | TPP Jertovac 1 | NG | 40 | 0.0 | 0.0 | 0 | 0 | 0 | 0 |
| 7 | TPP Jertovac 2 | NG | 40 | 0.0 | 0.0 | 0 | 0 | 0 | 0 |
| 8 | CHP Zagreb C | NG | 120 | 24.5 | 1.3 | 38 | 409 | 371 | 11 |
| 9 | CHP Zagreb K | NG | 208 | 0.0 | 0.0 | 0 | 0 | 0 | 0 |
| 10 | CHP Zagreb L | NG | 112 | 0.0 | 0.0 | 0 | 0 | 0 | 0 |
| 11 | CHP Zagreb EL-TO K6 | NG | 11 | 4.5 | 0.1 | 5 | 24 | 19 | 5 |
| 12 | CHP Zagreb EL-TO K8 | NG | 30 | 4.4 | 0.2 | 7 | 62 | 55 | 9 |
| 13 | CHP Zagreb EL-TO H | NG | 25 | 0.0 | 0.0 | 0 | 0 | 0 | 0 |
| 14 | CHP Zagreb EL-TO J | NG | 25 | 0.0 | 0.0 | 0 | 0 | 0 | 0 |
| 15 | CHP Osijek A | NG | 46 | 0.0 | 0.0 | 0 | 0 | 0 | 0 |
| 16 | CHP Osijek B | NG | 25 | 0.0 | 0.0 | 0 | 0 | 0 | 0 |
| 17 | CHP Osijek C | NG | 25 | 0.0 | 0.0 | 0 | 0 | 0 | 0 |
| Total | | | 1,782 | 228 | 16 | 396 | 6,497 | 6,101 | 16 |

Table 5-7: Scenario 2 – Cost-benefit analysis for Croatia (IED)

| Code | Plant name | Fuel type | Power MW | Costs | | NPV | | | B/C |
|-------|---------------------|-----------|----------|---------|----------|--------|---------|---------|------|
| | | | | Invest. | O&M | C | B | B-C | |
| | | | | Mil. € | Mil. €/y | Mil. € | Mil. € | Mil. € | |
| 1 | TPP Plomin 1 | HC | 125 | | | | | | |
| 2 | TPP Plomin 2 | HC | 210 | 20 | 2 | 41 | 115.0 | 74.2 | 2.8 |
| 3 | TPP Rijeka | FO | 320 | 89 | 6 | 152 | 2,686.2 | 2,534.0 | 17.6 |
| 4 | TPP Sisak A | FO | 210 | 76 | 4 | 116 | 1,972.4 | 1,856.0 | 16.9 |
| 5 | TPP Sisak B | FO | 210 | 76 | 4 | 116 | 1,972.4 | 1,856.0 | 16.9 |
| 6 | TPP Jertovac 1 | NG | 40 | 1 | 0 | 1 | 2.7 | 1.4 | 2.1 |
| 7 | TPP Jertovac 2 | NG | 40 | 1 | 0 | 1 | 2.8 | 1.5 | 2.2 |
| 8 | CHP Zagreb C | NG | 120 | 37 | 2 | 53 | 582.4 | 529.3 | 11.0 |
| 9 | CHP Zagreb K | NG | 208 | 0 | 0 | 0 | 0.0 | 0.0 | 0 |
| 10 | CHP Zagreb L | NG | 112 | 0 | 0 | 0 | 0.0 | 0.0 | 0 |
| 11 | CHP Zagreb EL-TO K6 | NG | 11 | 7 | 0 | 8 | 40.1 | 32.5 | 5.2 |
| 12 | CHP Zagreb EL-TO K8 | NG | 30 | 8 | 0 | 10 | 100.3 | 90.0 | 9.7 |
| 13 | CHP Zagreb EL-TO H | NG | 25 | 1 | 0 | 2 | 15.2 | 13.5 | 8.8 |
| 14 | CHP Zagreb EL-TO J | NG | 25 | 1 | 0 | 2 | 12.1 | 10.4 | 7.0 |
| 15 | CHP Osijek A | NG | 46 | 1 | 0 | 3 | 18.5 | 15.5 | 6.3 |
| 16 | CHP Osijek B | NG | 25 | 1 | 0 | 1 | 3.0 | 2.0 | 3.1 |
| 17 | CHP Osijek C | NG | 25 | 1 | 0 | 1 | 1.5 | 0.7 | 1.8 |
| Total | | | 1,782 | 318 | 18 | 508 | 7,524.9 | 7,017.1 | 15 |

The basic parameters of the alternative scenarios that can be taken into consideration (see Chapter 4) are presented in Table 5-8 for units fired by fuel oil and natural gas, with a total capacity of 411 MW. According to Scenario 1, 70 million € shall be necessary for the environmental upgrade. However, in alternative solutions 546 million € is required, thus achieving the annual external benefits of 6.13 million € and direct costs savings (fuel and O&M cost) of 15.8 million per year.

Table 5-8: Basic differences of Scenarios 3 and 1 for Croatia

| Code | Plant name | Fuel type | Power MW | LCPD | | | | Altern. Scenario | | Difference Alt-LCPD | |
|-------|---------------------|-----------|----------|---------|---------|-----------|-------------|------------------|-----------|---------------------|----------|
| | | | | Inv-env | OM-env | Ret. Plan | Fuel Costs. | Investments | Fuel sav. | Ext. Ben. | Fuel+O&M |
| | | | | Mill. € | Mill. € | | Mill. € | | % | | |
| 3 | TPP Rijeka | FO | 320 | 61.2 | 5.91 | 2028 | 11 | 416 | 11 | 3.4 | 14.8 |
| 11 | CHP Zagreb EL-TO K6 | NG | 11 | 4.5 | 0.06 | 2020 | 4 | 16 | 45 | 0.8 | 2.4 |
| 12 | CHP Zagreb EL-TO K8 | NG | 30 | 4.4 | 0.24 | 2035 | 6 | 43 | 15 | 0.7 | 2 |
| 13 | CHP Zagreb EL-TO H | NG | 25 | 0 | 0 | 2025 | 22 | 36 | 33 | 0.6 | 7.9 |
| 14 | CHP Zagreb EL-TO J | NG | 25 | 0 | 0 | 2025 | 22 | 35 | 33 | 0.6 | 7.9 |
| Total | | | 411 | 70.1 | 6.2 | | 65 | 546 | | 6.1 | 15.8 |

5.5. CBA for FYR Macedonia

The benefits for avoiding external costs for TPP in FYR Macedonia are presented in Table 5-9, both for the LCPD and the IED. These benefits are obtained according to the methodology and data presented in Chapter 3 for the present state of emission control, reduced by the proportion of the required emission concentrations presented in Chapter 2. However, in case that the existing emissions are lower than the required ELVs for a certain scenario, emissions for that scenario are assumed at their present levels. The benefits are calculated for the period of 2018 to 2030 and discounted to the year 2017.

Table 5-9: Pollution control benefits for FYR Macedonia

| Code | Plant name | Fuel type | Power MW | Energy GWh/a | PV for LCPD | | | | PV for IED | | | |
|-------|------------|-----------|----------|--------------|-------------------------------------|-----------------|-----------------|-------|-------------------------------------|-----------------|-----------------|--------|
| | | | | | External costs reduction, million € | | | | External costs reduction, million € | | | |
| | | | | | Dust | NO _x | SO ₂ | Total | Dust | NO _x | SO ₂ | Total |
| 1 | Bitola 1 | L | 233 | 1,387 | 13 | 271 | 2,926 | 3,210 | 14 | 271 | 3,059 | 3,345 |
| 2 | Bitola 2 | L | 233 | 1,387 | 24 | 276 | 2,328 | 2,627 | 25 | 276 | 2,461 | 2,761 |
| 3 | Bitola 3 | L | 233 | 1,387 | 24 | 276 | 2,328 | 2,627 | 25 | 276 | 2,461 | 2,761 |
| 4 | Oslomej | L | 125 | 604 | 8 | 0 | 878 | 886 | 10 | 31 | 1,127 | 1,168 |
| 5 | Negotino | FO | 210 | 17 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 6 | Skopje CHP | NG | 227 | 1394 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 7 | Kogel CHP | NG | 30 | 185 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Total | | | 1,034 | 4,783 | 68 | 0 | 8,459 | 9,350 | 73 | 854 | 9,108 | 10,035 |

The cost calculation is based on the data presented in Chapter 4. The investment cost estimate for the environmental upgrade of each TPP unit is presented in Annex 3 (Table A3-5 for Scenario 1 and Table A3-6 for Scenario 2). The annual O&M costs are presented in the same tables alongside the investment costs. The total investment costs are calculated to be 230 million € for LCPD and 272 million € for IED, while O&M costs amount up to 12 million € and 17 million € respectively for these scenarios. The results of the CBA are presented in Table 5-10 for Scenario 1 and in Table 5-11 for Scenario 2.

Table 5-10: Scenario 1 – Cost-benefit analysis for FYR Macedonia (LCPD)

| Code | Plant name | Fuel type | Pow. MW | Costs | | PV | | | B/C |
|-------|------------|-----------|---------|---------|-----------|---------|---------|---------|-----|
| | | | | Invest. | O&M | C | B | B-C | |
| | | | | Mill. € | Mill. €/y | Mill. € | Mill. € | Mill. € | |
| 1 | Bitola 1 | L | 233 | 63.9 | 3.7 | 103 | 3,210 | 3,107 | 31 |
| 2 | Bitola 2 | L | 233 | 63.9 | 3.4 | 100 | 2,627 | 2,527 | 26 |
| 3 | Bitola 3 | L | 233 | 63.9 | 3.4 | 100 | 2,627 | 2,527 | 26 |
| 4 | Oslomej | L | 125 | 38.0 | 1.5 | 54 | 886 | 832 | 16 |
| 5 | Negotino | FO | 210 | 0 | 0 | 0 | 0 | 0 | 0 |
| 6 | Skopje CHP | NG | 227 | 0 | 0 | 0 | 0 | 0 | 0 |
| 7 | Kogel CHP | NG | 30 | 0 | 0 | 0 | 0 | 0 | 0 |
| Total | | | 1,034 | 230 | 12 | 358 | 9,350 | 8,992 | 26 |

Table 5-11: Scenario 2 - Cost-benefit analysis for FYR Macedonia (IED)

| Code | Plant name | Fuel type | Power MW | Costs | | PV | | | B/C |
|-------|------------|-----------|----------|---------|----------|--------|--------|--------|------|
| | | | | Invest. | O&M | C | B | B-C | |
| | | | | Mil. € | Mil. €/y | Mil. € | Mil. € | Mil. € | |
| 1 | Bitola 1 | L | 233 | 78 | 5 | 135 | 3,345 | 3,209 | 24.7 |
| 2 | Bitola 2 | L | 233 | 78 | 5 | 133 | 2,761 | 2,629 | 20.8 |
| 3 | Bitola 3 | L | 233 | 78 | 5 | 133 | 2,761 | 2,629 | 20.8 |
| 4 | Oslomej | L | 125 | 37 | 2 | 55 | 1,168 | 1,112 | 21.1 |
| 5 | Negotino | FO | 210 | 0 | 0 | 0 | 0 | 0 | |
| Total | | | 1,034 | 272 | 17 | 456 | 10,035 | 9,579 | 22 |

The results show that in all cases, benefits significantly exceed the costs of environmental upgrading. The average B/C ratio is about 26 for the LCPD scenario and 22 for the IED scenario. The basic parameters of the alternative scenarios that can be taken into consideration (see Chapter 4) for lignite-fired TPP units, with a total capacity of 824 MW, are presented in Table 5-12. According to Scenario 1, 230 million € shall be necessary for the environmental upgrading. However, in alternative solutions 1,369 million € is required, thus achieving the annual external benefits of nearly 33 million € and direct costs savings (fuel and O&M cost) of 69 million € per year.

Table 5-12: Basic differences of Scenarios 3 and 1 for FYR Macedonia

| Code | Plant name | Fuel type | Power MW | LCPD | | | | Alternative Scenario | | Difference Alt-LCPD | |
|-------|------------|-----------|----------|---------|---------|-----------|---------|----------------------|-----------|---------------------|----------|
| | | | | Inv-env | OM-env | Ret. Plan | Fuel C. | Investments | Fuel sav. | Ext. Ben. | Fuel+O&M |
| | | | | Mill. € | Mill. € | | Mill. € | Mill. € | % | Mil€/a | Mil€/a |
| 1 | Bitola 1 | L | 233 | 63.9 | 3.7 | 2027 | 40 | 385 | 25 | 8.5 | 19.4 |
| 2 | Bitola 2 | L | 233 | 63.9 | 3.4 | 2028 | 40 | 385 | 25 | 8.5 | 19.4 |
| 3 | Bitola 3 | L | 233 | 63.9 | 3.4 | 2029 | 40 | 385 | 25 | 8.5 | 19.4 |
| 4 | Oslomej | L | 125 | 38.0 | 1.5 | 2027 | 17 | 214 | 18 | 7.4 | 10.7 |
| Total | | | 824 | 229.7 | 12.1 | | 137 | 1,369 | | 32.9 | 68.9 |

5.6. CBA for Moldova

The TPPs in Moldova fulfil the requirements of the LCPD. Therefore, the only scenario that needs to be analysed is Scenario 2 (compliance with the IED). The benefits of the IED Scenario, based on the avoidance of the external costs, are presented in Table 5-13. These benefits are obtained according to the methodology and data presented in Chapter 3 for the present state of pollutant emission control, reduced by the proportion of the required emission concentrations as presented in Chapter 2. However, in case that the existing emissions are lower than the required ELVs for a certain scenario, the emissions for that scenario is assumed at their present levels. The benefits are calculated for the period of 2018 to 2030 and discounted to the year 2017.

The cost calculation is based on the data presented in Chapter 4. The investment cost estimate for the environmental upgrade of each TPP unit is presented in Annex 3 (Table A3-7). The annual O&M costs are presented in the same tables alongside the investment costs. The value of total investment costs for the IED Scenario is 1.92 million €, while O&M costs amount up to 0.4 million € per year. The results of the CBA are presented in Table 5-14. The results show that in all cases, benefits are considerably higher than the costs of environmental upgrading. The average B/C ratio is 3.24 for the IED scenario.

Table 5-13: Pollution control benefits for Moldova

| Code | Plant name | Fuel type | Power MW | Energy GWh/a | PV for IED | | | |
|-------|-------------|-----------|----------|--------------|-------------------------------------|-----------------|-----------------|-------|
| | | | | | External costs reduction, million € | | | |
| | | | | | Dust | NO _x | SO ₂ | Total |
| 1 | CET-1, No 1 | NG | 12 | 59 | 0.0 | 0.0 | 0.0 | 0.0 |
| 2 | CET-1, No 2 | NG | 12 | 59 | 0.0 | 0.3 | 0.0 | 0.3 |
| 3 | CET-1, No 3 | NG | 10 | 49 | 0.0 | 0.3 | 0.0 | 0.3 |
| 4 | CET-1, No 4 | NG | 27 | 132 | 0.0 | 0.0 | 0.0 | 0.0 |
| 5 | CET-1, No 5 | NG | 5 | 24 | 0.0 | 0.0 | 0.0 | 0.0 |
| 6 | CET-2, No 1 | NG | 80 | 398 | 0.0 | 5.3 | 0.0 | 5.3 |
| 7 | CET-2, No 2 | NG | 80 | 371 | 0.0 | 7.3 | 0.0 | 7.3 |
| 8 | CET-2, No 3 | NG | 80 | 371 | 0.0 | 5.6 | 0.0 | 5.6 |
| Total | | | 330 | 1580 | 0.0 | 22.7 | 0.0 | 22.7 |

Table 5-14: Scenario 2 - Cost-benefit analysis for Moldova (IED)

| Code | Plant name | Fuel type | Power MW | Costs | | PV | | | B/C |
|-------|-------------|-----------|----------|---------|----------|--------|--------|--------|-----|
| | | | | Invest. | O&M | C | B | B-C | |
| | | | | Mil. € | Mil. €/y | Mil. € | Mil. € | Mil. € | |
| 1 | CET-1, No 1 | NG | 12 | | | | | | |
| 2 | CET-1, No 2 | NG | 12 | 0.1 | 0.0 | 0.2 | 0.3 | 0.1 | 1.3 |
| 3 | CET-1, No 3 | NG | 10 | 0.1 | 0.0 | 0.2 | 0.3 | 0.1 | 1.5 |
| 4 | CET-1, No 4 | NG | | | | | | | |
| 5 | CET-1, No 5 | NG | 5 | | | | | | |
| 6 | CET-2, No 1 | NG | 80 | 0.6 | 0.1 | 1.9 | 5.3 | 3.4 | 2.8 |
| 7 | CET-2, No 2 | NG | 80 | 0.6 | 0.1 | 1.8 | 7.3 | 5.5 | 4.1 |
| 8 | CET-2, No 3 | NG | 80 | 0.6 | 0.1 | 1.8 | 5.6 | 3.8 | 3.1 |
| Total | | | 306 | 2 | 0 | 6 | 19 | 13 | 3.2 |

5.7. CBA for Montenegro

The benefits of avoiding the external costs for the only TPP in Montenegro are presented in Table 5-15, both for the LCPD and the IED. These benefits are obtained according to the methodology and data presented in Chapter 3 for the present state of emission control, reduced by the proportion of the required emission concentrations as presented in Chapter 2. The benefits are calculated for the period of 2018 to 2030 and discounted to the year 2017.

The cost calculation is based on the data presented in Chapter 4. The investment cost estimate for the environmental upgrade of each TPP unit is presented in Annex 3 (Table A3-8 for Scenario 1 and Table A3-9 for Scenario 2). The annual O&M costs are presented in the same tables alongside the investment costs. The value of total investment costs is 47 million € for the LCPD and 51 million € for the IED, while O&M costs amount up to 4 million € for each scenario.

The results of the CBA are presented in Table 5-16 for Scenario 1 and in Table 5-17 for Scenario 2. The results show that in all cases, benefits are considerably higher than the costs of environmental upgrading. The average B/C ratio is approximately 51 for the LCPD scenario and 50 for the IED scenario.

Table 5-15: Pollution control benefits for Montenegro

| Code | Plant name | Fuel type | Power MW | Energy GWh/a | PV for LCPD | | | | PV for IED | | | |
|-------|------------|-----------|----------|--------------|-------------------------------------|-----------------|-----------------|-------|-------------------------------------|-----------------|-----------------|-------|
| | | | | | External costs reduction, million € | | | | External costs reduction, million € | | | |
| | | | | | Dust | NO _x | SO ₂ | Total | Dust | NO _x | SO ₂ | Total |
| 1 | Pljevlja | L | 219 | 1,489 | 0 | 220 | 4,505 | 4,725 | 1 | 220 | 4,666 | 4,886 |
| Total | | | 219 | 1,489 | 0 | 220 | 4,505 | 4,725 | 1 | 220 | 4,666 | 4,886 |

Table 5-16: Scenario 1 – Cost-benefit analysis for Montenegro (LCPD)

| Code | Plant name | Fuel type | Pow. MW | Costs | | NPV | | | B/C |
|------|------------|-----------|---------|---------|----------|--------|--------|--------|-----|
| | | | | Invest. | O&M | C | B | B-C | |
| | | | | Mil. € | Mil. €/y | Mil. € | Mil. € | Mil. € | |
| 1 | Pljevlja | L | 219 | 46.9 | 4.3 | 93 | 4,725 | 4,632 | 51 |
| | Total | | 219 | 47 | 4 | 93 | 4,725 | 4,632 | 51 |

Table 5-17: Scenario 2 – Cost-benefit analysis for Montenegro (IED)

| Code | Plant name | Fuel type | Power MW | Costs | | NPV | | | B/C |
|------|------------|-----------|----------|---------|----------|--------|--------|--------|-----|
| | | | | Invest. | O&M | C | B | B-C | |
| | | | | Mil. € | Mil. €/y | Mil. € | Mil. € | Mil. € | |
| 1 | Pljevlja | Lignite | 219 | 51 | 4.3 | 96.8 | 4,886 | 4,789 | 50 |
| | Total | | 219 | 51 | 4.3 | 96.8 | 4,886 | 4,789 | 50 |

The basic parameters of the alternative scenarios that can be taken into consideration (see Chapter 4) for lignite-fired TPP units, with the capacity of 219 MW, are presented in Table 5-18. According to Scenario 1, approximately 47 million € shall be necessary for the environmental upgrade. By the use of alternative solutions, 370 million € is required, thus achieving the annual external benefits of nearly 8.9 million € and direct savings (fuel and O&M cost) of 13 million € per year.

Table 5-18: Basic differences of Scenarios 3 and 1 for Montenegro

| Code | Plant Name | Fuel Type | Power MW | LCPD | | | | Alternative Scenario | | Difference Alt-LCPD | |
|------|------------|-----------|----------|---------|--------|-----------|---------|----------------------|-----------|---------------------|----------|
| | | | | Inv-env | OM-env | Ret. Plan | Fuel C. | Investments | Fuel sav. | Ext. Ben. | Fuel+O&M |
| | | | | Mil. € | Mil. € | | | | | | |
| 1 | Pljevlja | L | 219 | 46.9 | 4.3 | 2,025 | 48 | 370 | 24 | 8.9 | 12.9 |
| | Total | | 219 | 46.9 | 4.3 | 2,025 | 48 | 370 | 24 | 8.9 | 12.9 |

5.8. CBA for Serbia

The benefits of avoiding of external costs for the TPPs in Serbia are presented in Table 5-19, both for the LCPD and the IED. These benefits are obtained according to the methodology and data presented in Chapter 3 for the present state of emission control, reduced by the proportion of the required emission concentrations as presented in Chapter 2. However, in case that the existing emissions are lower than the required ELVs for a certain scenario, the emission for that scenario is assumed as it is at present. The benefits are calculated for the period of 2018 to 2030 and discounted to the year 2017.

The cost calculation is based on the data presented in Chapter 4. The investment cost estimate for the environmental upgrade of each TPP unit is presented in Annex 3 (Table A3-10 for Scenario 1 and Table A3-11 for Scenario 2). The annual O&M costs are presented in the same tables alongside the investment costs. The value of total investment costs is 640 million € for LCPD and 711 million for IED €, while annual O&M costs amount up to 68 million € and 66 million € respectively for these scenarios.

The results of the CBA are presented in Table 5-20 for Scenario 1 and in Table 5-21 for Scenario 2. The results show that in all cases, benefits significantly exceed the costs of environmental upgrading. The average B/C ratio is approximately 27 for the LCPD Scenario and 28 for the IED Scenario.

Table 5-19: Pollution control benefits for Serbia

| Code | Plant Name | Fuel Type | Power MW | Energy GWh/a | PV for LCPD | | | | PV for IED | | | |
|-------|-----------------|-----------|----------|--------------|-------------------------------------|-----------------|-----------------|--------|-------------------------------------|-----------------|-----------------|--------|
| | | | | | External Costs Reduction, Million € | | | | External Costs Reduction, Million € | | | |
| | | | | | Dust | NO _x | SO ₂ | Total | Dust | NO _x | SO ₂ | Total |
| 1 | Nikola Tesla A1 | L | 210 | 1,231 | 5.7 | 136.2 | 1,037.1 | 1,179 | 7.5 | 136.2 | 1,167 | 1,311 |
| 2 | Nikola Tesla A2 | L | 210 | 1,198 | 5.5 | 132.5 | 1,008.9 | 1,147 | 7.3 | 132.5 | 1,135 | 1,275 |
| 3 | Nikola Tesla A3 | L | 305 | 1,923 | 8.6 | 207.1 | 1,576.5 | 1,792 | 11.4 | 207.1 | 1,774 | 1,992 |
| 4 | Nikola Tesla A4 | L | 309 | 1,989 | 0.0 | 252.0 | 1,649.9 | 1,902 | 1.7 | 252.0 | 1,852 | 2,106 |
| 5 | Nikola Tesla A5 | L | 309 | 1,999 | 0.0 | 251.0 | 1,643.0 | 1,894 | 1.7 | 251.0 | 1,844 | 2,097 |
| 6 | Nikola Tesla A6 | L | 309 | 1,987 | 0.0 | 249.4 | 1,632.9 | 1,882 | 1.7 | 249.4 | 1,833 | 2,084 |
| 7 | Nikola Tesla B1 | L | 620 | 4,151 | 0.0 | 554.1 | 3,410.1 | 3,964 | 4.0 | 554.1 | 3,816 | 4,374 |
| 8 | Nikola Tesla B2 | L | 620 | 4,004 | 0.0 | 539.6 | 3,320.4 | 3,860 | 3.9 | 539.6 | 3,715 | 4,259 |
| 9 | Kolubara 1 | L | 32 | 175 | 14.4 | 0.0 | 70.6 | 85 | 15.4 | 29.2 | 292 | 337 |
| 10 | Kolubara 2 | L | 32 | 116 | 9.5 | 0.0 | 37.6 | 47 | 10.1 | 0.0 | 180 | 190 |
| 11 | Kolubara 3 | L | 64 | 135 | 11.1 | 0.0 | 43.7 | 55 | 11.8 | 0.0 | 209 | 221 |
| 12 | Kolubara 4 | L | 32 | 0 | 0.0 | 0.0 | 0.0 | 0 | 0.0 | 0.0 | 0 | 0 |
| 13 | Kolubara 5 | L | 110 | 626 | 0.0 | 0.0 | 530.5 | 530 | 1.3 | 82.5 | 786 | 870 |
| 14 | Morava | L | 125 | 566 | 30.7 | 0.0 | 932.4 | 963 | 33.0 | 112.8 | 1,139 | 1,285 |
| 15 | Kostolac A1 | L | 100 | 560 | 10.0 | 0.0 | 1,679.2 | 1,689 | 12.5 | 71.9 | 2,009 | 2,094 |
| 16 | Kostolac A2 | L | 210 | 1,196 | 3.8 | 129.2 | 3,778.8 | 3,912 | 5.6 | 129.2 | 3,909 | 4,044 |
| 17 | Kostolac B1 | L | 348 | 1,937 | 51.4 | 393.2 | 5,910.1 | 6,355 | 54.2 | 393.2 | 6,110 | 6,557 |
| 18 | Kostolac B2 | L | 348 | 1,895 | 19.6 | 329.9 | 5,201.6 | 5,551 | 22.3 | 329.9 | 5396 | 5,748 |
| 19 | Novi Sad 1 | NG | 135 | 189 | 0.0 | 52.4 | 9.0 | 61 | 0.0 | 68.9 | 9 | 78 |
| 20 | Novi Sad 2 | NG | 110 | 175 | 0.0 | 48.5 | 8.3 | 57 | 0.0 | 63.8 | 8 | 72 |
| 21 | Zrenjanin | NG | 110 | 66 | 0.0 | 20.0 | 3.4 | 23 | 0.0 | 26.4 | 3 | 30 |
| 22 | Sr. Mitrovica 1 | NG | 32 | 123 | 0.0 | 7.7 | 0.0 | 8 | 0.0 | 20.8 | 0 | 21 |
| Total | | | 4,679 | 26,240 | 170 | 3,303 | 33,484 | 36,957 | 205 | 3,651 | 37,188 | 41,044 |

Table 5-20: Scenario 1 - Cost-benefit analysis for Serbia (LCPD)

| Code | Plant name | Fuel type | Pow. MW | Costs | | NPV | | | B/C |
|-------|-----------------|-----------|---------|---------|----------|--------|--------|--------|------|
| | | | | Invest. | O&M | C | B | B-C | |
| | | | | Mil. € | Mil. €/y | Mil. € | Mil. € | Mil. € | |
| 1 | Nikola Tesla A1 | L | 210 | 21.7 | 3.0 | 53 | 1179 | 1,126 | 22.2 |
| 2 | Nikola Tesla A2 | L | 210 | 23.0 | 2.9 | 54 | 1147 | 1,093 | 21.4 |
| 3 | Nikola Tesla A3 | L | 305 | 55.2 | 4.6 | 104 | 1792 | 1,688 | 17.2 |
| 4 | Nikola Tesla A4 | L | 309 | 45.6 | 4.8 | 97 | 1902 | 1,805 | 19.7 |
| 5 | Nikola Tesla A5 | L | 309 | 45.6 | 4.8 | 97 | 1894 | 1,797 | 19.6 |
| 6 | Nikola Tesla A6 | L | 309 | 45.6 | 4.8 | 96 | 1882 | 1,786 | 19.5 |
| 7 | Nikola Tesla B1 | L | 620 | 87.0 | 10.0 | 194 | 3964 | 3,771 | 20.5 |
| 8 | Nikola Tesla B2 | L | 620 | 77.6 | 9.7 | 180 | 3860 | 3,679 | 21.4 |
| 9 | Kolubara 1 | L | 32 | | | | | | |
| 10 | Kolubara 2 | L | 32 | | | | | | |
| 11 | Kolubara 3 | L | 64 | 8.2 | 0.3 | 12 | 55 | 43 | 4.7 |
| 12 | Kolubara 4 | L | 32 | | | | | | |
| 13 | Kolubara 5 | L | 110 | 8.6 | 1.5 | 24 | 530 | 506 | 21.9 |
| 14 | Morava | L | 125 | 17.0 | 1.5 | 33 | 963 | 930 | 28.8 |
| 15 | Kostolac A1 | L | 100 | 47.5 | 1.5 | 63 | 1689 | 1,626 | 26.7 |
| 16 | Kostolac A2 | L | 210 | 9.6 | 3.9 | 51 | 3912 | 3,861 | 77.0 |
| 17 | Kostolac B1 | L | 348 | 70.8 | 7.7 | 152 | 6355 | 6,203 | 41.7 |
| 18 | Kostolac B2 | L | 348 | 65.8 | 7.1 | 142 | 5551 | 5,409 | 39.2 |
| 19 | Novi Sad 1 | NG | 135 | 4.0 | 0.1 | 5 | 61 | 56 | 11.4 |
| 20 | Novi Sad 2 | NG | 110 | 3.3 | 0.1 | 5 | 57 | 52 | 12.4 |
| 21 | Zrenjanin | NG | 110 | 3.3 | 0.0 | 4 | 23 | 20 | 6.2 |
| 22 | Sr. Mitrovica 1 | NG | 32 | 1.0 | 0.1 | 2 | 8 | 6 | 4.3 |
| Total | | | 4,679 | 640 | 68 | 1,368 | 3,6825 | 35,458 | 27 |

Table 5-21: Scenario 2 –Cost-benefit analysis for Serbia (IED)

| Code | Plant name | Fuel type | Power MW | Costs | | NPV | | | B/C |
|------|-----------------|-----------|----------|---------|----------|--------|--------|--------|------|
| | | | | Invest. | O&M | C | B | B-C | |
| | | | | Mil. € | Mil. €/y | Mil. € | Mil. € | Mil. € | |
| 1 | Nikola Tesla A1 | L | 210 | 24.9 | 3 | 56 | 1,311 | 1,254 | 23.3 |
| 2 | Nikola Tesla A2 | L | 210 | 24.7 | 3 | 55 | 1,275 | 1,220 | 23.1 |
| 3 | Nikola Tesla A3 | L | 305 | 59.2 | 5 | 108 | 1,992 | 1,884 | 18.4 |
| 4 | Nikola Tesla A4 | L | 309 | 49.6 | 5 | 101 | 2,106 | 2,005 | 21.0 |
| 5 | Nikola Tesla A5 | L | 309 | 49.6 | 5 | 101 | 2,097 | 1,996 | 20.8 |
| 6 | Nikola Tesla A6 | L | 309 | 49.6 | 5 | 100 | 2,084 | 1,984 | 20.8 |

| | | | | | | | | | |
|-------|-----------------|----|-------|------|----|-------|--------|--------|------|
| 7 | Nikola Tesla B1 | L | 620 | 94.0 | 10 | 201 | 4,374 | 4,173 | 21.8 |
| 8 | Nikola Tesla B2 | L | 620 | 84.6 | 10 | 187 | 4,259 | 4,071 | 22.7 |
| 9 | Kolubara 1 | L | 32 | | | | | | |
| 10 | Kolubara 2 | L | 32 | | | | | | |
| 11 | Kolubara 3 | L | 64 | 11.4 | 0 | 15 | 259 | 245 | 17.8 |
| 12 | Kolubara 4 | L | 32 | | | | | | |
| 13 | Kolubara 5 | L | 110 | 12.1 | 2 | 29 | 870 | 841 | 30.4 |
| 14 | Morava | L | 125 | 22.4 | 1 | 36 | 1,285 | 1,249 | 36.2 |
| 15 | Kostolac A1 | L | 100 | 54.8 | 2 | 74 | 2,094 | 2,019 | 28.3 |
| 16 | Kostolac A2 | L | 210 | 10.1 | 4 | 51 | 4,044 | 3,993 | 78.9 |
| 17 | Kostolac B1 | L | 348 | 75.8 | 5 | 131 | 6,557 | 6,426 | 50.2 |
| 18 | Kostolac B2 | L | 348 | 70.6 | 7 | 147 | 5,748 | 5,601 | 39.2 |
| 19 | Novi Sad 1 | NG | 135 | 5.9 | 0 | 9 | 78 | 69 | 8.8 |
| 20 | Novi Sad 2 | NG | 110 | 4.8 | 0 | 8 | 72 | 65 | 9.6 |
| 21 | Zrenjanin | NG | 110 | 4.8 | 0 | 6 | 30 | 24 | 5.1 |
| 22 | Sr. Mitrovica 1 | NG | 32 | 1.8 | 0 | 3 | 21 | 18 | 8.1 |
| Total | | | 4,679 | 711 | 69 | 1,448 | 40,706 | 39,258 | 28 |

The basic parameters of the alternative scenarios that can be taken into consideration (see Chapter 4) for lignite-fired TPP units (with a total capacity of 594 MW) and gas-fired units (with a total capacity of 245 MW) are presented in Table 5-22. According to Scenario 1, approximately 69 million € shall be necessary for the environmental upgrade. However, in alternative solutions 1,273 million € is required, thus achieving the annual external benefits of about 36 million € and direct costs savings (fuel and O&M cost) of 77 million € per year.

Table 5-22: Basic differences of Scenarios 3 and 1 for Serbia

| Code | Plant Name | Fuel Type | Power MW | LCPD | | | Alternative Scenario | | | Difference Alt-LCPD | |
|-------|-----------------|-----------|----------|---------|---------|-----------|----------------------|------------|-----------|---------------------|----------|
| | | | | Inv-env | OM-env | Ret. Plan | Fuel C. | Investment | Fuel sav. | Ext. Ben. | Fuel+O&M |
| | | | | Mill. € | Mill. € | | Mill. € | Mill. € | % | Mil€/a | Mil€/a |
| 1 | Nikola Tesla A1 | L | 210 | 21.7 | 3.0 | 2020 | 21 | 366 | 24 | 7.1 | 5.8 |
| 2 | Nikola Tesla A2 | L | 210 | 23 | 2.9 | 2022 | 20 | 366 | 24 | 6.9 | 5.6 |
| 11 | Kolubara 3 | L | 64 | 8.2 | 0.3 | 2018 | 3 | 109 | 43 | 8.5 | 10 |
| 13 | Kolubara 5 | L | 110 | 8.6 | 1.5 | 2019 | 12 | 187 | 24 | 10.1 | 13.3 |
| 19 | Novi Sad 1 | NG | 135 | 4 | 0.3 | 2027 | 47 | 135 | 43 | 1.8 | 22.1 |
| 20 | Novi Sad 2 | NG | 110 | 3.3 | 0.2 | 2027 | 44 | 110 | 43 | 1.6 | 20.5 |
| Total | | | 839 | 68.8 | 8.1 | | 147 | 1273 | | 36.0 | 77.3 |

5.9. CBA for Ukraine

The benefits for the avoidance of external costs for the TPPs in Ukraine are presented in Table 5-23, both for the LCPD and the IED. These benefits are obtained according to the methodology and data presented in Chapter 3 for the present state of emission control, reduced by the proportion of the required emission concentrations as presented in Chapter 2. However, in case that the existing emissions are lower than the required ELVs for a certain scenario, the pollutant emission for that scenario is assumed as it is at present. The benefits are calculated for the period of 2018 to 2030 and discounted to the year 2017.

The cost calculation is based on the data presented in Chapter 4. The investment cost estimate for the environmental upgrade of each TPP unit is presented in Annex 3 (Table A3-12 for Scenario 1 and Table A3-13 for Scenario 2). The annual O&M costs are presented in the same tables alongside the investment costs. The value of total investment costs is 5,115 million € for LCPD and 6,033 million € for IED, while annual O&M

costs amount to 302 million € and 323 million € respectively for these scenarios. The results of benefit-cost calculation are presented in Table 5-24 for Scenario 1 and in Table 5-25 for Scenario 2. The results show that in all cases, benefits significantly exceed the costs of environmental upgrading. The average B/C ratio is approximately 13 for the LCPD Scenario and 12 for the IED Scenario.

Table 5-23: Pollution control benefits for Ukraine

| Code | Plant name | Fuel type | Power MW | Energy GWh/a | PV for LCPD | | | | PV for IED | | | |
|------|-------------------|-----------|----------|--------------|-------------------------------------|-----------------|-----------------|-------|-------------------------------------|-----------------|-----------------|-------|
| | | | | | External costs reduction, million € | | | | External costs reduction, million € | | | |
| | | | | | Dust | NO _x | SO ₂ | Total | Dust | NO _x | SO ₂ | Total |
| 1 | Prydniprovskya 7 | HC | 150 | 439 | 27 | 76 | 380 | 483 | 29 | 127 | 474 | 629 |
| 2 | Prydniprovskya 8 | HC | 150 | 682 | 40 | 123 | 627 | 791 | 44 | 198 | 766 | 1008 |
| 3 | Prydniprovskya 9 | HC | 150 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 4 | Prydniprovskya 10 | HC | 150 | 590 | 30 | 95 | 475 | 599 | 33 | 160 | 596 | 788 |
| 5 | Prydniprovskya 11 | HC | 310 | 1,186 | 78 | 324 | 1,126 | 1,527 | 79 | 324 | 1,202 | 1,606 |
| 6 | Prydniprovskya 12 | HC | 285 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 7 | Prydniprovskya 13 | HC | 285 | 774 | 60 | 230 | 730 | 1,020 | 61 | 230 | 782 | 1,074 |
| 8 | Prydniprovskya 14 | HC | 285 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 9 | Kryvorizka 1 | HC | 282 | 1,106 | 82 | 331 | 1,164 | 1,578 | 84 | 331 | 1,236 | 1,651 |
| 10 | Kryvorizka 2 | HC | 282 | 1,382 | 91 | 415 | 1,429 | 1,935 | 93 | 415 | 1,516 | 2,024 |
| 11 | Kryvorizka 3 | HC | 282 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 12 | Kryvorizka 4 | HC | 282 | 1,221 | 15 | 378 | 1,228 | 1,622 | 17 | 378 | 1,304 | 1,700 |
| 13 | Kryvorizka 5 | HC | 282 | 1,221 | 98 | 397 | 1,314 | 1,810 | 100 | 397 | 1,392 | 1,889 |
| 14 | Kryvorizka 6 | HC | 282 | 714 | 60 | 252 | 800 | 1,112 | 61 | 252 | 846 | 1,159 |
| 15 | Kryvorizka 7 | HC | 282 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 16 | Kryvorizka 8 | HC | 282 | 1,014 | 74 | 358 | 1,127 | 1,559 | 75 | 358 | 1,192 | 1,626 |
| 17 | Kryvorizka 9 | HC | 282 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 18 | Kryvorizka 10 | HC | 282 | 1,198 | 93 | 424 | 1,333 | 1,850 | 95 | 424 | 1,411 | 1,930 |
| 19 | Zaporiska 1 | HC | 325 | 1,048 | 55 | 373 | 1,217 | 1,645 | 57 | 373 | 1,288 | 1,718 |
| 20 | Zaporiska 2 | HC | 300 | 1,277 | 58 | 435 | 1,527 | 2,020 | 60 | 435 | 1,613 | 2,108 |
| 21 | Zaporiska 3 | HC | 300 | 1,301 | 58 | 441 | 1,621 | 2,121 | 61 | 441 | 1,709 | 2,211 |
| 22 | Zaporiska 4 | HC | 300 | 1,205 | 54 | 445 | 1,440 | 1,939 | 56 | 445 | 1,522 | 2,023 |
| 23 | Zaporiska 5 | NG | 800 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 24 | Zaporiska 6 | NG | 800 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 25 | Zaporiska 7 | NG | 800 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 26 | Starobeshivska 4 | HC | 175 | 715 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 27 | Starobeshivska 5 | HC | 175 | 715 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 28 | Starobeshivska 6 | HC | 175 | 715 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 29 | Starobeshivska 7 | HC | 175 | 715 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 30 | Starobeshivska 8 | HC | 175 | 715 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 31 | Starobeshivska 9 | HC | 175 | 715 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 32 | Starobeshivska 10 | HC | 175 | 715 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 33 | Starobeshivska 11 | HC | 175 | 715 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 34 | Starobeshivska 12 | HC | 175 | 715 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 35 | Starobeshivska 13 | HC | 175 | 715 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 36 | Slovianska 7 | HC | 800 | 3,269 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 37 | Burshtynska 1 | HC | 195 | 915 | 62 | 89 | 1,150 | 1,300 | 63 | 89 | 1,208 | 1,360 |
| 38 | Burshtynska 2 | HC | 185 | 397 | 29 | 42 | 542 | 613 | 29 | 42 | 570 | 642 |
| 39 | Burshtynska 3 | HC | 185 | 662 | 54 | 66 | 920 | 1,041 | 56 | 66 | 967 | 1,089 |
| 40 | Burshtynska 4 | HC | 195 | 884 | 70 | 91 | 1,246 | 1,407 | 72 | 91 | 1,308 | 1,471 |
| 41 | Burshtynska 5 | HC | 195 | 465 | 35 | 46 | 692 | 774 | 36 | 46 | 725 | 808 |
| 42 | Burshtynska 6 | HC | 185 | 986 | 70 | 92 | 1,384 | 1,546 | 72 | 92 | 1,453 | 1,617 |
| 43 | Burshtynska 7 | HC | 185 | 508 | 37 | 54 | 767 | 858 | 38 | 54 | 802 | 895 |
| 44 | Burshtynska 8 | HC | 195 | 806 | 33 | 81 | 1,241 | 1,355 | 34 | 81 | 1,296 | 1,412 |
| 45 | Burshtynska 9 | HC | 195 | 961 | 0 | 104 | 1,288 | 1,392 | 2 | 104 | 1,354 | 1,460 |
| 46 | Burshtynska 10 | HC | 195 | 930 | 0 | 103 | 1,272 | 1,375 | 2 | 103 | 1,336 | 1,441 |
| 47 | Burshtynska 11 | HC | 195 | 992 | 0 | 79 | 1,308 | 1,387 | 2 | 79 | 1,375 | 1,456 |
| 48 | Burshtynska 12 | HC | 195 | 667 | 8 | 56 | 901 | 964 | 9 | 56 | 947 | 1,012 |
| 49 | Dobrotvirska 5 | HC | 100 | 402 | 15 | 21 | 495 | 532 | 17 | 70 | 693 | 780 |
| 50 | Dobrotvirska 6 | HC | 100 | 402 | 15 | 21 | 495 | 532 | 17 | 70 | 693 | 780 |
| 51 | Dobrotvirska 7 | HC | 150 | 786 | 55 | 40 | 1,185 | 1,280 | 59 | 126 | 1,355 | 1,541 |
| 52 | Dobrotvirska 8 | HC | 150 | 568 | 41 | 29 | 870 | 940 | 43 | 93 | 995 | 1,132 |
| 53 | Ladyzhinska 1 | HC | 300 | 874 | 55 | 245 | 807 | 1,107 | 56 | 245 | 865 | 1,166 |

| Code | Plant name | Fuel type | Power MW | Energy GWh/a | PV for LCPD | | | | PV for IED | | | |
|-------|--------------------|-----------|----------|--------------|-------------------------------------|-----------------|-----------------|---------|-------------------------------------|-----------------|-----------------|---------|
| | | | | | External costs reduction, million € | | | | External costs reduction, million € | | | |
| | | | | | Dust | NO _x | SO ₂ | Total | Dust | NO _x | SO ₂ | Total |
| 54 | Ladyzhinska 2 | HC | 300 | 1,092 | 21 | 305 | 1,045 | 1,371 | 23 | 305 | 1,117 | 1,445 |
| 55 | Ladyzhinska 3 | HC | 300 | 1,262 | 23 | 354 | 1,261 | 1,639 | 25 | 354 | 1,345 | 1,724 |
| 56 | Ladyzhinska 4 | HC | 300 | 752 | 47 | 209 | 712 | 968 | 48 | 209 | 762 | 1,019 |
| 57 | Ladyzhinska 5 | HC | 300 | 582 | 46 | 162 | 578 | 786 | 47 | 162 | 617 | 826 |
| 58 | Ladyzhinska 6 | HC | 300 | 558 | 53 | 156 | 546 | 756 | 54 | 156 | 583 | 794 |
| 59 | Trypilska 1 | HC | 300 | 1,250 | 78 | 183 | 147 | 408 | 80 | 183 | 234 | 497 |
| 60 | Trypilska 2 | HC | 300 | 1,250 | 108 | 284 | 276 | 668 | 110 | 284 | 363 | 757 |
| 61 | Trypilska 3 | HC | 300 | 1,250 | 102 | 187 | 152 | 441 | 104 | 187 | 239 | 531 |
| 62 | Trypilska 4 | HC | 300 | 1,250 | 99 | 184 | 148 | 431 | 101 | 184 | 236 | 521 |
| 63 | Trypilska 5 | NG | 300 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 64 | Trypilska 6 | NG | 300 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 65 | Zmiivska 1 | HC | 175 | 548 | 119 | 52 | 512 | 683 | 121 | 117 | 560 | 798 |
| 66 | Zmiivska 2 | HC | 175 | 548 | 120 | 52 | 490 | 662 | 122 | 117 | 539 | 779 |
| 67 | Zmiivska 3 | HC | 175 | 548 | 115 | 48 | 484 | 647 | 118 | 112 | 539 | 768 |
| 68 | Zmiivska 4 | HC | 175 | 548 | 112 | 45 | 481 | 638 | 115 | 109 | 535 | 758 |
| 69 | Zmiivska 5 | HC | 175 | 548 | 107 | 38 | 502 | 647 | 110 | 101 | 559 | 770 |
| 70 | Zmiivska 6 | HC | 175 | 548 | 103 | 26 | 441 | 571 | 106 | 90 | 495 | 691 |
| 71 | Zmiivska 7 | HC | 275 | 793 | 120 | 345 | 1,005 | 1,470 | 121 | 345 | 1,066 | 1,532 |
| 72 | Zmiivska 8 | HC | 325 | 937 | 12 | 492 | 1,534 | 2,039 | 14 | 492 | 1,597 | 2,103 |
| 73 | Zmiivska 9 | HC | 275 | 793 | 114 | 272 | 895 | 1,281 | 115 | 272 | 950 | 1,337 |
| 74 | Zmiivska 10 | HC | 275 | 793 | 114 | 276 | 840 | 1,230 | 116 | 276 | 896 | 1,288 |
| 75 | Vuglegirska 1 | HC | 300 | 1,359 | 27 | 379 | 2,011 | 2,416 | 29 | 379 | 2,105 | 2,512 |
| 76 | Vuglegirska 2 | HC | 300 | 1,359 | 27 | 378 | 2,007 | 2,411 | 29 | 378 | 2,101 | 2,508 |
| 77 | Vuglegirska 3 | HC | 300 | 1,359 | 27 | 380 | 2,018 | 2,425 | 29 | 380 | 2,113 | 2,522 |
| 78 | Vuglegirska 4 | HC | 300 | 1,359 | 27 | 380 | 2,016 | 2,423 | 29 | 380 | 2,111 | 2,519 |
| 79 | Vuglegirska 5 | NG | 800 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 80 | Vuglegirska 6 | NG | 800 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 81 | Vuglegirska 7 | NG | 800 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 82 | Zuevvskaia 1 | HC | 325 | 1,606 | 13 | 717 | 2,574 | 3,303 | 16 | 717 | 2,684 | 3,416 |
| 83 | Zuevvskaia 2 | HC | 320 | 1,660 | 14 | 718 | 2,634 | 3,366 | 17 | 718 | 2,746 | 3,481 |
| 84 | Zuevvskaia 3 | HC | 300 | 1,606 | 27 | 610 | 2,397 | 3,034 | 30 | 610 | 2,506 | 3,146 |
| 85 | Zuevvskaia 4 | HC | 325 | 1,740 | 0 | 693 | 2,659 | 3,353 | 3 | 693 | 2,780 | 3,476 |
| 86 | Kurakhovskaya 3 | HC | 200 | 1,005 | 173 | 135 | 1,612 | 1,920 | 175 | 135 | 1,686 | 1,996 |
| 87 | Kurakhovskaya 4 | HC | 210 | 1,003 | 175 | 138 | 1,663 | 1,977 | 177 | 138 | 1,738 | 2,053 |
| 88 | Kurakhovskaya 5 | HC | 222 | 969 | 157 | 125 | 1,654 | 1,935 | 159 | 125 | 1,725 | 2,009 |
| 89 | Kurakhovskaya 6 | HC | 210 | 640 | 159 | 78 | 1,089 | 1,325 | 160 | 78 | 1,137 | 1,376 |
| 90 | Kurakhovskaya 7 | HC | 225 | 982 | 110 | 127 | 1,524 | 1,761 | 112 | 127 | 1,596 | 1,835 |
| 91 | Kurakhovskaya 8 | HC | 210 | 674 | 99 | 84 | 1,122 | 1,305 | 101 | 84 | 1,171 | 1,356 |
| 92 | Kurakhovskaya 9 | HC | 221 | 1,019 | 122 | 117 | 1,679 | 1,918 | 124 | 117 | 1,754 | 1,995 |
| 93 | Luganskaya 9 | HC | 200 | 1,070 | 164 | 286 | 1,302 | 1,752 | 166 | 286 | 1,382 | 1,834 |
| 94 | Luganskaya 10 | HC | 200 | 642 | 29 | 155 | 759 | 943 | 30 | 155 | 808 | 993 |
| 95 | Luganskaya 11 | HC | 200 | 988 | 140 | 279 | 1,164 | 1,583 | 142 | 279 | 1,237 | 1,657 |
| 96 | Luganskaya 12 | HC | 175 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 97 | Luganskaya 13 | HC | 175 | 951 | 130 | 166 | 1,205 | 1,500 | 134 | 275 | 1,300 | 1,710 |
| 98 | Luganskaya 14 | HC | 200 | 1,070 | 166 | 339 | 1,385 | 1,890 | 168 | 339 | 1,465 | 1,972 |
| 99 | Luganskaya 15 | HC | 200 | 988 | 143 | 295 | 1,331 | 1,769 | 145 | 295 | 1,406 | 1,846 |
| 100 | Bilotserkivska CHP | NG | 120 | 494 | 0 | 0 | 0 | 0 | 0 | 24 | 0 | 24 |
| 101 | Darnytska CHP 5,10 | NG | 50 | 212 | 0 | 0 | 0 | 0 | 0 | 11 | 0 | 11 |
| 102 | Darnytska CHP 6-9 | HC | 110 | 453 | 30 | 87 | 229 | 346 | 32 | 142 | 380 | 555 |
| 103 | Kaluska CHP 1, 2 | HC | 100 | 412 | 30 | 0 | 232 | 262 | 32 | 0 | 378 | 410 |
| 104 | Kaluska CHP 3, 4 | NG | 100 | 425 | 0 | 6 | 0 | 6 | 0 | 26 | 0 | 26 |
| 105 | Kyivska CHP-5 | NG | 540 | 1,147 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 106 | Kyivska CHP-5 | FO | 540 | 1,147 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 107 | Kyivska CHP-6 | NG | 500 | 1,062 | 11 | 92 | 981 | 1,084 | 11 | 115 | 981 | 1,107 |
| 108 | Kyivska CHP-6 | FO | 500 | 1,062 | 6 | 64 | 678 | 748 | 8 | 109 | 735 | 851 |
| 109 | Kramatorska CHP | HC | 120 | 494 | 12 | 0 | 474 | 486 | 14 | 42 | 619 | 675 |
| 110 | Myronivska 4 | HC | 60 | 247 | 2 | 0 | 183 | 185 | 3 | 31 | 312 | 347 |
| 111 | Myronivska 9 | HC | 115 | 616 | 3 | 17 | 437 | 457 | 7 | 93 | 632 | 732 |
| 112 | Odeska CHP-2 | NG | 68 | 289 | 0 | 51 | 0 | 51 | 0 | 65 | 0 | 65 |
| 113 | Sevastopolska CHP | NG | 55 | 234 | 0 | 0 | 0 | 0 | 0 | 7 | 0 | 7 |
| 114 | Simferopilska CHP | NG | 278 | 1,181 | 0 | 0 | 0 | 0 | 0 | 7 | 0 | 7 |
| 115 | Kharkivska CHP-2 | HC | 74 | 314 | 49 | 8 | 511 | 567 | 50 | 45 | 650 | 745 |
| Total | | | 29,368 | 88,669 | 5,238 | 16,928 | 85,682 | 107,849 | 5,395 | 18,254 | 92,265 | 115,914 |

Table 5-24 Scenario 1 – Cost-benefit analysis for Ukraine (LCPD)

| Code | Plant name | Fuel type | Power MW | Costs | | NPV | | | B/C |
|------|-------------------|-----------|----------|---------|----------|--------|--------|--------|------|
| | | | | Invest. | O&M | C | B | B-C | |
| | | | | Mil. € | Mil. €/y | Mil. € | Mil. € | Mil. € | |
| 1 | Prydniprovsk 7 | HC | 150 | 34.6 | 1.6 | 51.1 | 596 | 545.2 | 11.7 |
| 2 | Prydniprovsk 8 | HC | 150 | 34.6 | 2.5 | 60.7 | 959 | 898.4 | 15.8 |
| 3 | Prydniprovsk 9 | HC | 150 | 32.4 | 0.0 | 32.4 | | | |
| 4 | Prydniprovsk 10 | HC | 150 | 34.3 | 2.1 | 56.3 | 746 | 689.4 | 13.2 |
| 5 | Prydniprovsk 11 | HC | 310 | 69.0 | 4.3 | 114.2 | 1527 | 1413.0 | 13.4 |
| 6 | Prydniprovsk 12 | HC | 285 | 65.4 | 0.0 | 65.4 | | | |
| 7 | Prydniprovsk 13 | HC | 285 | 68.3 | 2.7 | 97.5 | 1020 | 922.5 | 10.5 |
| 8 | Prydniprovsk 14 | HC | 285 | 68.3 | 0.0 | 68.3 | | | |
| 9 | Kryvorizka 1 | HC | 282 | 62.2 | 4.0 | 105.2 | 1578 | 1472.5 | 15.0 |
| 10 | Kryvorizka 2 | HC | 282 | 64.7 | 5.1 | 118.7 | 1935 | 1816.4 | 16.3 |
| 11 | Kryvorizka 3 | HC | 282 | 57.9 | 0.0 | 57.9 | | | |
| 12 | Kryvorizka 4 | HC | 282 | 59.1 | 4.5 | 106.6 | 1622 | 1515.3 | 15.2 |
| 13 | Kryvorizka 5 | HC | 282 | 63.1 | 4.5 | 111.1 | 1810 | 1698.4 | 16.3 |
| 14 | Kryvorizka 6 | HC | 282 | 65.1 | 2.6 | 93.3 | 1112 | 1018.4 | 11.9 |
| 15 | Kryvorizka 7 | HC | 282 | 64.4 | 0.0 | 64.4 | | | |
| 16 | Kryvorizka 8 | HC | 282 | 64.4 | 3.8 | 104.4 | 1559 | 1454.4 | 14.9 |
| 17 | Kryvorizka 9 | HC | 282 | 63.3 | 0.0 | 63.3 | | | |
| 18 | Kryvorizka 10 | HC | 282 | 64.4 | 4.4 | 111.7 | 1850 | 1738.7 | 16.6 |
| 19 | Zaporiska 1 | HC | 325 | 65.9 | 3.9 | 107.2 | 1645 | 1538.0 | 15.3 |
| 20 | Zaporiska 2 | HC | 300 | 70.0 | 4.8 | 120.7 | 2020 | 1898.9 | 16.7 |
| 21 | Zaporiska 3 | HC | 300 | 66.2 | 4.9 | 118.4 | 2121 | 2002.4 | 17.9 |
| 22 | Zaporiska 4 | HC | 300 | 70.4 | 4.5 | 118.2 | 1939 | 1820.8 | 16.4 |
| 23 | Zaporiska 5 | NG | 800 | 24.0 | 0.0 | 24.0 | | | |
| 24 | Zaporiska 6 | NG | 800 | 25.0 | 0.0 | 25.0 | | | |
| 25 | Zaporiska 7 | NG | 800 | 25.6 | 0.0 | 25.6 | | | |
| 26 | Starobeshivska 4 | HC | 175 | 25.0 | 1.7 | 42.9 | | | |
| 27 | Starobeshivska 5 | HC | 175 | 40.0 | 2.2 | 63.2 | | | |
| 28 | Starobeshivska 6 | HC | 175 | 37.9 | 2.2 | 61.1 | | | |
| 29 | Starobeshivska 7 | HC | 175 | 37.2 | 2.2 | 60.4 | | | |
| 30 | Starobeshivska 8 | HC | 175 | 37.2 | 2.2 | 60.4 | | | |
| 31 | Starobeshivska 9 | HC | 175 | 38.2 | 2.2 | 61.4 | | | |
| 32 | Starobeshivska 10 | HC | 175 | 39.2 | 2.2 | 62.4 | | | |
| 33 | Starobeshivska 11 | HC | 175 | 39.2 | 2.2 | 62.4 | | | |
| 34 | Starobeshivska 12 | HC | 175 | 33.8 | 2.2 | 57.0 | | | |
| 35 | Starobeshivska 13 | HC | 175 | 31.6 | 2.2 | 54.8 | | | |
| 36 | Slovianska 7 | HC | 800 | 169.3 | 10.0 | 275.3 | | | |
| 37 | Burshtynska 1 | HC | 195 | 35.6 | 3.8 | 76.0 | 1300 | 1224.3 | 17.1 |
| 38 | Burshtynska 2 | HC | 185 | 33.7 | 1.6 | 51.2 | 613 | 561.9 | 12.0 |
| 39 | Burshtynska 3 | HC | 185 | 33.6 | 2.7 | 62.6 | 1041 | 978.0 | 16.6 |
| 40 | Burshtynska 4 | HC | 195 | 35.5 | 3.7 | 74.6 | 1407 | 1332.2 | 18.9 |
| 41 | Burshtynska 5 | HC | 195 | 38.6 | 1.9 | 59.3 | 774 | 714.7 | 13.0 |
| 42 | Burshtynska 6 | HC | 185 | 33.6 | 4.1 | 76.7 | 1546 | 1469.5 | 20.2 |
| 43 | Burshtynska 7 | HC | 185 | 33.7 | 2.2 | 56.6 | 858 | 801.3 | 15.2 |
| 44 | Burshtynska 8 | HC | 195 | 39.0 | 3.4 | 75.6 | 1355 | 1279.5 | 17.9 |
| 45 | Burshtynska 9 | HC | 195 | 35.9 | 4.0 | 78.4 | 1392 | 1313.4 | 17.8 |
| 46 | Burshtynska 10 | HC | 195 | 35.9 | 3.9 | 77.2 | 1375 | 1297.9 | 17.8 |
| 47 | Burshtynska 11 | HC | 195 | 35.1 | 4.0 | 77.5 | 1387 | 1309.5 | 17.9 |
| 48 | Burshtynska 12 | HC | 195 | 32.4 | 2.7 | 61.1 | 964 | 903.3 | 15.8 |
| 49 | Dobrotvirsk 5 | HC | 100 | 14.8 | 1.4 | 29.9 | 633 | 602.7 | 21.2 |
| 50 | Dobrotvirsk 6 | HC | 100 | 14.8 | 1.4 | 29.9 | 633 | 602.7 | 21.2 |
| 51 | Dobrotvirsk 7 | HC | 150 | 35.4 | 2.8 | 65.7 | 1484 | 1418.5 | 22.6 |
| 52 | Dobrotvirsk 8 | HC | 150 | 37.3 | 2.1 | 59.2 | 1090 | 1030.7 | 18.4 |
| 53 | Ladyzhinska 1 | HC | 300 | 65.1 | 3.1 | 98.1 | 1107 | 1008.5 | 11.3 |
| 54 | Ladyzhinska 2 | HC | 300 | 63.9 | 3.9 | 105.4 | 1371 | 1265.3 | 13.0 |
| 55 | Ladyzhinska 3 | HC | 300 | 63.9 | 4.6 | 112.3 | 1639 | 1526.3 | 14.6 |
| 56 | Ladyzhinska 4 | HC | 300 | 63.9 | 2.7 | 92.4 | 968 | 875.7 | 10.5 |
| 57 | Ladyzhinska 5 | HC | 300 | 63.9 | 2.1 | 86.2 | 786 | 700.2 | 9.1 |
| 58 | Ladyzhinska 6 | HC | 300 | 63.9 | 2.0 | 85.2 | 756 | 670.8 | 8.9 |
| 59 | Trypilska 1 | HC | 300 | 63.8 | 4.3 | 109.1 | 408 | 298.6 | 3.7 |
| 60 | Trypilska 2 | HC | 300 | 63.0 | 4.3 | 108.5 | 668 | 559.1 | 6.2 |
| 61 | Trypilska 3 | HC | 300 | 63.8 | 4.3 | 109.0 | 441 | 332.1 | 4.0 |

| Code | Plant name | Fuel type | Power MW | Costs | | NPV | | | B/C |
|-------|--------------------|-----------|----------|---------|----------|--------|---------|---------|------|
| | | | | Invest. | O&M | C | B | B-C | |
| | | | | Mil. € | Mil. €/y | Mil. € | Mil. € | Mil. € | |
| 62 | Trypilska 4 | HC | 300 | 63.8 | 4.3 | 109.1 | 431 | 322.2 | 4.0 |
| 63 | Trypilska 5 | NG | 300 | 22.3 | 0.0 | 22.3 | | | |
| 64 | Trypilska 6 | NG | 300 | 22.3 | 0.0 | 22.3 | | | |
| 65 | Zmiivska 1 | HC | 175 | 53.1 | 1.9 | 73.3 | 755 | 682.2 | 10.3 |
| 66 | Zmiivska 2 | HC | 175 | 43.6 | 1.9 | 63.7 | 737 | 673.0 | 11.6 |
| 67 | Zmiivska 3 | HC | 175 | 55.1 | 1.9 | 75.3 | 726 | 651.0 | 9.7 |
| 68 | Zmiivska 4 | HC | 175 | 43.6 | 1.9 | 63.7 | 716 | 652.3 | 11.2 |
| 69 | Zmiivska 5 | HC | 175 | 55.1 | 1.9 | 75.4 | 728 | 652.9 | 9.7 |
| 70 | Zmiivska 6 | HC | 175 | 43.6 | 1.9 | 63.4 | 649 | 585.5 | 10.2 |
| 71 | Zmiivska 7 | HC | 275 | 67.0 | 2.9 | 98.0 | 1470 | 1372.0 | 15.0 |
| 72 | Zmiivska 8 | HC | 325 | 75.2 | 3.8 | 115.8 | 2039 | 1923.2 | 17.6 |
| 73 | Zmiivska 9 | HC | 275 | 65.0 | 2.9 | 95.9 | 1281 | 1185.3 | 13.4 |
| 74 | Zmiivska 10 | HC | 275 | 66.5 | 2.9 | 96.8 | 1230 | 1133.4 | 12.7 |
| 75 | Vuglegirska 1 | HC | 300 | 68.6 | 5.3 | 125.2 | 2416 | 2290.9 | 19.3 |
| 76 | Vuglegirska 2 | HC | 300 | 68.6 | 5.3 | 125.2 | 2411 | 2286.2 | 19.3 |
| 77 | Vuglegirska 3 | HC | 300 | 68.6 | 5.3 | 125.2 | 2425 | 2299.8 | 19.4 |
| 78 | Vuglegirska 4 | HC | 300 | 68.6 | 5.3 | 125.2 | 2423 | 2297.4 | 19.3 |
| 79 | Vuglegirska 5 | NG | 800 | 65.0 | 0.0 | 65.0 | | | |
| 80 | Vuglegirska 6 | NG | 800 | 65.0 | 0.0 | 65.0 | | | |
| 81 | Vuglegirska 7 | NG | 800 | 65.0 | 0.0 | 65.0 | | | |
| 82 | Zuevskaya 1 | HC | 325 | 75.3 | 6.5 | 144.0 | 3303 | 3159.2 | 22.9 |
| 83 | Zuevskaya 2 | HC | 320 | 75.0 | 6.7 | 145.9 | 3366 | 3219.9 | 23.1 |
| 84 | Zuevskaya 3 | HC | 300 | 72.0 | 6.3 | 139.4 | 3034 | 2894.7 | 21.8 |
| 85 | Zuevskaya 4 | HC | 325 | 63.5 | 6.9 | 136.6 | 3353 | 3216.3 | 24.5 |
| 86 | Kurakhovskaya 3 | HC | 200 | 40.2 | 4.4 | 86.5 | 1920 | 1833.5 | 22.2 |
| 87 | Kurakhovskaya 4 | HC | 210 | 39.1 | 4.4 | 85.7 | 1977 | 1890.9 | 23.1 |
| 88 | Kurakhovskaya 5 | HC | 222 | 42.8 | 4.3 | 88.1 | 1935 | 1847.4 | 22.0 |
| 89 | Kurakhovskaya 6 | HC | 210 | 36.2 | 2.8 | 65.5 | 1325 | 1260.0 | 20.2 |
| 90 | Kurakhovskaya 7 | HC | 225 | 43.1 | 4.2 | 87.9 | 1761 | 1673.0 | 20.0 |
| 91 | Kurakhovskaya 8 | HC | 210 | 30.9 | 2.9 | 62.0 | 1305 | 1242.8 | 21.0 |
| 92 | Kurakhovskaya 9 | HC | 221 | 42.2 | 4.4 | 88.7 | 1918 | 1829.5 | 21.6 |
| 93 | Luganskaya 9 | HC | 200 | 48.5 | 3.9 | 90.2 | 1752 | 1661.4 | 19.4 |
| 94 | Luganskaya 10 | HC | 200 | 40.3 | 2.3 | 65.1 | 943 | 877.8 | 14.5 |
| 95 | Luganskaya 11 | HC | 200 | 51.6 | 3.6 | 89.9 | 1583 | 1492.6 | 17.6 |
| 96 | Luganskaya 12 | HC | 175 | 29.3 | 0.0 | 29.3 | | | |
| 97 | Luganskaya 13 | HC | 175 | 43.3 | 3.2 | 76.9 | 1500 | 1422.9 | 19.5 |
| 98 | Luganskaya 14 | HC | 200 | 48.6 | 4.0 | 90.9 | 1890 | 1799.5 | 20.8 |
| 99 | Luganskaya 15 | HC | 200 | 50.9 | 3.7 | 90.2 | 1769 | 1678.8 | 19.6 |
| 100 | Bilotserkivska CHP | NG | 120 | | | | | | |
| 101 | Darnytska CHP 5,10 | NG | 50 | | | | | | |
| 102 | Darnytska CHP 6-9 | HC | 110 | 4.5 | 1.3 | 18.6 | 346 | 327.4 | 18.6 |
| 103 | Kaluska CHP 1, 2 | HC | 100 | 11.0 | 1.0 | 21.5 | 262 | 240.0 | 12.2 |
| 104 | Kaluska CHP 3, 4 | NG | 100 | 0.4 | 0.1 | 1.8 | 6 | 4.3 | 3.4 |
| 105 | Kyivska CHP-5 | NG | 540 | 8.5 | 0.7 | 15.8 | | | |
| 106 | Kyivska CHP-5 | FO | 540 | 8.5 | 0.7 | 15.8 | | | |
| 107 | Kyivska CHP-6 | NG | 500 | 8.1 | 0.6 | 14.9 | 36 | 21.6 | 2.5 |
| 108 | Kyivska CHP-6 | FO | 500 | 18.8 | 0.6 | 25.6 | 742 | 716.2 | 29.0 |
| 109 | Kramatorska CHP | HC | 120 | 15.5 | 1.3 | 29.2 | 486 | 457.0 | 16.7 |
| 110 | Myronivska 4 | HC | 60 | 6.3 | 0.6 | 13.1 | 185 | 172.1 | 14.1 |
| 111 | Myronivska 9 | HC | 115 | 12.7 | 1.7 | 30.7 | 457 | 426.7 | 14.9 |
| 112 | Odeska CHP-2 | NG | 68 | 2.2 | 0.2 | 4.0 | 51 | 46.6 | 12.5 |
| 113 | Sevastopolska CHP | NG | 55 | | | | | | |
| 114 | Simferopilska CHP | NG | 278 | | | | | | |
| 115 | Kharkivska CHP-2 | HC | 74 | 12.6 | 1.2 | 25.2 | 567 | 541.5 | 22.5 |
| Total | | | 29,368 | 5,138.5 | 302.1 | 8,351 | 108,243 | 101,448 | 13 |

Table 5-25: Scenario 2 – Cost-benefit analysis for Ukraine (IED)

| Code | Plant name | Fuel type | Power MW | Costs | | NPV | | | B/C |
|------|-------------------|-----------|----------|---------|----------|--------|--------|--------|------|
| | | | | Invest. | O&M | C | B | B-C | |
| | | | | Mil. € | Mil. €/y | Mil. € | Mil. € | Mil. € | |
| 1 | Prydniprovskaya 7 | HC | 150 | 38.4 | 2 | 56 | 629 | 574 | 11.3 |
| 2 | Prydniprovskaya 8 | HC | 150 | 38.4 | 3 | 66 | 1008 | 942 | 15.3 |
| 3 | Prydniprovskaya 9 | HC | 150 | 35.6 | 0 | 36 | | | |

| Code | Plant name | Fuel type | Power MW | Costs | | NPV | | | B/C |
|------|-------------------|-----------|----------|---------|----------|--------|--------|--------|------|
| | | | | Invest. | O&M | C | B | B-C | |
| | | | | Mil. € | Mil. €/y | Mil. € | Mil. € | Mil. € | |
| 4 | Prydniprovskia 10 | HC | 150 | 38.4 | 2 | 61 | 788 | 727 | 12.8 |
| 5 | Prydniprovskia 11 | HC | 310 | 76.8 | 5 | 125 | 1,606 | 1,481 | 12.9 |
| 6 | Prydniprovskia 12 | HC | 285 | 70.4 | 0 | 70 | | | |
| 7 | Prydniprovskia 13 | HC | 285 | 74.0 | 3 | 105 | 1,074 | 969 | 10.2 |
| 8 | Prydniprovskia 14 | HC | 285 | 74.0 | 0 | 74 | | | |
| 9 | Kryvorizka 1 | HC | 282 | 66.6 | 4 | 113 | 1,651 | 1,539 | 14.6 |
| 10 | Kryvorizka 2 | HC | 282 | 69.5 | 5 | 128 | 2,024 | 1,897 | 15.8 |
| 11 | Kryvorizka 3 | HC | 282 | 60.5 | 0 | 61 | | | |
| 12 | Kryvorizka 4 | HC | 282 | 62.8 | 5 | 114 | 1,700 | 1,586 | 14.9 |
| 13 | Kryvorizka 5 | HC | 282 | 67.5 | 5 | 120 | 1,889 | 1,769 | 15.8 |
| 14 | Kryvorizka 6 | HC | 282 | 69.9 | 3 | 101 | 1,159 | 1,058 | 11.5 |
| 15 | Kryvorizka 7 | HC | 282 | 69.1 | 0 | 69 | | | |
| 16 | Kryvorizka 8 | HC | 282 | 69.1 | 4 | 113 | 1,626 | 1,513 | 14.4 |
| 17 | Kryvorizka 9 | HC | 282 | 67.1 | 0 | 67 | | | |
| 18 | Kryvorizka 10 | HC | 282 | 69.1 | 5 | 121 | 1,930 | 1,808 | 15.9 |
| 19 | Zaporiska 1 | HC | 325 | 70.1 | 4 | 115 | 1,718 | 1,602 | 14.9 |
| 20 | Zaporiska 2 | HC | 300 | 74.4 | 5 | 130 | 2,108 | 1,979 | 16.3 |
| 21 | Zaporiska 3 | HC | 300 | 70.3 | 5 | 127 | 2,211 | 2,084 | 17.4 |
| 22 | Zaporiska 4 | HC | 300 | 74.8 | 5 | 127 | 2,023 | 1,895 | 15.9 |
| 23 | Zaporiska 5 | NG | 800 | 24.0 | 0 | 24 | | | |
| 24 | Zaporiska 6 | NG | 800 | 25.0 | 0 | 25 | | | |
| 25 | Zaporiska 7 | NG | 800 | 25.6 | 0 | 26 | | | |
| 26 | Starobeshivska 4 | HC | 175 | 56.5 | 2 | 80 | | | |
| 27 | Starobeshivska 5 | HC | 175 | 68.0 | 2 | 91 | | | |
| 28 | Starobeshivska 6 | HC | 175 | 65.6 | 2 | 89 | | | |
| 29 | Starobeshivska 7 | HC | 175 | 64.9 | 2 | 88 | | | |
| 30 | Starobeshivska 8 | HC | 175 | 64.9 | 2 | 88 | | | |
| 31 | Starobeshivska 9 | HC | 175 | 66.0 | 2 | 89 | | | |
| 32 | Starobeshivska 10 | HC | 175 | 66.5 | 2 | 90 | | | |
| 33 | Starobeshivska 11 | HC | 175 | 66.5 | 2 | 90 | | | |
| 34 | Starobeshivska 12 | HC | 175 | 61.1 | 2 | 84 | | | |
| 35 | Starobeshivska 13 | HC | 175 | 58.7 | 2 | 82 | | | |
| 36 | Slovianska 7 | HC | 800 | 180.8 | 10 | 287 | | | |
| 37 | Burshtynska 1 | HC | 195 | 38.6 | 4 | 79 | 1,360 | 1,281 | 17.2 |
| 38 | Burshtynska 2 | HC | 185 | 36.5 | 2 | 54 | 642 | 588 | 11.9 |
| 39 | Burshtynska 3 | HC | 185 | 36.4 | 3 | 65 | 1,089 | 1,023 | 16.7 |
| 40 | Burshtynska 4 | HC | 195 | 38.5 | 4 | 78 | 1,471 | 1,393 | 19.0 |
| 41 | Burshtynska 5 | HC | 195 | 40.9 | 2 | 62 | 808 | 746 | 13.1 |
| 42 | Burshtynska 6 | HC | 185 | 36.4 | 4 | 80 | 1,617 | 1,538 | 20.3 |
| 43 | Burshtynska 7 | HC | 185 | 36.5 | 2 | 59 | 895 | 835 | 15.1 |
| 44 | Burshtynska 8 | HC | 195 | 42.4 | 3 | 79 | 1,412 | 1,333 | 17.9 |
| 45 | Burshtynska 9 | HC | 195 | 38.9 | 4 | 81 | 1,460 | 1,378 | 17.9 |
| 46 | Burshtynska 10 | HC | 195 | 38.9 | 4 | 80 | 1,441 | 1,361 | 18.0 |
| 47 | Burshtynska 11 | HC | 195 | 38.1 | 4 | 81 | 1,456 | 1,376 | 18.1 |
| 48 | Burshtynska 12 | HC | 195 | 35.1 | 3 | 64 | 1,012 | 948 | 15.9 |
| 49 | Dobrotvirska 5 | HC | 100 | 37.9 | 1 | 53 | 780 | 727 | 14.6 |
| 50 | Dobrotvirska 6 | HC | 100 | 13.7 | 1 | 29 | 780 | 751 | 26.7 |
| 51 | Dobrotvirska 7 | HC | 150 | 56.4 | 3 | 88 | 1,541 | 1,453 | 17.6 |
| 52 | Dobrotvirska 8 | HC | 150 | 21.0 | 2 | 44 | 1,132 | 1,088 | 25.9 |
| 53 | Ladyzhinska 1 | HC | 300 | 71.5 | 3 | 107 | 1,166 | 1,059 | 10.9 |
| 54 | Ladyzhinska 2 | HC | 300 | 70.0 | 4 | 114 | 1,445 | 1,330 | 12.7 |
| 55 | Ladyzhinska 3 | HC | 300 | 70.0 | 5 | 121 | 1,724 | 1,603 | 14.2 |
| 56 | Ladyzhinska 4 | HC | 300 | 70.0 | 3 | 100 | 1,019 | 919 | 10.2 |
| 57 | Ladyzhinska 5 | HC | 300 | 70.0 | 2 | 94 | 826 | 732 | 8.8 |
| 58 | Ladyzhinska 6 | HC | 300 | 70.0 | 2 | 93 | 794 | 701 | 8.6 |
| 59 | Trypilska 1 | HC | 300 | 69.5 | 4 | 110 | 497 | 387 | 4.5 |
| 60 | Trypilska 2 | HC | 300 | 68.3 | 4 | 114 | 757 | 643 | 6.6 |
| 61 | Trypilska 3 | HC | 300 | 69.5 | 4 | 110 | 531 | 420 | 4.8 |
| 62 | Trypilska 4 | HC | 300 | 69.5 | 4 | 110 | 521 | 411 | 4.7 |
| 63 | Trypilska 5 | NG | 300 | 22.3 | 0 | 22 | | | |
| 64 | Trypilska 6 | NG | 300 | 22.3 | 0 | 22 | | | |
| 65 | Zmiivska 1 | HC | 175 | 57.3 | 2 | 77 | 798 | 721 | 10.4 |
| 66 | Zmiivska 2 | HC | 175 | 45.5 | 2 | 65 | 779 | 714 | 12.0 |

| Code | Plant name | Fuel type | Power MW | Costs | | NPV | | | B/C |
|-------|--------------------|-----------|----------|---------|----------|--------|---------|---------|------|
| | | | | Invest. | O&M | C | B | B-C | |
| | | | | Mil. € | Mil. €/y | Mil. € | Mil. € | Mil. € | |
| 67 | Zmiivska 3 | HC | 175 | 59.8 | 2 | 79 | 768 | 689 | 9.7 |
| 68 | Zmiivska 4 | HC | 175 | 45.5 | 2 | 65 | 758 | 693 | 11.7 |
| 69 | Zmiivska 5 | HC | 175 | 59.8 | 2 | 79 | 770 | 691 | 9.7 |
| 70 | Zmiivska 6 | HC | 175 | 45.5 | 2 | 64 | 691 | 627 | 10.9 |
| 71 | Zmiivska 7 | HC | 275 | 72.3 | 3 | 107 | 1,532 | 1,425 | 14.4 |
| 72 | Zmiivska 8 | HC | 325 | 81.2 | 4 | 127 | 2,103 | 1,976 | 16.5 |
| 73 | Zmiivska 9 | HC | 275 | 70.3 | 3 | 104 | 1,337 | 1,234 | 12.9 |
| 74 | Zmiivska 10 | HC | 275 | 72.0 | 3 | 105 | 1,288 | 1,183 | 12.3 |
| 75 | Vuglegirska 1 | HC | 300 | 73.7 | 6 | 133 | 2,512 | 2,379 | 18.9 |
| 76 | Vuglegirska 2 | HC | 300 | 73.7 | 6 | 133 | 2,508 | 2,375 | 18.8 |
| 77 | Vuglegirska 3 | HC | 300 | 73.7 | 6 | 133 | 2,522 | 2,389 | 19.0 |
| 78 | Vuglegirska 4 | HC | 300 | 73.7 | 6 | 133 | 2,519 | 2,386 | 18.9 |
| 79 | Vuglegirska 5 | NG | 800 | 65.0 | 0 | 65 | | | |
| 80 | Vuglegirska 6 | NG | 800 | 65.0 | 0 | 65 | | | |
| 81 | Vuglegirska 7 | NG | 800 | 65.0 | 0 | 65 | | | |
| 82 | Zuevskaya 1 | HC | 325 | 69.6 | 7 | 146 | 3,416 | 3,269 | 23.4 |
| 83 | Zuevskaya 2 | HC | 320 | 69.3 | 7 | 148 | 3,481 | 3,333 | 23.5 |
| 84 | Zuevskaya 3 | HC | 300 | 66.1 | 7 | 140 | 3,146 | 3,006 | 22.5 |
| 85 | Zuevskaya 4 | HC | 325 | 67.3 | 8 | 148 | 3,476 | 3,328 | 23.5 |
| 86 | Kurakhovskaya 3 | HC | 200 | 47.0 | 4 | 93 | 1,996 | 1,903 | 21.4 |
| 87 | Kurakhovskaya 4 | HC | 210 | 43.6 | 4 | 90 | 2,053 | 1,963 | 22.8 |
| 88 | Kurakhovskaya 5 | HC | 222 | 46.8 | 4 | 92 | 2,009 | 1,916 | 21.8 |
| 89 | Kurakhovskaya 6 | HC | 210 | 40.1 | 3 | 69 | 1,376 | 1,306 | 19.8 |
| 90 | Kurakhovskaya 7 | HC | 225 | 48.1 | 4 | 93 | 1,835 | 1,742 | 19.7 |
| 91 | Kurakhovskaya 8 | HC | 210 | 36.0 | 3 | 67 | 1,356 | 1,289 | 20.2 |
| 92 | Kurakhovskaya 9 | HC | 221 | 47.4 | 4 | 94 | 1,995 | 1,901 | 21.2 |
| 93 | Luganskaya 9 | HC | 200 | 50.0 | 4 | 93 | 1,834 | 1,741 | 19.7 |
| 94 | Luganskaya 10 | HC | 200 | 40.3 | 2 | 65 | 993 | 928 | 15.2 |
| 95 | Luganskaya 11 | HC | 200 | 53.9 | 4 | 94 | 1,657 | 1,563 | 17.7 |
| 96 | Luganskaya 12 | HC | 175 | 42.3 | 0 | 42 | | | |
| 97 | Luganskaya 13 | HC | 175 | 44.8 | 4 | 84 | 1,710 | 1,626 | 20.3 |
| 98 | Luganskaya 14 | HC | 200 | 50.1 | 4 | 95 | 1,972 | 1,878 | 20.8 |
| 99 | Luganskaya 15 | HC | 200 | 53.0 | 4 | 94 | 1,846 | 1,752 | 19.6 |
| 100 | Bilotserkivska CHP | NG | 120 | 3.6 | 0 | 7 | 24 | 17 | 3.5 |
| 101 | Darnytska CHP 5,10 | NG | 50 | 4.5 | 0 | 7 | 11 | 4 | 1.6 |
| 102 | Darnytska CHP 6-9 | HC | 110 | 27.1 | 2 | 43 | 555 | 512 | 12.9 |
| 103 | Kaluska CHP 1, 2 | HC | 100 | 15.0 | 1 | 26 | 410 | 384 | 16.1 |
| 104 | Kaluska CHP 3, 4 | NG | 100 | 9.5 | 0 | 14 | 26 | 12 | 1.9 |
| 105 | Kyivska CHP-5 | NG | 540 | 35.0 | 1 | 47 | | | |
| 106 | Kyivska CHP-5 | FO | 540 | 94.0 | 3 | 128 | | | |
| 107 | Kyivska CHP-6 | NG | 500 | 32.6 | 1 | 44 | 59 | 15 | 1.4 |
| 108 | Kyivska CHP-6 | FO | 500 | 87.1 | 4 | 127 | 843 | 717 | 6.7 |
| 109 | Kramatorska CHP | HC | 120 | 23.2 | 1 | 37 | 675 | 638 | 18.3 |
| 110 | Myronivska 4 | HC | 60 | 11.0 | 1 | 21 | 347 | 326 | 16.3 |
| 111 | Myronivska 9 | HC | 115 | 20.8 | 2 | 46 | 732 | 686 | 15.9 |
| 112 | Odeska CHP-2 | NG | 68 | 7.8 | 0 | 11 | 65 | 54 | 6.0 |
| 113 | Sevastopolska CHP | NG | 55 | 1.2 | 0 | 3 | 7 | 4 | 2.6 |
| 114 | Simferopilska CHP | NG | 278 | 1.4 | 0 | 5 | 7 | 2 | 1.4 |
| 115 | Kharkivska CHP-2 | HC | 74 | 14.7 | 1 | 30 | 745 | 715 | 24.8 |
| Total | | | 29,368 | 6,033 | 323 | 9,467 | 114,860 | 107,283 | 12 |

In the case of Scenario 3 for Ukraine, it is proposed that a selection of old and less economic TPP units should be temporarily shut down. However, in case of a possible future increase in power demand, they could be retrofitted and re-introduced in operation (see Chapter 4). The remaining TPPs shall increase their power production and could operate more economically. However, the total amount of emissions will remain as in the LCPD Scenario, and therefore, there will be no change in external costs of power production and there will be no additional benefits to society.

On the other hand, by the temporary shut-down of several TPP units (with a total rated thermal input of ca. 9,400 MW), the investment costs of environmental upgrading shall be spread out over a longer time period, thus achieving cost reduction of financing for the whole power generation system.

5.10. CBA for Kosovo*

The benefits for the avoidance of the external costs for the one TPP in Kosovo* are presented in Table 5-26, both for the LCPD and the IED directives. These benefits are obtained according to the methodology and data presented in Chapter 3 for the present state of pollutant emission control, reduced by the proportion of the required emission concentrations as presented in Chapter 2. However, in case that the existing emissions are lower than the required ELVs for a certain scenario (dust emission), the pollutant emission for that scenario is assumed as it is at present. The benefits are calculated for the period of 2018 to 2030 and discounted to the year 2017.

Table 5-26: Pollution control benefits for Kosovo*

| Code | Plant name | Fuel type | Power MW | Energy GWh/a | PV for LCPD | | | | PV for IED | | | |
|------|------------|-----------|----------|--------------|-------------------------------------|-----------------|-----------------|-------|-------------------------------------|-----------------|-----------------|-------|
| | | | | | External costs reduction, million € | | | | External costs reduction, million € | | | |
| | | | | | Dust | NO _x | SO ₂ | Total | Dust | NO _x | SO ₂ | Total |
| 1 | Kosovo A3 | L | 200 | 590 | 0.0 | 218.5 | 88.4 | 307 | 1.2 | 218.5 | 177.3 | 397 |
| 2 | Kosovo A4 | L | 200 | 590 | 28.3 | 236.5 | 80.9 | 346 | 29.5 | 236.5 | 169.8 | 436 |
| 3 | Kosovo A5 | L | 210 | 606 | 0.0 | 239.5 | 87.7 | 327 | 1.1 | 239.5 | 179.0 | 420 |
| 4 | Kosovo B1 | L | 339 | 1,083 | 22.8 | 424.5 | 147.1 | 594 | 24.7 | 424.5 | 279.0 | 728 |
| 5 | Kosovo B2 | L | 339 | 1,083 | 24.4 | 436.1 | 139.2 | 600 | 26.2 | 436.1 | 271.1 | 733 |
| | Total | | 1,288 | 3,951 | 75 | 1,555 | 543 | 2,174 | 83 | 1,555 | 1,076 | 2,714 |

The cost calculation is based on the data presented in Chapter 4. The investment cost estimate for the environmental upgrade of each TPP unit is presented in Annex 3 (Table A3-14 for Scenario 1 and Table A3-15 for Scenario 2). The annual O&M costs are presented in the same tables alongside the investment costs. According to retirement plans, TPP Kosovo A shall be decommissioned by the end of 2017. Therefore, the total investment costs of the environmental upgrade are calculated for TPP Kosovo B units. The estimated value of total investment costs is 78 million € for LCPD and 84 million € for IED, while the annual O&M costs amount up to 7 million € for each scenario. The results of the CBA are presented in Table 5-27 for Scenario 1 and in Table 5-28 for Scenario 2. The results show that in all cases, benefits significantly exceed the costs of environmental upgrading. The average B/C ratio is approximately 8 for the LCPD and 9 for the IED scenario.

Table 5-27: Scenario 1 – Cost-benefit analysis for Kosovo* (LCPD)

| Code | Plant name | Fuel type | Power MW | Costs | | NPV | | | B/C |
|------|------------|-----------|----------|---------|----------|--------|--------|--------|-----|
| | | | | Invest. | O&M | C | B | B-C | |
| | | | | Mil. € | Mil. €/y | Mil. € | Mil. € | Mil. € | |
| 1 | Kosovo A3 | L | 200 | | | | 0 | | |
| 2 | Kosovo A4 | L | 200 | | | | 0 | | |
| 3 | Kosovo A5 | L | 210 | | | | 0 | | |
| 4 | Kosovo B1 | L | 339 | 39.0 | 3.7 | 78 | 594 | 516 | 7.6 |
| 5 | Kosovo B2 | L | 339 | 39.0 | 3.7 | 78 | 600 | 521 | 7.7 |
| | Total | | 1,288 | 78 | 7.4 | 156 | 1,194 | 1,038 | 8 |

Table 5-28: Scenario 2 – Cost-benefit analysis for Kosovo* (IED)

| Code | Plant name | Fuel type | Power MW | Costs | | NPV | | | B/C |
|------|------------|-----------|----------|---------|-----------|---------|---------|---------|-----|
| | | | | Invest. | O&M | C | B | B-C | |
| | | | | Mill. € | Mill. €/y | Mill. € | Mill. € | Mill. € | |
| 1 | Kosovo A3 | L | 200 | | 0 | | | | |
| 2 | Kosovo A4 | L | 200 | | 0 | | | | |
| 3 | Kosovo A5 | L | 210 | | 0 | | | | |
| 4 | Kosovo B1 | L | 339 | 42.1 | 4 | 81 | 728 | 647 | 9.0 |
| 5 | Kosovo B2 | L | 339 | 42.1 | 4 | 81 | 733 | 652 | 9.0 |
| | Total | | 1,288 | 84 | 8 | 163 | 1,462 | 1299 | 9.0 |

The basic parameters of the alternative scenarios that can be taken into consideration (see Chapter 4) for lignite-fired TPP units, with a total capacity of 678 MW, are presented in Table 5-12. According to Scenario 1, 78 million € shall be necessary for the environmental upgrade. However, in alternative solutions 1,090 million € is required, thus achieving the annual external benefits of nearly 20 million € and direct costs savings (fuel and O&M cost) of 16 million € per year.

Table 5-29: Basic differences of Scenarios 3 and 1 for Kosovo*

| Code | Plant name | Fuel type | Power MW | LCPD | | | Alternative Scenario | | Difference Alt-LCPD | | |
|------|------------|-----------|----------|---------|---------|-----------|----------------------|-------------|---------------------|-----------|----------|
| | | | | Inv-env | OM-env | Ret. Plan | Fuel C. | Investments | Fuel saving | Ext. Ben. | Fuel+O&M |
| | | | | Mill. € | Mill. € | | Mill. € | Mill. € | % | Mill€/a | Mill€/a |
| 4 | Kosovo B1 | L | 339 | 39 | 3.67998 | 2030 | 21 | 545 | 33 | 9.9 | 8.2 |
| 5 | Kosovo B2 | L | 339 | 39 | 3.68764 | 2030 | 21 | 545 | 33 | 9.9 | 8.2 |
| | Total | | 678 | 78 | 7.4 | | 42 | 1,090 | | 19.8 | 16.4 |

6. Conclusions

The Energy Community Contracting Parties, with the exception of Croatia, which has joined the European Union in 2013, do not apply adequate measures to reduce emissions of NO_x, SO₂ and dust from large combustion plants. Taking only TPP in Albania is already capable of meeting the more stringent requirements of the IED and therefore no further environmental upgrade measures are considered to be necessary. The TPPs of Moldova already comply with the LCPD's requirements and with a limited amount of adjustments, it would be possible to implement the requirements of the IED. Other Contracting Parties, namely Bosnia and Herzegovina, FYR Macedonia, Montenegro, Serbia, Ukraine and Kosovo* are facing serious challenges to implement the requirements of the LCPD and the IED.

The estimated external costs of the emissions of SO₂, NO_x and dust arising from electricity and heat production are significant in all Energy Community Contracting Parties. The highest amount of external costs are related to electricity and heat production from coal and lignite, followed by oil, while the lowest external costs are related to power plants fired by natural gas.

In 2014, the average estimated external costs of electricity and heat production related to SO₂, NO_x and dust emissions would be between 0.1-26.7 €cent/kWh. These external costs are not adequately reflected in the energy prices of any of the Contracting Parties. Consequently, decision makers, energy companies as well as consumers do not get the accurate price signals that are necessary to reach decisions about the best ways of using energy resources.

The external costs of electricity and heat production related to SO₂, NO_x and dust emissions were estimated in the Contracting Parties at the following amounts:

| | | | |
|----|------------------------|------|-----------|
| 1. | Montenegro | 26.7 | €cent/kWh |
| 2. | Bosnia and Herzegovina | 22.3 | €cent/kWh |
| 3. | Serbia | 13.5 | €cent/kWh |
| 4. | FYR Macedonia | 10.4 | €cent/kWh |
| 5. | Ukraine | 10.3 | €cent/kWh |
| 6. | Kosovo* | 7.2 | €cent/kWh |
| 7. | Croatia | 6.7 | €cent/kWh |
| 8. | Moldova | 0.4 | €cent/kWh |
| 9. | Albania | 0.1 | €cent/kWh |

With the exception of Albania and Moldova, all Contracting Parties of the Energy Community have a high level of estimated external costs.

The implementation of the requirements of the LCPD and the IED in the Contracting Parties has been analysed according to the best available techniques and based on the experience of the utilities. The analysis was carried out separately for every TPP and CHP unit, as they have different technical parameters, fuel characteristics, emission concentrations as well as load factors. In the case of certain plants, abatement techniques for the reduction of particulate matters and nitrogen oxides were already installed and in a few cases, desulphurisation systems are in operation.

On the basis of the above facts, the following techniques were considered as best available for the environmental upgrade:

- a) BAT for the reduction of dust emissions are: electrostatic precipitator (ESP) and bag filter (BF). The multi cyclones can be used as auxiliary devices to the ESP or BF.
- b) BAT for the reduction of NO_x emission are: primary measures (mainly LNB – Low-NO_x burners designed to control fuel and air mixing at burner in order to create larger and more branched flames, OFA – Over-fire Air and flue gas recirculation) and secondary measures (SNCR – selective non-catalytic reduction and SCR – selective catalytic reduction). Primary measures can be usually applied when the required efficiencies for reduction of NO_x emission are less than 60 % for coal- and oil-fired plants and less than 70 % for gas fired plants.
- c) BAT for the reduction of SO₂ emission are: wet processes (WLS – wet limestone scrubber, WL – wet lime), dry techniques (SD – spray drying, including NID – novel innovation de acidification). For TPP units with very low levels of SO₂ emissions, a dry injection system can be used.

The investment cost requirements have been estimated on the basis of the selected technology for the environmental upgrade systems for each TPP and CHP unit. This has been prepared in accordance with the experience of the Contracting Parties, as well as in accordance to data obtained from international studies on various TPPs in the region. Investment costs have been corrected according to current price levels by use of consumer price index. After the price range has been determined, the local conditions of individual TPPs and CHPs have been taken into account, in order to specify the investment costs for the units which will be in operation after 2017.

Apart from the LCPD and IED scenarios, some alternative scenarios were envisaged. These are:

- The decommissioning of certain old TPP units, for which the remaining operation lifetime is not more than 3 to 5 years. These units would be replaced by modern, more efficient units compliant to the newest

environmental standards.

- Temporary closure of certain old units in order to increase the load factor of the remaining TPP units. This will postpone their environmental upgrade investment costs until when a higher output in production should become necessary once again, with higher load factors. In the meantime the other TPPs shall have more economic operation, due to their larger power production per year.

The valuation of different scenarios of the environmental upgrade systems is performed by the use of the cost-benefit methodology described in Chapter 5.1. Benefits consist of the monetization of avoidance of all external costs, caused by the emission of pollutants with respect to the existing, business as usual (BAU) scenario. Costs mean the investment costs as well as the operation and maintenance (O&M) costs of the environmental upgrade systems. In order to calculate present values over the operation period all benefits and costs are summarized by the use of an appropriate social discount rate of 3%. The reference year for the present values calculation is 2017. The main result of the CBA economic model is the Net Present Value which is defined as a difference of present values of benefits and costs (B-C). In addition the B/C Ratio is evaluated. The CBA is performed for each LCP unit and further ranking is allowed according to the B/C ratio (detailed information can be found in Annex 4). The main criterion for the social viability of the project is that the B/C ratio is greater than 1.

The exceptions of these analyses are the alternative scenarios. For these scenarios, individual feasibility studies are needed, taking into account the remaining fixed assets of the old power plant units, operating conditions of the equipment and technical parameters of new TPP units as well as fuel cost and O&M savings. The alternative scenarios have to be compared with the LCPD scenarios by the use of a financial CBA methodology, which has to be prepared according to the interest of the utilities.

Albania has only one thermal power plant, designed and constructed in accordance with the requirements of the IED and therefore no CBA was necessary.

In order to comply with the requirements of the EU directives, all nine TPP units in Bosnia and Herzegovina need an environmental upgrade. In that respect the largest emitter in the Energy Community is TPP Ugljevik, with average SO₂ emission concentrations of over 16,000 mg/m³. The required investment costs for the LCPD scenario are estimated at a level of 337 million €, while for the IED Scenario 375 million € is estimated. The B/C Ratio for the LCPD Scenario vary from 12-60, with an average of 36, while the IED scenario has the B/C Ratio in the range of 14-58 and the average is 35.

Croatia has 17 TPP units, out of which seven units need environmental upgrading. The B/C Ratio is within the range of 3-19, with an average of 16 for the LCPD scenario for which 228 million € is estimated. The highest investments are needed for TPP Rijeka and TPP Sisak. As far as IED compliance is concerned, the investment

costs for the necessary environmental upgrades are estimated at 318 million € with an average B/C ratio of 15.

FYR Macedonia has four coal-fired TPP units. All of them are in need of environmental upgrading in order to reach compliance with EU standards. An investment need of 230 million € is estimated for the LCPD scenario with an average B/C Ratio of 26 and 272 million € for the IED scenario with an average B/C ratio of 22.

Moldova has eight gas-fired units that are in compliance with the requirements of the LCPD. For the implementation of the IED, an estimated amount of 1.92 million € of investments would be needed, thus achieving a B/C ratio of 3.

Montenegro has one coal-fired TPP, for which an investment of 47 million € for the implementation of the LCPD is estimated. The investment needs for the compliance with IED emission standards are estimated at a level of 51 million €. In both cases, the B/C Ratio is over 50.

Serbia has 22 TPP units, out of which 18 are coal-fired. The largest polluters are TPP Kostolac A2, B1 and B2. The estimated investment costs for the LCPD scenario are about 640 million €, while for the IED Scenario 711 million € is estimated. The average B/C ratio is 27 for the LCPD scenario (ranging from 4 to 77) and 28 for the IED scenario (ranging from 5 to 79).

Ukraine has 101 TPP units and 12 CHP units. For 27 units, there was no sufficient data to perform a proper CBA. The highest polluters are the TPPs fired by hard coal. The costs of implementing the LCPD in the 83 units where a CBA could have been carried out are estimated at 5.139 billion of €, with the B/C ratio ranging from 2.5 to 29, with an average of 13. For implementing the IED, an estimated 6.033 billion € is required and 87 units are included in the environmental upgrade list. The B/C ratio ranges from 1.4 to 27, with an average value of 27.

Kosovo* has five coal-fired TPP units, out of which three should be shut down before the end of 2017. It is estimated that the remaining two units need ca. 78 million € for the implementation of the LCPD scenario (with an expected B/C ratio of 8) and 84 million € for the IED scenario (with an expected B/C ratio of 9).

For reaching compliance with the requirements of the LCPD in the Contracting Parties, investment costs for the environmental upgrade of LCPs with the aim of reducing emissions of SO₂, NO_x and dust are estimated as follows:

| | |
|------------------------|-----------------|
| Albania | 0 million € |
| Bosnia and Herzegovina | 337.2 million € |
| Croatia | 228.0 million € |
| FYR Macedonia | 229.7 million € |
| Moldova | 0 million € |

| | |
|--------------|--------------------------|
| Montenegro | 46.9 million € |
| Serbia | 640.4 million € |
| Ukraine | 5,138.5 million € |
| Kosovo* | 78.0 million € |
| TOTAL | 6,698.7 million € |

For reaching compliance with the IED in the Contracting Parties, investment costs for the environmental upgrade of LCPs with the aim of reducing emissions of SO₂, NO_x and dust are estimated as follows:

| | |
|------------------------|--------------------------|
| Albania | 0 million € |
| Bosnia and Herzegovina | 374.7 million € |
| Croatia | 318.2 million € |
| FYR Macedonia | 271.6 million € |
| Moldova | 1.9 million € |
| Montenegro | 50.9 million € |
| Serbia | 710.7 million € |
| Ukraine | 6,033.2 million € |
| Kosovo* | 84.2 million € |
| TOTAL | 7,845.4 million € |

It is therefore visible that, with the exceptions of Albania and Moldova, major investments would be necessary throughout the Contracting Parties in order to carry out the necessary environmental upgrades that could safeguard the proper implementation of the LCPD and the IED. According to the above calculations, however, benefits significantly outweigh the costs the case of each and every Contracting Party.

The investments required to comply with the requirements of the LCPD in the Contracting Parties are estimated at 6,701.6 million €; more specifically:

- 882 million € for the installation and upgrade of electrostatic precipitators;
- 2,123 million € for NO_x control; and
- 3,694 million € for SO₂ control (flue gas desulphurization systems).

The most significant investments are required for the reduction of SO₂ emissions (55.3 %), followed by the costs of NO_x (31.5 %) and dust (13.2 %) emission reduction.

The investments required to comply with IED requirements in the Contracting Parties are estimated at 7,843.8 million €; more specifically:

- 1,003 million € for the installation and upgrade of electrostatic precipitators;
- 2,664 million € for NO_x control; and
- 4,179 million € for SO₂ control (flue gas desulphurization systems).

The most significant investments are required for the reduction of SO₂ emissions (53.3 %), followed by the costs of NO_x (34.0 %) and dust (12.7 %) emission reduction.

7. Recommendations

For all Energy Community Contracting Parties, the best solution to deal with the requirements on the limitation of emissions of SO₂, NO_x and dust from large combustion plants is to prepare and adopt a combined approach for the implementation of the emission limit values of the LCPD and the IED for the majority of LCPs.

The total capacity of LCPs in the Contracting Parties is over 40,500 MW. They use different kind of fuel with a variety of sulphur content, which has direct implications on the SO₂ emission levels. Furthermore, they have different combustion chamber characteristics, which imply different characteristics in the emissions of nitrogen oxides.

The external costs of the current emissions of LCPs in the Contracting Parties (BAU status) vary between 0.1 – 53 €cent/kWh. Therefore, it is important and economically sensible that Contracting Parties make significant efforts to reduce the emissions of LCPs in order to be able to meet the requirements of EU standards, which could bring major benefits to society. As it is shown by the cost-benefit analyses, compliance with the environmental standards of the LCPD and the IED will bring a number of benefits through avoiding external costs of thermal power production and combined heat and power production. According to the calculations presented in this study, these benefits would significantly outweigh the costs in the case of every Contracting Party.

In this chapter, country-specific recommendations are made for each Contracting Party. The necessary retrofitting measures in order to meet the requirements of the LCPD and the IED have been recommended for each plant for those LCP units remaining in service after 2018.

➤ **Recommendations for Albania:**

The TPP in Albania fulfils the requirements of both the LCPD and the IED and therefore no. The TPP presently uses light distillate oil as a fuel and it is therefore important to make sure that the sulphur content of the fuel is not higher than 0.1%.

➤ **Recommendations for Bosnia and Herzegovina:**

- To urgently install emission abatement techniques for TPP Ugljevik, as it currently has the highest level of emissions in the Energy Community in terms of SO₂ emissions;
- To prepare plans for the rest of the TPPs, except for Tuzla 3 that will be decommissioned by the end of 2015. For the units exceeding the ELVs of the LCPD and/or the IED, the recommendations for specific techniques of environmental upgrade are presented in Table 7-1.

Table 7-1: Recommended environmental upgrade measures for Bosnia and Herzegovina

| No | Plant name | Capacity /MW/ | LCPD retrofit measures | | | IED retrofit measures | | |
|----|------------|---------------|------------------------|-----------------|-----------------|-----------------------|-----------------|-----------------|
| | | | Dust | NO _x | SO ₂ | Dust | NO _x | SO ₂ |
| 1 | Gacko | 300 | ESP | LNB+OFA+SNCR | SD | ESP | LNB+OFA+SNCR | SD |
| 2 | Ugljevik | 300 | ESP | LNB+OFA+SNCR | WLS | ESP | LNB+OFA+SNCR | WLS |
| 3 | Tuzla 4, 5 | 2x200 | ESP | LNB+OFA | SD | ESP | LNB+OFA | SD |
| 4 | Tuzla 6 | 215 | ESP | LNB+OFA | WLS | ESP | LNB+OFA | WLS |
| 5 | Kakanj 5 | 110 | | LNB+OFA | WLS | | SCR+SNCR | WLS |
| 6 | Kakanj 6 | 110 | | LNB | WLS | | SCR+SNCR | WLS |
| 7 | Kakanj 7 | 230 | ESP | SCR+LNB | WLS | ESP | LNB+SCR | WLS |

➤ **Recommendations for Croatia:**

- To install the recommended environmental upgrade system firstly for the oil-fired TPP units (Rijeka and Sisak A and B) as highest priority, followed by the installation of the abatement techniques in other TPP units. The recommendations for specific techniques of environmental upgrade are presented in Table 7-2.

Table 7-2: Recommended environmental upgrade measures for Croatia

| No | Plant name | Capacity /MW/ | LCPD retrofit measures | | | IED retrofit measures | | |
|----|---------------|---------------|------------------------|-----------------|-----------------|-----------------------|-----------------|-----------------|
| | | | Dust | NO _x | SO ₂ | Dust | NO _x | SO ₂ |
| 1 | Plomin | 210 | | LNB+SCR | | | LNB+SCR | |
| 2 | Rijeka | 320 | | LNB+OFA+SNCR | | | SCR | |
| 3 | Sisak | 2x210 | | LNB+OFA | | | SCR | |
| 4 | Jertovac | 2x40 | | | | | LNB+OFA | |
| 5 | Zagreb C | 120 | BF | LNB+OFA | WLS | BF | SCR | WLS |
| 6 | Zagreb K, L | 208+112 | | | | | | |
| 7 | Zagreb K6, K8 | 11+30 | BF | LNB | SD | BF | LNB | WLS |
| 8 | Zagreb | 2x25 | | | | | LNB+OFA | |
| 9 | Osijek | 46+2x25 | | | | | LNB+OFA | |

➤ **Recommendations for FYR Macedonia:**

- To urgently install the environmental abatement techniques in the coal-fired TPPs Bitola and Oslomej;
- To prepare a feasibility study for the oil-fired TPP Negotino, which is presently in reserve operation. The recommendations for specific techniques of environment upgrade are presented in Table 7-3.

Table 7-3: Recommended environmental upgrade measures for FYR Macedonia

| No | Plant Name | Capacity /MW/ | LCPD retrofit measures | | | IED retrofit measures | | | Note |
|----|------------|---------------|------------------------|-----------------|-----------------|-----------------------|-----------------|-----------------|------------|
| | | | Dust | NO _x | SO ₂ | Dust | NO _x | SO ₂ | |
| 1 | Bitola | 3x233 | ESP | LNB+OFA+SNCR | WLS | ESP | LNB+SCR | WLS | |
| 2 | Oslomej | 125 | ESP | | WLS | ESP | LNB+OFA | WLS | |
| 3 | Negotino | 210 | | | | | | | In reserve |

➤ Recommendations for Moldova:

- The TPPs in Moldova are in compliance with the requirements of the LCPD and therefore no additional recommendation is needed in that respect. The recommendations for specific techniques of environmental upgrade in order to achieve compliance with the IED are presented in Table 7-4.

Table 7-4: Recommended environmental upgrade measures for Moldova

| No | Plant name | Capacity /MW/ | LCPD retrofit measures | | | IED retrofit measures | | |
|----|----------------|---------------|------------------------|-----------------|-----------------|-----------------------|-----------------|-----------------|
| | | | Dust | NO _x | SO ₂ | Dust | NO _x | SO ₂ |
| 1 | CET-1, Un 2, 3 | 12+10 | | | | | LNB | |
| 2 | CET-2 | 3x80 | | | | | LNB | |

➤ Recommendations for Montenegro:

- The one coal-fired TPP in Montenegro is a large polluter and need to be retrofitted as a high priority; the recommendations for specific techniques of environmental upgrade are presented in Table 7-5.

Table 7-5: Recommended environmental upgrade measures for Montenegro

| No | Plant name | Capacity /MW/ | LCPD retrofit measures | | | IED retrofit measures | | |
|----|------------|---------------|------------------------|-----------------|-----------------|-----------------------|-----------------|-----------------|
| | | | Dust | NO _x | SO ₂ | Dust | NO _x | SO ₂ |
| 1 | Pljevlja | 219 | | LNB | WLS | | LNB | WLS |

➤ Recommendations for Serbia:

- To install the recommended environmental abatement techniques in TPP Kostolac A and B as highest priority;
- To prepare the necessary plans in order to install the necessary abatement techniques in TPP Nikola Tesla A and B;
- To prepare a program for the replacement of gas-fired CHPs with CCGT units with higher efficiency; the recommendations for specific techniques of environmental upgrade are presented in Table 7-6.

Table 7-6: Recommended environmental upgrade measures for Serbia

| No | Plant name | Capacity /MW/ | LCPD retrofit measures | | | IED retrofit measures | | |
|----|----------------|---------------|------------------------|-----------------|-----------------|-----------------------|-----------------|-----------------|
| | | | Dust | NO _x | SO ₂ | Dust | NO _x | SO ₂ |
| 1 | N.Tesla A1+ A2 | 2x210 | ESP | LNB+OFA | SD | ESP | LNB+OFA | WLS |
| 2 | N.Tesla A3-6 | 4x309 | ESP | LNB+OFA | WLS | ESP | LNB+OFA | WLS |
| 3 | N.Tesla B | 2x620 | ESP | LNB+OFA | WLS | ESP | LNB+OFA | WLS |
| 4 | Kolubara 3 | 64 | ESP | | SD | ESP | LNB | WLS |
| 5 | Kolubara 5 | 110 | ESP | | SD | ESP | LNB+OFA | WLS |
| 6 | Morava | 125 | ESP | | SD | ESP | LNB+OFA+SNCR | WLS |
| 7 | Kostolac A1 | 100 | ESP | | WLS | ESP | LNB+OFA | WLS |
| 7 | Kostolac A2 | 210 | ESP | LNB+OFA | WLS | ESP | LNB+OFA | WLS |
| 8 | Kostolac B | 2x348 | ESP | LNB+OFA+SNCR | WLS | ESP | LNB+OFA+SNCR | WLS |
| 9 | N. Sad | 135+110 | | LNB+SCR | | | LNB+SCR | |
| 10 | Zrenjanin | 110 | | LNB+SCR | | | LNB+SCR | |
| 11 | S. Mitrovica | 32 | | LNB+OFA | | | LNB+OFA | |

➤ Recommendations for Ukraine:

- To implement the emission abatement measures for the pilot plants that have been selected already in order to obtain necessary experience on the use of the following technologies: SD in Trypilska 2 and Zmiivska 1 and SNCR for Zaporiska 1 and 2;
- To prepare the implementation of environmental upgrade systems in coal-fired TPPs which have the highest emission levels, such as: Dobrotvirska, Zuevskaya, Kurakhovskaya, Luganskaya, Burshtynska, Vuglegirska, Zaporishka, Kyivska CHP;
- Optionally, to prepare the plans for the temporary conservation of certain TPP units which are close to the end of their operational lifetime as well as for TPPs with natural gas as their main fuel. This would increase the efficiency of electricity production in the rest of the TPPs; furthermore, with the use of this option investments costs of the environmental upgrade of TPPs in reserve operation could be postponed until and increase of power consumption will require the reopening of these plants. The recommendations for specific techniques of environmental upgrade are presented in Table 7-7.

Table 7-7: Recommended environmental upgrade measures for Ukraine

| No | Plant name | Capacity /MW/ | LCPD retrofit measures | | | IED retrofit measures | | |
|----|----------------------|-----------------|------------------------|-----------------|-----------------|-----------------------|-----------------|-----------------|
| | | | Dust | NO _x | SO ₂ | Dust | NO _x | SO ₂ |
| 1 | Prydniprovskya | 4x150+310+3x285 | ESP | SCR+LNB | NID | ESP | SCR+LNB | NID |
| 2 | Kryvorizka | 10x282 | ESP | SCR+LNB | NID | ESP | SCR+LNB | NID |
| 3 | Zaporiska 1-4 | 325+3x300 | ESP | SCR+LNB | NID | ESP | SCR+LNB | NID |
| 4 | Zaporiska 5-7 | 3x800 | | LNB+OFA | | | LNB+OFA | |
| 5 | Starobeshivska | 10x175 | ESP,BF | LNB+OFA | NID | ESP,BF | SCR+LNB | NID |
| 6 | Slovianska 7 | 800 | ESP | SCR+LNB | NID | ESP | SCR+LNB | WLS |
| 7 | Burshtynska | 4x185 + 8x195 | ESP | LNB+OFA+SNCR | NID | ESP | LNB+OFA+SNCR | NID |
| 8 | Dobrotvirska 5&6 | 2x100 | ESP | LNB+OFA | NID | ESP | LNB+OFA | NID |
| 9 | Dobrotvirska 7&8 | 2x150 | ESP | LNB +SCR | NID | ESP | LNB+SCR | NID |
| 10 | Ladyzhinska | 4x300 | ESP | LNB+SCR | NID | ESP | LNB+SCR | NID |
| 11 | Trypilska | 4x300 | ESP,BF | LNB+SCR | NID | ESP | LNB+SCR | NID |
| 12 | Trypilska NG | 2x300 | | LNB+SCR | | | LNB+SCR | |
| 13 | Zmiivska | 6x175+3x275+325 | ESP,BF | LNB+SCR | NID | ESP | LNB+SCR | NID |
| 14 | Vuglegirska 1-4 | 4x300 | ESP,BF | LNB+SCR | NID | ESP | LNB+SCR | NID |
| 15 | Vuglegirska 5-7 | 3x800 | | LNB+SCR | | | LNB+SCR | |
| 16 | Zuevskaya | 2x325+320+300 | ESP | LNB+SCR | NID | ESP | LNB+SCR | NID |
| 17 | Kurakhovskaya | 210+3x210+3x222 | ESP | LNB+OFA+SNCR | NID | ESP | LNB+OFA+SNCR | NID |
| 18 | Luganskaya 9, 11 | 2x200 | Scr | LNB+SCR | NID | ESP | LNB+SCR | NID |
| 19 | Luganskaya 10, 13-15 | 175+3x200 | ESP | LNB+SCR | NID | ESP | LNB+SCR | NID |
| 20 | Luganskaya 12 | 175 | | LNB+OFA | NID | ESP | LNB+OFA | NID |
| 21 | Bilotserkivska | 120 | | | | | LNB+OFA | |
| 22 | Darnytska 5,10 | 50 | | | | | LNB+SCR | |
| 23 | Darnytska 6-9 | 110 | ESP | LNB+OFA | SD | ESP | LNB+SCR | NID |
| 24 | Kaluska CHP 1, 2 | 100 | ESP | | SD | ESP | LNB+SCR | NID |
| 25 | Kaluska CHP 3, 4 | 100 | | LNB | | | LNB+SCR | |
| 26 | Kyivska CHP-5 | 540 | | LNB+OFA | | | LNB+SCR | |
| 27 | Kyivska CHP-6 | 500 | | LNB+OFA | | | LNB+SCR | |
| 28 | Kramatorska CHP | 120 | Scr | | SD | Scr | | NID |
| 29 | Myronivska 4 | 60 | ESP | | SD | ESP | LNB+OFA+SNCR | NID |
| 30 | Myronivska 9 | 115 | ESP | LNB | SD | ESP | LNB+OFA+SNCR | NID |
| 31 | Odeska CHP-2 | 68 | | LNB+OFA | | | LNB+SCR | |
| 32 | Sevastopolska CHP | 55 | | | | | LNB+OFA | |
| 33 | Simferopilska CHP | 278 | | | | | LNB | |
| 34 | Kharkivska CHP-2 | 74 | ESP | LNB+OFA | NID | ESP | LNB+OFA+SNCR | NID |
| 35 | Luganskaya | 2x175+5x201 | ESP | LNB+SCR | NID | ESP | LNB+SCR | NID |

➤ **Recommendations for Kosovo*:**

- To install the emission abatement techniques in the two TPP units of Kosovo B before the closure of TPP Kosovo A. The recommendations for specific techniques of environment upgrade are presented in Table 7-8.

Table 7-8: Environmental Upgrade Measures for Kosovo*

| No | Plant name | Capacity /MW/ | LCPD retrofit measures | | | IED retrofit measures | | |
|----|------------|---------------|------------------------|-----------------|-----------------|-----------------------|-----------------|-----------------|
| | | | Dust | NO _x | SO ₂ | Dust | NO _x | SO ₂ |
| 1 | Kosovo B | 2x339 | ESP | LNB+OFA+SNCR | SD | ESP | LNB+OFA+SNCR | SD |

ANNEXES

Annex 1 Description of BAT for the environmental upgrade of LCPs

Thermal power plants and combined heat and power production plants are the largest emitters of particulate matters, nitrogen oxides and sulphur dioxide.

To comply with the regulatory requirements, LCPs have to be equipped with air pollution control devices. However, such control devices can contribute significantly to the cost of electricity. An understanding of cost structures of various control technologies can assist industry in determining the most cost effective means by which to comply with regulatory requirements¹⁸.

A.1.1. Control of PM (dust) emissions

In modern TPPs and CHPs, PM emissions are controlled by electrostatic precipitators (ESP) or fabric filters (FF). Both technologies are highly efficient and capable of removing particulates to a level well beyond the ELVs of the LCPD and the IED. FFs are generally more efficient in removing fine particles. The choice between ESPs and FFs depends on fuel type, plant size, boiler type and configuration as well as the required PM removal efficiency. ESPs are mainly used in modern TPPs and CHPs. FFs are used only in special cases, for example if the electrical resistivity of ash is extremely high or the emission reduction requirement for PM is extremely strict.

Apart from the above considered modern techniques, wet scrubbers are used in several coal-fired plants to capture fly ash in addition to sulphur dioxide (SO₂). In the most widely used venture scrubber, water is injected into the flue gas stream at the venture throat to form droplets.

a) Electrostatic precipitators (ESP)

From the first development of commercial electrostatic precipitator designed by Fredrick Garner Cottrell in 1907, ESPs remain the dominant device for particulate emission control until nowadays. ESP design has been seriously improved based on the experience collected during the exploitation of ESPs in various industries. Stringent emission standards have also had an important influence on development of ESPs by forcing manufacturers to further improve ESP efficiency. According to the newest trends on the ESP market, intelligent precipitator control including integration into global plant control system, pulse energization, wide plate spacing, Hi-R™ (high reliability) system are used.

The main advantages of ESPs are:

¹⁸ The Consultants used the *Guidance document on control techniques for emissions of sulphur, NOx, VOCs, dust (including PM10, PM2.5 and black carbon) from stationary sources* as a reference (Working Group on Strategies and Review, Fiftieth session, 24 September 2012), which includes the criteria and requirements of the revised LCP BREF

- Possibility of treatment of the large volumes of gas without significantly increasing process pressure drop (0.15-0.3 kPa)
- Possibility of operation over a wide range of temperatures (80-220 °C, cold ESP and 300-450 °C, hot ESP)
- Robustness and endurance at the high concentration of erosive ash in flue gases and Low electric energy consumption (0.1-1.8%) and low operating costs.

The efficiencies of modern ESPs are above 99.5% and can reach values up to 99.9 %. In practical terms, ESPs collect larger particles better than smaller ones.

The most important factor which determines the electrical migration velocity is the ash resistivity. If the resistivity is too low, particles lose their charge either before being collected or they may be released back into the flue gas stream after impacting the collection electrodes and secondly, dust re-entrainment can occur. However, when particles have too high resistivity, an insulating layer is formed on the electrode which hinders normal corona discharge and causes an electrical breakdown resulting in back corona or sparking at the surface.

The ash resistivity depends on the flue gas composition, ash composition, sulphur content, flue gas temperature and moisture content.

Other limitations of precipitator performance are flow non-uniformity and re-entrainment. More uniform flow ensures that there is no “sneakage” or gas flow bypassing the electric fields. Re-entrainment of collected particles may occur during rapping. Proper rapping design and timing will minimize rapper re-entrainment.

In order to improve the efficiency of existing ESPs the following action can be performed: replacement of the electrodes, rappers and other internal elements, modernization of the precipitator power supply and control system, enlargement of precipitator size and specific collection area.

b) Bag Filters (Fabric filters)

Bag filters (BF) are used where a very high efficiency (over 99.9%) is required. The performances of BFs are independent of the sulphur content, fluctuation in gas flow conditions and changes in inlet ash load.

BFs are often used for collecting high resistivity fly ash from low-sulphur coals which is relatively difficult to be collected by ESP.

BFs are characterized by:

- very high pressure drop (0.5-2 kPa);
- high electricity consumption (0.2-3 % of TPP capacity);
- low operating temperature, ≤ 150 °C (with polyester bags) ≤ 260 °C (with fiberglass bags);
- high maintenance and operational costs.

Bag life decreases with the increase of the sulphur content of coal and the filtering velocity. The individual bags fail at an average annual rate of about 1 % of installed bags.

For oil-, coal- and lignite-fired TPPs, the selected best available techniques for ash emission control are ESP or FF in combination with FGD (for units with a rated thermal input of ≥ 100 MW) and ESP or FF (for units with a rated thermal input from 50 to 100 MW).

c) Wet scrubbers

In the most widely used venturi scrubber, water is injected into the flue gas stream at the venturi throat to form droplets. Fly ash particulates impact with the droplets forming a wet by-product which then generally requires disposal. The system efficiency is reduced as the particle size decreases. The process can also have high energy consumption due to the use of sorbent slurry pumps and fans. Many of the wet particulate scrubbers are designed to control both SO_2 and particulates by using alkaline fly ash as a sorbent. Lime is frequently used to boost SO_2 removal efficiencies. The method has not been used in power plants with a rated thermal input over 300 MW. The removal efficiency is from 70 % up to 90 %.

A.1.2. DeNO_x techniques

DeNO_x techniques can be grouped into primary (combustion modifications) and secondary (post-combustion techniques) measures.

a) Primary measures

Primary measures include relatively simple and low-cost techniques, such as:

- Low excess air (LEA);
- Over-fire air (OFA);
- Air staging (AS);
- Flue gas recirculation (FGR);
- Fuel staging (FS);
- Low NO_x burners (LNB).

Low excess air (LEA) technique is based on the reduction of air in the reaction zone by the use of which a considerable reduction of NO_x emissions can be achieved. The main idea is to reduce the available oxygen in the combustion zone to the amount necessary for the complete burnout of the fuel. It reduces the conversion of fuel-bound nitrogen as well. Usual excess air in flue gases is in the range of 5-9% O₂. By the use of this technique, **20-40%** of NO_x emission reduction can be achieved.

Air staging is a zoned method in which a primary rich combustion zone is formed with primary air up to 90% and a secondary lean combustion zone with surplus of 10-30 % of the combustion air. The sub stoichiometric combustion in the primary zone suppresses both the thermal NO_x and conversion of fuel-bound nitrogen to NO_x.

Over-fire air (OFA) technique is a method in which a part of the combustion air is injected through separate ports which are located above the top row of burners. Typically, 15-30 % of the total combustion air is introduced

through these ports. This is the most frequently used DeNO_x technique. Different combinations of OFA exist. NO_x reduction can reach 40-50% (~40 % for solid fuel; 45 % for oil; ≤ 65 % for gaseous fuel). There are two possible drawbacks of the air staging retrofit techniques: an increase of CO emissions and unburnt carbon in the ash.

Flue gas recirculation (FGR) technique is based on the decrease of combustion peak temperature, a reduction of available oxygen in the combustion zone and a change of the concentration of reacting species by introducing diluents such as nitrogen, water vapour and carbon dioxide. Both fuel-bound nitrogen and thermal NO_x are reduced. The FGR is mainly used in gas- and oil-fuelled boilers. Achievable NO_x reduction is in the range of 15-20%.

Fuel staging or re-burning method is based on the spatially divided zones in a furnace with controlled injection of fuel and air in order to recover nitrogen from already formed nitrogen oxides. In the primary zone, up to 90 % of fuel is burnt in a close stoichiometric atmosphere. In the second zone (the re-burning zone), secondary fuel is injected into a reducing atmosphere. The produced hydrocarbon radicals react with the formed NO_x to form nitrogen. The combustion is completed in the third zone when air is added to burn out the remaining combustible compounds. Although all types of fuel can be used, natural gas is considered the most effective. The re-burned fuel is 15-20% of the total heat input. The corresponding NO_x reduction can reach 40-50% of NO_x level achieved with low NO_x burners.

Low NO_x burners (LNB) are purposely designed burners that utilize combinations of combustion modification techniques such as air staging, fuel staging and FGR. Low NO_x burners are effective in reducing NO_x emissions by 30-50% and can be combined with other primary measures such as over-fire air, re-burning or flue gas recirculation. A drawback is the possible increase of unburnt carbon in the ash. To overcome this problem, an improvement of the fineness of the pulverized coal might be necessary. The most frequently used LNBs are air-staged or fuel-staged type burners with respective NO_x emission reduction levels **of 25-35% and 50-60%**. The LNB technique is the most often applied technique in both new and existing coal-fired boilers. When optimized with other air and fuel control equipment, including secondary and tertiary air, the NO_x reduction efficiency can reach **up to 70%**.

b) Secondary measures or post-combustion NO_x removal

Secondary measures are based on the injection of small quantities of additives into flue gas which react with NO_x and under favourable temperature and residence time conditions produce N₂ and H₂O. Standard additives are ammonia (NH₃) and urea ([NH₂]₂CO). If the reaction takes place in the gaseous phase, it is called selective noncatalytic reduction (SNCR) while if a catalyst is present, the technique is selective catalytic reduction (SCR).

Selective non-catalytic reduction (SNCR)

The chemical reaction is very sensitive to temperature and the working temperature range is between 1150 – 1400 °K. The efficiency of NO_x reduction is 20 (30) – 50%.

Selective catalytic reduction (SCR) is a process based on the selective reduction of nitrogen oxides with ammonia or urea in the presence of a catalyst, at 300 and 450 °C. There are many possible catalysts, from heavy metal oxides, to zeolites and activated carbon. SCR is widely applied and proven DeNO_x technique. The life of catalyst depending on the applied material can be up to ten years. The reduction potential of the SCR technique is 50 – 80% (95%) and therefore this is the most efficient DeNO_x technique.

Secondary measures have largely been applied to coal-fired plants. At lignite-fired TPPs, the application of primary measures is usually sufficient to reduce NO_x emissions below the ELVs of the EU directives.

Table A1-1: Average reduction efficiency of selected primary and secondary measures for reducing NO_x emissions in large combustion plants

| Technique Average | NO _x reduction rate* | Technical limitations |
|--|---|---|
| Low excess air (LEA) | 10-44 % | incomplete burn-out |
| Over fire air (OFA) | 15 – 30 % | incomplete burn-out |
| Flue gas recirculation (FGR) | < 20 % (coal) 30-50 % (gas, combined with OFA) | flame instability |
| Fuel staging (FG) | 50-60 % | |
| Air-staged LNB | 25-35 % | incomplete burn-out flame instability |
| Flue-gas recirculation LNB | <20 % | flame instability |
| Fuel-staged LNB | 50-60 % | incomplete burn-out flame instability |
| Selective catalytic reduction (SCR) | 80-95 % | ammonia slip; contamination of fly ash by ammonia; air heater fouling |
| Selective non-catalytic reduction (SNCR) | 30-50 % | ammonia slip which is usually higher than with SCR |

* If several measures are applied reduction rates are different

A.1.3. Sulphur dioxide emissions control

There are a number of techniques for reducing SO₂ emission from coal combustion: wet scrubbers (absorbers), spray dry scrubbers, and sorbent injection. The choice of SO₂ control technology depends on a number of factors: emission requirements, plant size and operating conditions, sulphur content in the coal and the cost of various technology options, all of which are unique to each site.

a) Wet absorbers (scrubbers)

The limestone wet absorbers is the most common type of flue gas desulfurization (FGD). Lime can also be used as a reagent but it is usually more expensive.

There are generally two types of wet limestone scrubber: forced oxidation and natural oxidation. In the limestone with forced oxidation (LSFO) system, air is introduced into the bottom of the absorber to force oxidation of calcium sulphite to calcium sulphate while gypsum is obtained as a by-product.

When implementing wet limestone FGD systems on an existing installation, the flue gas path from the inlet of the

absorber to the stack may need to be modified to protect against corrosion and acid attack. In most retrofit units, new stacks are required. As an FGD system requires considerable space, retrofitting may be more expensive in cases where there is a lack of available space.

Wet processes have undergone considerable developments in the last few decades. The state-of-the art wet absorbers are capable of routinely achieving SO₂ removal efficiencies **over 95% and up to 99.6%**.

b) Spray dry scrubbers

In spray dry scrubbers highly atomized aqueous alkaline slurry is sprayed into an absorption tower. As the slurry droplets are evaporating, SO₂ absorbs into the droplet and reacts with the dissolved and suspended alkaline material. These dry droplets are entrained in the flue gas and then collected in ESPs or FFs. Lime is the most commonly used alkaline chemical.

The absorption chemistry is strongly affected by factors such as flue gas temperature, gas humidity, SO₂ concentration in the flue gas and atomized slurry droplet size. The by-product is a dry mixture of calcium sulphite, sulphate, fly ash and un-reacted lime. They are mostly used for small to medium capacity boilers (<300MW) burning low to moderate sulphur fuel.

This technology has relatively low energy consumption, compared to the use of wet scrubbers

The main disadvantage of this technology relates to the disposal of the solid residue as the waste products are mixtures of fly ash, calcium sulphite and calcium sulphate which are less attractive commercially.

On the other hand, an important feature of the spray dry scrubber is that waste water treatment is not required, because the water is completely evaporated in the spray dry scrubber. As they are normally more compact than wet systems, they are suitable for retrofit applications or in sites where there is no space for waste water handling. In addition, this is a highly efficient process for acid gas (SO₃ and HCl) removal.

Application of spray dry scrubbers is limited to the flue gas volume of about 200 MW (electric capacity) plants on average. Larger plants require the use of several modules to deal with the total flue gas flow.

SO₂ control efficiencies for spray dry scrubbers are lower than those for wet scrubbers and **vary from 80% to 92%**.

c) Semi-dry NID technology

Semi-dry Novel Innovation De-acidification (NID) Technology for flue gas desulfurization comprises a mixer, J-duct reactor and typically bag filter, but electrostatic precipitators can be used as well. The lime is used as absorbent. SO₂ reacts with hydrated lime under humid conditions. Once bound to the particulate matter, SO₂ is removed from the flue gas in a downstream BF or ESP. The collected particles are recycled to the mixer where

fresh lime and water are added to the process. The removal efficiency can reach **up to 98 %**. The by-product is dust and there is no need for waste water treatment.

d) **Dry sorbent injection**

Dry sorbent injection systems are those where the sorbent is injected into the furnace and/or duct.

Sulphur dioxide adsorbs to the surface of the sorbent particles and reacts to form sulphite and sulphate compounds that are subsequently captured in particulate control devices along with fly ash. In order to increase removal efficiency and sorbent utilization, the reaction product collected by the particulate control device is re-injected into the furnace or duct and circulated several times. Commercially available limestone (CaCO_3) or hydrated lime (calcium hydroxide) is commonly used as sorbent; although sodium based alkaline reagents can also be used.

There are three types of sorbent injection processes: furnace, duct sorbent injection and hybrid sorbent injection. Furnace sorbent injection is the most commonly used system, and involves direct injection of dry sorbent into the upper part of the boiler furnace.

Dry sorbent injection is viewed as an emerging SO_2 control technology for medium to small boilers. Due to their low capital cost, but relatively high operating costs, these are suitable for retrofit applications, especially for old boilers with limited remaining lifetime and for peak load boilers with short annual operating time. According to basic characteristics of the system, dry sorbent injection cannot be used for waste gas having SO_2 concentrations greater than 2000 ppm (7500 mg/m^3). The dry process eliminates the slurry production and handling equipment required for wet scrubbers and spray dryers, although the technology also produces large quantity of wastes containing calcium sulphite, calcium sulphate, un-reacted sorbent and ash which may require special handling and disposal. The performance of a sorbent injection process depends on factors such as sorbent reactivity, the relative humidity of the flue gas and the gas and solids residence time, the quantity of injected sorbent, and quantity of recycled, unreacted sorbent from the particulate control device.

Sorbent injection systems normally have a moderate (**30-50%**) SO_2 removal efficiency, which is much lower than the wet systems described previously. An even distribution of fine sorbent particles ($<5 \mu\text{m}$) across the reactor and adequate residence time at the proper temperature ($750\text{-}1,250^\circ\text{C}$) are critical for high SO_2 removal rates. More recent applications of dry sorbent injection on small coal-fired industrial boilers have achieved **greater than 90%** SO_2 control efficiencies and in systems where the reaction product is recycled, removal efficiencies of **70-80%** can be achieved.

Annex 2 Methodology for the investment cost estimate for environmental upgrade techniques

A.2.1. General

In general, the cost of measures for emission reduction for all three pollutants (Dust - PM, SO₂ and NO_x) depends on many factors. The main factors are:

- Flue gas flow rate
- Concentration of pollutant in flue gas
- Type and characteristics of fuel
- Site conditions.

a) Cost dependence on the flue gas flow rate

The flue gas flow rate has the dominant influence on the cost of the measure for emission reduction. The cost is decreasing when the flow rate increases. In the range of small flow rates the cost increases quickly with decreasing flow and in the range of high flow rates it decreases very slowly. In references usually the costs (specific or total) are depending on the TPP unit electric capacity and sometimes are depending on the thermal capacity. If the cost is depending on the electric capacity also the type of fuel should be taken into account.

b) Cost dependence on the pollutant concentration in flue gas

The higher concentration of the pollutant in flue gas requires the application of more effective measure for emission reduction, which is more expensive. In the range of small and medium concentration the cost increase is almost linear and slower than in the range of high concentration of pollutant.

c) Cost dependence on the type and characteristics of fuel

The ash resistivity is one of the dominant elements determining the cost of the ESP and the efficiency of primary measures is higher for gas fuel than for the other ones.

d) Site conditions

Geological, hydro-geological, seismological conditions and available space at the site, and available space in surrounding of the TPP site for disposal of by-products (gypsum, ash), distance from the disposal site, characteristics of soil and environment etc. have an impact on the construction cost of structures.

e) Application of emission reduction measures at the existing TPP

The design solutions for the existing TPP were optimized and executed without taking into account the implementation of less strict measures for emission reduction. The application of more strict measures usually

includes the dismantling of some existing constructions and the implementation of complicated solutions as the consequence of the lack of space. Sometimes the increase of cost can reach 30 % of the cost of emission reduction measure applied at the new constructed TPP plant.

A.2.2. Basis of the applied costs in this Study

The basis for determining the emission reduction costs of all three pollutants (SO₂, NO_x and dust - PM) is the available literature, information obtained from the beneficiary countries, information obtained through direct contacts with the manufacturers of the emission reduction measures and European Power Capital Cost Index (EPCCI) issued in 2012.

a) Data from the available references

The data values from the literature vary in a very wide range principally because of the specific conditions at the project site, the retrofit project complexity, and the timing differences between projects. Besides the above-mentioned facts that determine the cost of the emission reduction measures, the time period to which the data is related, completeness of the emission reduction system and many temporal, local and other facts can have the influence on the cost.

b) Data obtained from the beneficiary countries

Unfortunately, a sufficient amount of data on the investment cost estimates of the environmental upgrade equipment could have not been obtained from the beneficiary countries due to the brevity of the current exercise. The findings of the present study are without prejudice to calculations, cost estimates and/or cost-benefit analyses of the ones other entities or institutions may have arrived to.

c) European Power Capital Cost Index (EPCCI)

Investment costs can vary in time very quickly. The power plant capital cost increases during the last decade, provided by Simon Larsen are presented in Figure A2-1¹⁹. The cost increases can be partly explained by rising costs on steel, copper and oil, which have an influence on the equipment and material costs. This analysis was prepared both for nuclear power plants and thermal power plants. The capital cost index for thermal power plants is indicated from 2005. The same cost index is applicable not only for new thermal power plants, but also for the environmental upgrade systems.

¹⁹ Simon Larsen: Reviewing Electricity Generation Costs Assessments, Upsala University, Jun 2012




Figure A2-1: EPCCI index (IHS, 2012)

The base cost can be related to the year 2000. The highest index value was at the beginning of 2009 (cca 180 %) and at the end of 2010 and beginning of 2011 (about 170 %).

A.2.3. Particulate matter emission reduction

Efficiency of the electrostatic precipitators depends on the exit ash particulate concentration and resistivity. H. Nguyen et al have shown In Fig. A2-2 is presented the dependence of ESP cost on the range of the exit concentration between 100 mg/Nm³ and 20 mg/Nm³²⁰).




Figure A 2-2: ESP cost changes depending on the exit ash content and ash resistivity

²⁰ Hao Nguyen et al: Analyzes of Pollutant Control costs in Coal based Electricity Generation, Technology Assessment Report 68, January 2008

The costs of the dust (PM) reduction measures used in this Study

The cost of ESP retrofitting is extremely dependent on the site conditions and can only be estimated on the basis of a detailed knowledge and analyses of the site conditions. That was the reason why the authors of this Study decided to accept the dust (PM) reduction emission costs obtained from beneficiaries as the most correct solution. In the case of missing data from beneficiaries, the above curve is used. The reference specific cost for discharge concentration of 50 mg/Nm³ is assumed according to the flue gas flow rate as 8 €/Nm³/h. This value represents a best average cost of the recently retrofitted ESPs or ESPs with documentation prepared for retrofitting, as shown in Table A2-1, which includes a comparison between values provided by the beneficiaries and the calculated values.

Table A2-1: List of the ESP costs obtained from the beneficiary countries and calculated, discharge dust - PM concentration 50 mg/Nm³

| EnC Contracting Party /TPP/TPP's unit | Fuel | Unit(s) capacity, MW | Flue gas flow rate, mil.Nm ³ /h | Cost of ESP, mil. € | Calculated cost value mil. € | Year of retrofitting | Remarks |
|---------------------------------------|------|----------------------|--|---------------------|------------------------------|----------------------|--|
| Albania | | | | | | | |
| TPP Vlora | NG | | | | | | N/A |
| Bosnia and Herzegovina | | | | | | | |
| TPP Ugljevik | BC | 300 | 1.36 | 20.0 | 10.9 | <2017 | <20 mg/Nm ³ |
| TPP Tuzla 6 | BC | 215 | 0.92 | 4.95 | 7.3 | 2013 | <30 mg/Nm ³ |
| TPP Kakanj 5 | BC | 110 | 0.49 | 3.99 | 3.94 | 2003 | <11 mg/Nm ³ |
| TPP Kakanj 6 | BC | 110 | 0.48 | 3.98 | 3.82 | 2012 | <20 mg/Nm ³ |
| Croatia | | | | | | | |
| TPP Plomin 1 | HC | 125 | 0.426 | 4.5 | 3.41 | 1999 | <25 mg/Nm ³ |
| FYR Macedonia | | | | | | | |
| TPP Bitola | L | 3x225 | 3x1.13 | 3x11.6 | 3x9.1 | <2017 | <50 mg/Nm ³ |
| Oslomej | L | 125 | 0.625 | 7.0 | 5.0 | <2017 | <100 mg/Nm ³ |
| Moldova | | | | | | | |
| | | | | | | | N/A |
| Montenegro | | | | | | | |
| TPP Pljevlja | L | 220 | | 9.7 | 8.26 | 2009 | <30 mg/Nm ³ |
| Serbia | | | | | | | |
| TPP Nikola Tesla A3 | L | 305 | 1.4 | 10.5 | 11.2 | 2014 | <50 mg/Nm ³ |
| Kostolac B1&B2 | L | 2x350 | 2x1.62 | 2x10 | 2x13.0 | 2014 | <50 mg/Nm ³ |
| Morava | L | 120 | 0.616 | 8.0 | 5.0 | 2015 | <100 mg/Nm ³ |
| Ukraine | | | | | | | |
| Prydniprovskaja 9 | HC | 150 | 0.326 | 3.7 | 2.6 | 2012 | |
| Prydniprovskaja 13, 14 | HC | 2x285 | 2x0.996 | 11.5 | 7.96 | 2012/2015 | |
| Krivovirska 3,5,6,9 | HC | 4x 282 | 4x0.911 | 5.8-8 | 7.3 | 2012-2018 | |
| Zaporiska 1, | HC | 325 | 0.928 | 4.7 | 7.42 | 2012 | <50 mg/Nm ³ |
| Zaporiska 2,3,4 | HC | 3x300 | 3x0.856 | 9.4/5.6/94 | 3x6.85 | 2012-2015 | <50 mg/Nm ³ |
| Burshtynska5,7,8 | HC | ~5x195 | ~5x0.70 | 3.2-7.6 | 5.6 | 2012-2016 | <50 mg/Nm ³ |
| Burshtynska9,10 | HC | ~5x195 | ~5x0.70 | 3.2-7.6 | 2x5.6 | 2006/2006 | <50 mg/Nm ³ |
| Dobrotvirska 7,8 | HC | 2x150 | 2x550 | 5.5/7.6 | 2x4.4 | 2012-2015 | <50 mg/Nm ³ |
| Ladyzhinska | HC | 6x300 | 6x0.862 | 6x6.9 | 6x6.9 | 2015-2018 | <50 mg/Nm ³ |
| Zuyevskaia 1,2,3 | HC | 3x315 | 3x0.993 | 3x9.5 | 3x7.95 | 2013-2015 | <50 mg/Nm ³ |
| Zuyevskaia 4 | HC | 325 | 1.085 | 5.8 | 8.6 | 2012 | <50 mg/Nm ³ |
| Kosovo* | | | | | | | |
| TPP Kosovo A | L | 3x200 | 3x0.97 | 3x8.5 | 3x9.1 | 2012-2013 | |
| TPP Kosovo B | L | 2x339 | 2x1.57 | 2x10.0 | 2x12.5 | 2017 | Calculated for de rated capacity (280MW) |

A.2.4. SO₂ Reduction costs

a) Data from references

There is a large difference between costs of FGD presented in the available references and those presented in the answers obtained from the beneficiary countries. The Indicative costs of SO₂ emissions abatement techniques for boiler plants had been recently issued by EPA, with reference to Euros 2001²¹, Table A2-2 illustrate these differences.

Table A2-2: Indicative costs of SO₂ emission abatement techniques for boiler plants (2001 Euros)

| Control option | Process capacity MW _{th} | Capital costs €/kW | O&M costs €/kW | Annual costs €/kW | Pollutant removed costs €/ton SO ₂ |
|----------------|--------------------------------------|-----------------------|-------------------|----------------------|--|
| Wet scrubber | >400 | 104 - 262 | 2 - 8 | 21 - 52 | 210 - 523 |
| Wet scrubber | <400 | 262 - 1,572 | 8 - 21 | 52 - 210 | 523 - 5,230 |
| Dry Scrubber | >200 | 41 - 157 | 4 - 11 | 21 - 52 | 157 - 314 |
| Dry Scrubber | <200 | 157 - 1,572 | 11 - 314 | 52 - 523 | 523 - 4190 |

Robert Peltier has analysed the average total installed costs of FGD systems²², which are surveyed in the period 2007 and 2008, when quick changes in cost appeared. The prices rose about 15% (in average) from 2007 to 2008. The survey included 78 TPP units. The authors of this study underline a large variation of the costs of considered units of FGD systems. These differences come out as a consequence of the specific site conditions that exist at each project site, the retrofit project complexity, and the timing differences between projects.

Therefore, defining an average project cost is difficult without some understanding of the project-specific details of each of the units surveyed. A look at the summary or “fully loaded” installed costs clearly shows that costs continue to rise and continue to stay consistently above \$300/kW (250 €/MW).

The results of analyses of the emission reduction techniques in coal fired plants, done by Orfanoudakis et al.²³ have shown the following:

- For wet FGD systems, efficiency is from 70 % to 98 %, sulphur content in coal 0.3 % to 4.5 %
 - Cost 80 to 120 €/MW_{th} (cca 240 to 360 €/MW)
 - Electricity consumption 2-3 %
 - Operational costs 175-600 €/t
- For spray dry scrubber, efficiency is from 50 % to 70 %, S content in coal 0.5 % to 1.9 %
 - Cost 40-80 €/MW_{th} (cca 120-240 €/MW)
 - Electricity consumption 0.5 %
 - Operational cost 700-1,000 €/t.

²¹ EPA: Guidance document on control techniques for emission of sulphur, NO_x, VOC, dust from stationary sources, 2012; http://www.unece.org/fileadmin/DAM/env/documents/2012/EB/Informal_document_7_EGTEI_guidance-document_on_stationary_sources_tracked_changes_compared_with_WGSR_version.pdf

²² Robert Peltier: Air Quality Compliance, Latest Costs for SO₂ and NO_x Removal, June 13, 2009

²³ N. Orfanoudakis et al.: Emission Reduction Techniques and Economics in Coal fired Power plants, Greece, 2005

Company ALSTOM has shown the results of the economic analyses of FGD system costs²⁴ in a seminar held in December 2008, for TPP units fired by coal with high sulphur content and units fired by coal with low sulphur content, both with a capacity of 600 MW. The concentration of SO₂ in raw flue gas of TPP unit fired by high sulphur content coal was 3.7 times higher from the units with low sulphur content. The estimated costs of FGD plants were ca. 225 €/MW for high sulphur content coal fired unit and ca. 180 €/MW for low sulphur content coal fired unit.

The operational and maintenance costs were:

- For unit fired by high sulphur content coal cca 2.5 €/MWh
- For unit fired by low sulphur content coal cca 1.5 €/MWh

The specific cost (per 1 t) of SO₂ removal was three times lower for units fired by high S content coal.

The Study on the Economic Partnership Projects in Developing Countries in 2011 and the Study on the Environmental Improvement, FYRM, City Bitola, February, 2012, prepared by the company Yokogawa Electric Corporation includes an analysis of technical, environmental and economic issues of the flue gas desulphurization of lignite fired TPP Bitola (3x233 MW). The obtained results have shown that for all three lignite fired units, with a total capacity of 699 MW, existing SO₂ emission of 3,900 mg/Nm³ and exit SO₂ emission of 200 mg/Nm³, the total installed cost will be 19.4 billion yen (ca. 155 million € or 230,000 €/MW). The cost also included 5% contingency and a 5% fee. After the deduction of these expenses, the cost will be 140 million € or 207,000€/MW. The value of exit emission of 400 mg/ Nm³, without contingency, will be ca. 180,000 €/MW.

The author of the Study refers to the cost of the FGD plant equipment for the on-going project in Romania of 23.3 million yen/MW (cca 186,000 €/MW), which explains the reality of the obtained investment cost for TPP Bitola.

KEMA elaborated the study “Reducing Sulphur Dioxide and Nitrogen Oxide Emission” for TPP Kakanj, B&H, from November 2009 to June 2010²⁵. The results of SO₂ emission reduction are presented in Table A2-3. On the basis of the excerpt from the Study it can be concluded that the costs of the considered options for FGD systems include all elements of the project expenses.

b) Data obtained from direct contacts with a company with experience in FGD plant construction

The information obtained from a European experienced consultancy company was that the investment costs for a wet limestone gypsum FGD plant might be approximately 25 – 35 €/Nm³/h. Sulphur load and concentration will

²⁴ Ray Gansley: Wet FGD system Overview and Operation, Alstom, December 2008

²⁵ KEMA: Reducing Sulfur Dioxide and Nitrogen Oxides Emissions on TPP Kakanj, 2010

have an influence if it is on the lower or on the upper end of the range. Boiler size also has an influence: smaller FGDs are particularly more expensive than large systems. The full range of costs which the company has listed over the last 20 years is approx. 10 – 50 €/Nm³/h (cca from 55,000 to 270,000).

The complete FGD systems (including limestone handling and milling, gypsum handling etc.) will increase costs for about 20 %. This means that in the case of lignite fired TPP units the specific cost of the complete FGD system will vary from 135,000 €/MW to 190,000 €/MW (full range listed for the last 20 years varies from 55,000 €/MW to 270,000 €/MW). These values should be corrected for high and low SO₂ concentration in raw flue gas.

c) Data obtained from the beneficiary countries

A very small amount of data could have been obtained, which is presented in Table A2-3 below.

The obtained data includes the range from 42,000 €/MW for three units of TPP Prydniprovskia, with a capacity of 315 MW and SO₂ content in raw gas starting from cca 3,200 mg/Nm² to 317,000 €/MW for TPP Ugljevik, with a capacity of 300 MW and SO₂ content in raw gas 16,200 mg/Nm² (the project implementation is currently ongoing).

Table A2-3: List of FGD costs obtained from beneficiary countries

| EnC Contracting Parties/TPP/TPPs unit | Fuel | Unit(s) capacity, MW | SO ₂ in raw gas, mg/Nm ³ | Applied technology | Cost of FGD mil. € | Specific FGD cost, X1000 €/MW | Remark |
|---------------------------------------|------|----------------------|--|--------------------|--------------------|-------------------------------|--|
| Albania | | | | | | | |
| TPP Viora | N.G. | | | | N/A | N/A | N/A |
| Bosnia and Herzegovina | | | | | | | |
| TPP Ugljevik | BC | 300 | 16,200 | WLS | 95.0 | 317 | ELV≤200 |
| TPP Tuzla 6 | BC | 215 | 3,946 | SDA | 20.5 | 95 | ELV≤400 |
| TPP Kakanj 6 | BC | 110 | 8,600 | SDA | 15.5 | 141 | ELV≤1,080 |
| TPP Kakanj 6 | BC | 110 | 8,600 | WLS | 27.1 | 246 | ELV≤1,080 |
| TPP Kakanj 7 | BC | 230 | 8,600 | SDA | 27.1 | 118 | ELV≤516 |
| TPP Kakanj 7 | BC | 230 | 8,600 | WLS | 47.9 | 208 | ELV≤400 |
| Croatia | | | | | | | |
| | | | | | | | N/A |
| FYR Macedonia | | | | | | | |
| TPP Bitola | L | 3x225 | 3,900 | FWLS | 156 | 231 | ELV ≤200 |
| Oslomej | L | 125 | 4,100 | SDA | 13 | 104 | ELV<990 mg/Nm ³ |
| Moldova | | | | | | | |
| | | | | | | | N/A |
| Montenegro | | | | | | | |
| TPP Pljevlja | L | 220 | 600 | | | | Not provided |
| Serbia | | | | | | | |
| TPP Nikola Tesla A3- A6 | L | 305+308 308+308 | 2,000 | FWLS | 2x85 | 139 | ELV≤400, 2 FGD systems. Incomplete Assessed increased 15 % |
| TPP Nikola Tesla B | L | 2x650 | 2,001 | FWLS | 2x105 | 161 | Published June, 2009, EPS green book |
| Kostolac B1&B2 | L | 2x350 | 6,060 | FWLS | 2x43 | 138 | Incomplete. Missed gypsum handling system, WWTP etc. |
| Ukraine | | | | | | | |
| Prydniprovskia 11 | HC | 310 | 3,200 | NID | 13.3 | 43 | The value is not realistic |
| Orydniprovskia 13&14 | NC | 2x285 | 3,200 | NID | 2x13.3 | 47 | The value is not realistic |
| Starobeshivska5 to 13 | HC | 9x175 | | NID | 17.4 to 20.5 | 100 to 117 | Expected real values |
| Kosovo* | | | | | | | |
| TPP Kosovo B | L | 2x339 | 620 | SDA | 50-110 | 74-162 | |

The general impression is that the cost data provided by the beneficiary countries is lower than expected. In several cases, the beneficiaries elaborated more than one technical and economical document on the FGD issue. The preparation was done by the consulting companies engaged by the investor or by potential suppliers of equipment or/and services. The beneficiaries provided the lowest values.

In the case of TPP Kostolac B, Serbia, the project is contracted with a Chinese company. It is not complete, because it does not include gypsum handling system (transport and storage), waste water treatment plant, etc. By adding the missing costs to the existing ones, the complete costs can increase with approximately 10 to 15 %, but these costs will still be low.

d) **Costs to be used in this Study**

The values that were used in this Study are cost values for FGD systems in TPPs, which have been previously provided by the beneficiaries. In the cases where costs do not include the complete FGD system (FGD plant and all auxiliaries), the costs will be previously corrected, and will also include the corrections related to the time when the values were derived.

For LCPs for which the beneficiaries have not provided the data the curves in the Figure A2-3 have been used. These curves represent the curves of best fit generated for the cost values discussed above. The main base values for their generation were the data obtained as the result of the recent studies, i.e. technical and economical document which includes complete project cost:

1. 317,000 €/MW from the Feasibility study elaborated in 2008 for TPP Ugljevik, capacity 300 MW, SO₂ concentration in raw flue gas 16 200 mg/Nm³, and ELV = 400 mg/Nm³,
2. 210,000 €/MW from KEMA study elaborated in 2010 for TPP Kakanj 7, capacity 230 MW, SO₂ concentration in raw flue gas 8,600 mg/Nm³ and ELV = 400 mg/Nm³,
3. 185,000 €/MW from Yokogawa Electric Corporation study elaborated in 2012 for TPP Bitola, unit capacity 225 MW, SO₂ concentration in raw flue gas 3,900 mg/Nm³ and ELV = 400 mg/Nm³ and
4. 155,000 €/MW for unit capacity of 300 MW, SO₂ concentration in raw flue gas cca 2,500 mg/Nm³ and ELV = 400 mg/Nm³.

The above values can be applied to the wet limestone (WLS) technology including gypsum production and ELV = 400mg/Nm³. For ELV 200 mg/Nm³ the values to be used will be 10 % higher than for ELV = 400 mg/Nm³. For Spray drying FGD technology the cost value to be used in this study will be 60 % of the WLS technology.




Figure A2-3: Specific costs of FGD systems depending on the unit size and SO₂ concentration in raw flue gas

The shape of the curve, showing the WLS FGD system cost changes vs. TPP unit capacity, is taken from Hao Nguyen et al.²⁶

The operational costs are determined on the basis of analysis made by Ray Gansley²⁷ and KEMA²⁸. The most representative average values for operational costs of the WLS FGD system efficiency 98 % are:

- For concentration of SO₂ cca 9,000 mg/Nm³ 3,2 €/MWh
- For concentration of SO₂ cca 2,500 mg/Nm³ 1.9 €/MWh

Operational cost of the Spray drying (SD) technology for the same SO₂ concentration and removal efficiency is ca. 25 % higher than for WLS technology. For Semi dry NID technology, for the same SO₂ concentration and removal efficiency, the operational cost is ca. 30 % higher than for WLS technology.

A.2.5. NO_x reduction costs

The specific costs of DeNO_x techniques can vary significantly due to complexity of possible DeNO_x techniques, individual characteristics of thermal power plants, type of used fuel and country in which the technique is implemented.

²⁶ Hao Nguyen et al.: Analyses of Pollutant Control Costs in Coal based Electricity Generation, Technology Assessment Report 68, January 2008

²⁷ Ray Gansley: Wet FGD system Overview and Operation, Alstom, December 2008

²⁸ KEMA: Reducing Sulfur Dioxide and Nitrogen Oxides Emissions on TPP Kakanj, 2010

a) Data from references

In the SEEC study on the investments in environmental protection of South East Europe²⁹ the authors use the values of specific costs of different DeNO_x technologies undertaken by EPRI, Mitsui Babcock and Chubu, which are presented in Table A2-4 below.

Table A2-4: Specific costs of DeNO_x techniques

| Source | Technique | NO _x reduction (%) | Average retrofit capital cost (€/kW) | O&M cost (€/kWh) |
|-----------------------|-----------------|-------------------------------|--------------------------------------|----------------------|
| EPRI December 2000 | OFA | 15 – 30 | 5.7 | ~0.0005 [^] |
| | LNB | 40 – 60 | 15 | |
| | LNB + OFA | 50 – 70 | 22 | |
| Mitsui | LNB | 40 – 60 | 13.5 | |
| Chubu December 2000 | LNB | 30 | 4.1 | |
| | SNCR | 20 - 50 | 8.3 [^] | ~0.0004 [^] |
| Chubu E.P.Dec. 2000 | SCR Hot side | 50 – 80 | 66.5 | 0.0004 – 0.0012 |
| | Post FGD | 50 – 80 | 96 | |
| | SCR | < 90 | 42 - 53 | |

*Chubu/EPRI

In the Guidance document on control techniques for emissions of sulphur, NO_x, VOCs, dust (including PM₁₀, PM_{2.5} and black carbon) from stationary sources are shown indicative specific capital and O&M costs for different DeNO_x technologies, for EUROS 1999, Table A2-5.

Table A2-5: Efficiency and cost of the different DeNO_x technologies

| Control options | Typically achievable emission reduction | Process capacity (MWel) | Indicative capital cost €/kWel | Indicative operating cost €/kWh |
|----------------------------|---|-------------------------|--------------------------------|---------------------------------|
| SCR ¹ | 80-90% | Various | 30-70 ² | 11-14 €/kWel/a ³⁰ |
| SNCR | 30-50% | Various | 14 | 0.0011 |
| Re-burning (Fuel staging) | 50-75% | Various | 42 | 0.0011 |
| Flue gas recirculation | 15-45 ⁵ | Various | 14 | 0.00014 |
| Low NO _x Burner | 30-50 ⁵ | Various | 14 | 0 |

1 It should be noted that the design of SCR is highly site-specific and this makes definition of capital cost difficult

Robert Peltier in his Study on the air quality compliance³¹ presents the variation of surveyed cost categories by unit size. In this reference are identified the costs of construction labour, equipment, materials, and project management-engineering-construction management (including complete SCR system). In analyses were included 72 individual units totalling 41 GW (representing 39% of installed SCR systems in the U.S. by MW at the time of the study) owned by eight large utilities. They included Southern Company, Duke, TVA, Progress Energy, Constellation Energy, Ameren, Ontario Hydro, and AEP. The sample also reflected the distribution of installations in the U.S., so the survey results can be considered a valid top-level view of system costs. The larger units were installed earlier: the average unit size retrofit before 2003 was 623 MW, vs. 466 MW since 2003, what influenced on the results. The variations of the average cost were:

²⁹ SEEC: Development of power generation in South East Europe, Implication for investments in environmental protection, Belgrade, April, 2005

³⁰J. Theloke, et all, (2007): Maßnahmen zur Einhaltung der Emissionshöchstmengen der NEC Richtlinie, Umweltbundesamt

³¹ Robert Peltier: Air Quality Compliance, Latest Costs for SO₂ and NO_x Removal, June 13, 2009

- Units capacity <300 MW 125,000 €/MW
- Unit capacity 301-600 111,000 €/MW
- Unit capacity 601-900 93,000 €/MW.

b) Data obtained from the beneficiary countries

Data obtained from the beneficiary countries are shown in Table A2-6.

Table A2-6: List of the costs of DeNO_x techniques obtained from beneficiary countries

| EnC Contracting Party /TPP/TPPs unit | Fuel | Unit(s) capacity, MW | NO _x in raw gas, mg/Nm ³ | Applied technology | Cost of DeNO _x , mil. € | Specific DeNO _x cost, X1000 €/MW | Remark |
|--------------------------------------|------|----------------------|--|--------------------|------------------------------------|---|----------------------------|
| Albania | | | | | | | |
| TPP Viora | NG | | | | N/A | N/A | N/A |
| Bosnia and Herzegovina | | | | | | | |
| TPP Tuzla 3 | BC | 110 | 312 | LNB+OFA | | | |
| TPP Tuzla 4 | | 200 | 344 | LNB+OFA | 2.2 | 11.0 | |
| TPP Tuzla 5 | BC | 200 | 180 | LNB+OFA | 2.34 | 11.7 | |
| TPP Tuzla 6 | BC | 215 | 350 | LNB+OFA | 2.6 | 12.1 | ELV≤200 mg/Nm ³ |
| TPP Kakanj 5 | BC | 110 | 1,036 | | | | |
| TPP Kakanj 6 | BC | 110 | 747 | SCR | 13.6 | 123.5 | ELV≤600 mg/Nm ³ |
| TPP Kakanj 6 | BC | 110 | 747 | SCR+SNCR | 7.2 | 65.5 | ELV≤600 mg/Nm ³ |
| TPP Kakanj 7 | BC | 230 | 794 | SCR | 20.5 | 89.1 | ELV≤200 mg/Nm ³ |
| TPP Kakanj 7 | BC | 230 | 794 | SCR+SNCR | 10.9 | 47.4 | ELV≤200 mg/Nm ³ |
| Croatia | | | | | | | |
| Plomin 2 | HC | 210 | | LNB+SCR | 20.0 | 95.2 | ELV≤200 mg/Nm |
| FYR Macedonia | | | | | | | |
| TPP Bitola | L | 3x225 | 820 | SCR | 3x10 | 44,4 | |
| Oslomej | L | 125 | 360 | LNB+OFA | 6 | 48.0 | |
| Moldova | | | | | | | |
| | | | | | | | N/A |
| Montenegro | | | | | | | |
| TPP Pljevlja | L | 220 | 600 | | | | Not provided |
| Serbia | | | | | | | |
| TPP N. Tesla A3-A6 | L | 305+308 308+308 | 2,000 | | | | |
| TPP N. Tesala B | L | 2x650 | 2,001 | | | | |
| Kostolac B1&B2 | L | 2x350 | 6,060 | | | | |
| Ukraine | | | | | | | |
| Zaporiska 1 | HC | 325 | 1,550 | | | | |
| Dobrotviraska 7 | HC | 150 | 785 | SNCR | 2.2 | 14.7 | |
| Dobrotviraska | HC | 150 | 785 | SNCR | 2.3 | 15.3 | |
| Trypilska 2 | HC | 300 | | | | | |
| Zmivska 1 | HC | 175 | | | | | |
| Slovianska 7 | HC | 800 | | | | | |
| Kosovo* | | | | | | | |
| TPP Kosovo B | L | 2x339 | 620 | LNB+OFA+SNCR | 2x13 | 38.4 | |

c) Data used in this study

Capital costs of primary measures of the DeNO_x techniques are based on the data obtained from EPRI, CHUBU and Mitsui Babcock, presented as a function of NO_x reduction efficiency, and corrected to comply (as much as was possible) with the data obtained from beneficiary countries (the fact is that very limited amount of data was obtained from beneficiaries). Specific capital costs (€/kW) = 0.0643 x η^{1.462} where η is DeNO_x efficiency given in %.

O &M costs of primary measures are based on EPRI and CHUBU data and are assessed to be approximately 0.0006 EURO/kWh.

Capital costs of secondary measures: for SNCR the average capital costs is assessed to be about 10 EUR/kW, (actualized data of EPRI/Chubu).

For determination of the **specific capital costs for SCR** the authors of this study established the curves of the dependence of secondary measure cost versus unit size and NO_x removal efficiency presented in Figure A2-4. Usually the SCR technology is applied with LNB and in this case the capital cost can be lower for 10 to 15 %.

O&M costs of secondary measures: O&M costs depend on a number of factors such as the SCR arrangement, catalyst type, operating conditions such as flue gas volume, the required NO_x reduction, gas composition, flue gas temperature, operating hours per year, catalyst poisoning and others. Secondary DeNO_x measures are usually applied in combination with LNB and OFA. When the SCR is applied with LNB the capital and operational and maintenance costs are reduced from 12 to 15 % (H. Nguyen et al³⁰).




Figure A2-4: Specific capital cost of SCR system vs. TPP size and removal efficiency

For SCR the operational cost will be taken to vary linearly from 0.0006 €/kWh, at removal efficiency of 70 % to 0.0018 €/kWh for removal efficiency of 90 %. The costs are determined on the basis of the studies of SEEC³², as well as of the work of H. Nguyen et al.³³. For SNCR the cost is assessed to vary linearly from 0.0004 to 0.001 €/kWh depending on the removal efficiency (20-50 %).

³² SEEC: Development of power generation in South East Europe, Implication for investments in environmental protection, Belgrade, April, 2005

³³ Hao Nguyen et al.: Analyses of Pollutant Control Costs in Coal Based Electricity Generation, Technology Assessment Report 68, January 2008

Annex 3 European Union Directives - Environmental compliance costs

Table A3-1: Scenario 1 - LCPD compliance costs for Bosnia and Herzegovina

| Code | Plant name | Fuel type | Power MW | Energy GWh/a | LCPD Scenario | | | | | | |
|-------|------------|-----------|----------|--------------|-------------------------------|-----------------|-----------------|-------|-----------------------|-----------------|--------|
| | | | | | Investment costs /million € / | | | | O&M costs /000€/year/ | | |
| | | | | | Dust | NO _x | SO ₂ | Total | NO _x | SO ₂ | Total |
| 1 | Gacko | L | 300 | 1,934 | 11.4 | 9.0 | 13.0 | 33.4 | 2,579 | 4,110 | 6,689 |
| 2 | Ugljevik | L | 300 | 2,176 | 14.0 | 8.4 | 85.5 | 107.9 | 2,611 | 10,097 | 12,708 |
| 3 | Tuzla 3 | L | 110 | 473 | | | | | | | |
| 4 | Tuzla 4 | L | 200 | 1,196 | 1.0 | 3.0 | 18.0 | 22.0 | 717 | 2,741 | 3,459 |
| 5 | Tuzla 5 | L | 200 | 1,004 | 0.3 | 0.0 | 17.0 | 17.0 | 0 | 2,234 | 2,234 |
| 6 | Tuzla 6 | L | 215 | 1,008 | 5.0 | 2.6 | 39.0 | 46.6 | 605 | 2,206 | 2,811 |
| 7 | Kakanj 5 | L | 110 | 598 | 0.0 | 2.4 | 27.0 | 29.4 | 359 | 1,775 | 2,134 |
| 8 | Kakanj 6 | L | 110 | 312 | 0.0 | 2.4 | 20.0 | 22.4 | 94 | 920 | 1,014 |
| 9 | Kakanj 7 | L | 230 | 1,342 | 0.5 | 18.0 | 40.0 | 58.5 | 994 | 3,981 | 4,974 |
| Total | | | 1,775 | 10,044 | 31.9 | 45.8 | 259.5 | 337 | 7,959 | 28,064 | 36,022 |

Table A3-2: Scenario 2 - IED compliance costs for Bosnia and Herzegovina

| Code | Plant name | Fuel type | Power MW | Energy GWh/a | IED Scenario | | | | | | |
|-------|------------|-----------|----------|--------------|-------------------------------|-----------------|-----------------|-------|-----------------------|-----------------|--------|
| | | | | | Investment costs /million € / | | | | O&M costs /000€/year/ | | |
| | | | | | Dust | NO _x | SO ₂ | Total | NO _x | SO ₂ | Total |
| 1 | Gacko | L | 300 | 1,934 | 14.0 | 9.0 | 14.3 | 37.3 | 2,579 | 4,110 | 6,689 |
| 2 | Ugljevik | L | 300 | 2,176 | 15.0 | 8.4 | 95.0 | 118.4 | 2,611 | 10,097 | 12,708 |
| 3 | Tuzla 3 | L | 110 | 473 | | | | | | | |
| 4 | Tuzla 4 | L | 200 | 1,196 | 2.0 | 3.0 | 20.0 | 25.0 | 717 | 2,741 | 3,459 |
| 5 | Tuzla 5 | L | 200 | 1,004 | 1.0 | 0.0 | 19.0 | 20.0 | 0 | 2,234 | 2,234 |
| 6 | Tuzla 6 | L | 215 | 1,008 | 0.0 | 2.6 | 44.0 | 46.6 | 605 | 2,206 | 2,811 |
| 7 | Kakanj 5 | L | 110 | 598 | 0.0 | 6.2 | 30.0 | 36.2 | 966 | 1,775 | 2,741 |
| 8 | Kakanj 6 | L | 110 | 312 | 0.0 | 5.7 | 22.0 | 27.7 | 457 | 920 | 1,377 |
| 9 | Kakanj 7 | L | 230 | 1,342 | 1.5 | 18.0 | 44.0 | 63.5 | 2,008 | 3,981 | 5,988 |
| Total | | | 1,775 | 10,044 | 34 | 53 | 288 | 375 | 9,943 | 28,064 | 38,007 |

Table A3-3: Scenario 1 - LCPD compliance costs for Croatia

| Code | Plant name | Fuel type | Power MW | Energy GWh/a | LCPD Scenario | | | | | | |
|-------|---------------------|-----------|----------|--------------|-------------------------------|-----------------|-----------------|-------|-----------------------|-----------------|--------|
| | | | | | Investment costs /million € / | | | | O&M costs /000€/year/ | | |
| | | | | | Dust | NO _x | SO ₂ | Total | NO _x | SO ₂ | Total |
| 1 | TPP Plomin 1 | HC | 125 | 915 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 2 | TPP Plomin 2 | HC | 210 | 1,631 | 0.0 | 20.0 | 0.0 | 20.0 | 1,631 | 0 | 1,631 |
| 3 | TPP Rijeka | FO | 320 | 1,725 | 6.0 | 8.2 | 47.0 | 61.2 | 2,085 | 3,820 | 5,905 |
| 4 | TPP Sisak A | FO | 210 | 1,214 | 4.8 | 5.9 | 46.0 | 56.7 | 728 | 2,598 | 3,327 |
| 5 | TPP Sisak B | FO | 210 | 1,214 | 4.8 | 5.9 | 46.0 | 56.7 | 728 | 2,598 | 3,327 |
| 6 | TPP Jertovac 1 | NG | 40 | 47 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 7 | TPP Jertovac 2 | NG | 40 | 47 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 8 | CHP Zagreb C | NG | 120 | 469 | 2.7 | 2.8 | 19.0 | 24.5 | 281 | 1,003 | 1,284 |
| 9 | CHP Zagreb K | NG | 208 | 1,591 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 10 | CHP Zagreb L | NG | 112 | 866 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 11 | CHP Zagreb EL-TO K6 | NG | 11 | 21 | 1.0 | 0.5 | 3.0 | 4.5 | 6 | 56 | 63 |
| 12 | CHP Zagreb EL-TO K8 | NG | 30 | 82 | 1.1 | 0.3 | 3.0 | 4.4 | 24 | 217 | 242 |
| 13 | CHP Zagreb EL-TO H | NG | 25 | 161 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 14 | CHP Zagreb EL-TO J | NG | 25 | 161 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 15 | CHP Osijek A | NG | 46 | 256 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 16 | CHP Osijek B | NG | 25 | 42 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 17 | CHP Osijek C | NG | 25 | 21 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| Total | | | 1,782 | 10,464 | 20 | 44 | 164 | 228 | 5,486 | 10,293 | 15,779 |

Table A3-4: Scenario 2 - IED compliance costs for Croatia

| Code | Plant name | Fuel type | Power MW | Energy GWh/a | IED Scenario | | | | | | |
|------|----------------|-----------|----------|--------------|--------------------------------|-----------------|-----------------|-------|-----------------------|-----------------|-------|
| | | | | | Investment costs /mMillion € / | | | | O&M costs /000€/year/ | | |
| | | | | | Dust | NO _x | SO ₂ | Total | NO _x | SO ₂ | Total |
| 1 | TPP Plomin 1 | HC | 125 | 915 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 2 | TPP Plomin 2 | HC | 210 | 1,631 | 0.0 | 20.0 | 0.0 | 20.0 | 1,958 | 0 | 1,958 |
| 3 | TPP Rijeka | FO | 320 | 1,725 | 6.8 | 30.0 | 51.7 | 88.5 | 2,171 | 3,820 | 5,990 |
| 4 | TPP Sisak A | FO | 210 | 1,214 | 5.3 | 20.0 | 50.6 | 75.9 | 1,216 | 2,598 | 3,814 |
| 5 | TPP Sisak B | FO | 210 | 1,214 | 5.3 | 20.0 | 50.6 | 75.9 | 1,216 | 2,598 | 3,814 |
| 6 | TPP Jertovac 1 | NG | 40 | 47 | 0.0 | 1.0 | 0.0 | 1.0 | 28 | 0 | 28 |

| Code | Plant name | Fuel type | Power MW | Energy GWh/a | IED Scenario | | | | | | |
|-------|---------------------|-----------|----------|--------------|-------------------------------|-----------------|-----------------|-------|-----------------------|-----------------|--------|
| | | | | | Investment costs /mMillion €/ | | | | O&M costs /000€/year/ | | |
| | | | | | Dust | NO _x | SO ₂ | Total | NO _x | SO ₂ | Total |
| 7 | TPP Jertovac 2 | NG | 40 | 47 | 0.0 | 1.0 | 0.0 | 1.0 | 28 | 0 | 28 |
| 8 | CHP Zagreb C | NG | 120 | 469 | 3.0 | 12.5 | 21.0 | 36.5 | 557 | 1,003 | 1,560 |
| 9 | CHP Zagreb K | NG | 208 | 1,591 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 10 | CHP Zagreb L | NG | 112 | 866 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 11 | CHP Zagreb EL-TO K6 | NG | 11 | 21 | 1.1 | 1.0 | 5.0 | 7.1 | 6 | 45 | 52 |
| 12 | CHP Zagreb EL-TO K8 | NG | 30 | 82 | 1.2 | 1.0 | 6.0 | 8.2 | 24 | 174 | 198 |
| 13 | CHP Zagreb EL-TO H | NG | 25 | 161 | 0.0 | 0.7 | 0.0 | 0.7 | 97 | 0 | 97 |
| 14 | CHP Zagreb EL-TO J | NG | 25 | 161 | 0.0 | 0.7 | 0.0 | 0.7 | 97 | 0 | 97 |
| 15 | CHP Osijek A | NG | 46 | 256 | 0.0 | 1.3 | 0.0 | 1.3 | 154 | 0 | 154 |
| 16 | CHP Osijek B | NG | 25 | 42 | 0.0 | 0.7 | 0.0 | 0.7 | 25 | 0 | 25 |
| 17 | CHP Osijek C | NG | 25 | 21 | 0.0 | 0.7 | 0.0 | 0.7 | 13 | 0 | 13 |
| Total | | | 1,782 | 10,464 | 23 | 111 | 185 | 318 | 7,590 | 10,238 | 17,828 |

Table A3-5: Scenario 1 - LCPD compliance costs for FYR Macedonia

| Code | Plant name | Fuel type | Power MW | Energy GWh/a | LCPD Scenario | | | | | | |
|-------|------------|-----------|----------|--------------|------------------------------|-----------------|-----------------|-------|-----------------------|-----------------|--------|
| | | | | | Investment costs /million €/ | | | | O&M costs /000€/year/ | | |
| | | | | | Dust | NO _x | SO ₂ | Total | NO _x | SO ₂ | Total |
| 1 | Bitola 1 | L | 233 | 1,387 | 11.6 | 10.0 | 42.3 | 63.9 | 416 | 3,274 | 3,690 |
| 2 | Bitola 2 | L | 233 | 1,387 | 11.6 | 10.0 | 42.3 | 63.9 | 416 | 3,024 | 3,440 |
| 3 | Bitola 3 | L | 233 | 1,387 | 11.6 | 10.0 | 42.3 | 63.9 | 416 | 3,024 | 3,440 |
| 4 | Oslomej | L | 125 | 604 | 7.0 | 6.0 | 25.0 | 38.0 | 181 | 1,342 | 1,523 |
| 5 | Negotino | FO | 210 | 17 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| Total | | | 1,034 | 4,783 | 42 | 36 | 152 | 230 | 1,430 | 10,664 | 12,094 |

Table A3-6: Scenario 2 IED - compliance costs for FYR Macedonia

| Code | Plant name | Fuel type | Power MW | Energy GWh/a | IED Scenario | | | | | | |
|-------|------------|-----------|----------|--------------|------------------------------|-----------------|-----------------|-------|-----------------------|-----------------|--------|
| | | | | | Investment costs /million €/ | | | | O&M costs /000€/year/ | | |
| | | | | | Dust | NO _x | SO ₂ | Total | NO _x | SO ₂ | Total |
| 1 | Bitola 1 | L | 233 | 1,387 | 13.0 | 18.6 | 46.5 | 78.1 | 2,089 | 3,274 | 5,363 |
| 2 | Bitola 2 | L | 233 | 1,387 | 13.0 | 18.6 | 46.5 | 78.1 | 2,098 | 3,024 | 5,122 |
| 3 | Bitola 3 | L | 233 | 1,387 | 13.0 | 18.6 | 46.5 | 78.1 | 2,098 | 3,024 | 5,122 |
| 4 | Oslomej | L | 125 | 604 | 8.0 | 1.8 | 27.5 | 37.3 | 363 | 1,342 | 1,705 |
| 5 | Negotino | FO | 210 | 17 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| Total | | | 1,034 | 4,783 | 47 | 58 | 167 | 272 | 6,648 | 10,664 | 17,312 |

Table A3-7: Scenario 2 - IED compliance costs for Moldova

| Code | Plant name | Fuel type | Power MW | Energy GWh/a | IED Scenario | | | | | | |
|-------|-------------|-----------|----------|--------------|------------------------------|-----------------|-----------------|-------|-----------------------|-----------------|-------|
| | | | | | Investment costs /million €/ | | | | O&M costs /000€/year/ | | |
| | | | | | Dust | NO _x | SO ₂ | Total | NO _x | SO ₂ | Total |
| 1 | CET-1, No 1 | NG | 12 | 59 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 2 | CET-1, No 2 | NG | 12 | 59 | 0.0 | 0.1 | 0.0 | 0.1 | 18 | 0 | 18 |
| 3 | CET-1, No 3 | NG | 10 | 49 | 0.0 | 0.1 | 0.0 | 0.1 | 15 | 0 | 15 |
| 4 | CET-1, No 4 | NG | 27 | 132 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 5 | CET-1, No 5 | NG | 5 | 24 | 0.0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 |
| 6 | CET-2, No 1 | NG | 80 | 398 | 0.0 | 0.6 | 0.0 | 0.6 | 119 | 0 | 119 |
| 7 | CET-2, No 2 | NG | 80 | 371 | 0.0 | 0.6 | 0.0 | 0.6 | 111 | 0 | 111 |
| 8 | CET-2, No 3 | NG | 80 | 371 | 0.0 | 0.6 | 0.0 | 0.6 | 111 | 0 | 111 |
| Total | | | 306 | 1,463 | 0 | 2 | 0 | 2 | 374 | 0 | 374 |

Table A3-8: Scenario 1 LCPD - compliance costs for Montenegro

| Code | Plant name | Fuel type | Power MW | Energy GWh/a | LCPD Scenario | | | | | | |
|-------|------------|-----------|----------|--------------|------------------------------|-----------------|-----------------|-------|-----------------------|-----------------|-------|
| | | | | | Investment costs /million €/ | | | | O&M costs /000€/year/ | | |
| | | | | | Dust | NO _x | SO ₂ | Total | NO _x | SO ₂ | Total |
| 1 | Pljevlja | Lignite | 219 | 1,489 | 0.0 | 4.9 | 42.0 | 46.9 | 447 | 3,872 | 4,319 |
| Total | | | 219 | 1,489 | 0 | 5 | 42 | 47 | 447 | 3,872 | 4,319 |

Table A3-9: Scenario 2 - IED compliance Coasts for Montenegro

| Code | Plant name | Fuel type | Power MW | Energy GWh/a | IED Scenario | | | | | | |
|-------|------------|-----------|----------|--------------|------------------------------|-----------------|-----------------|-------|-----------------------|-----------------|-------|
| | | | | | Investment costs /million €/ | | | | O&M costs /000€/year/ | | |
| | | | | | Dust | NO _x | SO ₂ | Total | NO _x | SO ₂ | Total |
| 1 | Pljevlja | Lignite | 219 | 1,489 | 0 | 5 | 46 | 50.9 | 447 | 3,872 | 4,319 |
| Total | | | 219 | 1,489 | 0 | 5 | 46 | 51 | 447 | 3,872 | 4,319 |

Table A3-10: Scenario 1 - LCPD compliance costs for Serbia

| Code | Plant name | Fuel type | Power MW | Energy GWh/a | LCPD Scenario | | | | | | |
|-------|-----------------|-----------|----------|--------------|------------------------------|-----------------|-----------------|-------|-----------------------|-----------------|--------|
| | | | | | Investment costs /Million €/ | | | | O&M costs /000€/year/ | | |
| | | | | | Dust | NO _x | SO ₂ | Total | NO _x | SO ₂ | Total |
| 1 | Nikola Tesla A1 | L | 210 | 1,231 | 1.7 | 4.0 | 16.0 | 22 | 739 | 2,216 | 2,955 |
| 2 | Nikola Tesla A2 | L | 210 | 1,198 | 3.0 | 4.0 | 16.0 | 23 | 719 | 2,156 | 2,874 |
| 3 | Nikola Tesla A3 | L | 305 | 1,923 | 10.5 | 5.7 | 39.0 | 55 | 1,154 | 3,460 | 4,614 |
| 4 | Nikola Tesla A4 | L | 309 | 1,989 | 0.0 | 6.6 | 39.0 | 46 | 1,194 | 3,593 | 4,786 |
| 5 | Nikola Tesla A5 | L | 309 | 1,999 | 0.0 | 6.6 | 39.0 | 46 | 1,199 | 3,611 | 4,810 |
| 6 | Nikola Tesla A6 | L | 309 | 1,987 | 0.0 | 6.6 | 39.0 | 46 | 1,192 | 3,589 | 4,781 |
| 7 | Nikola Tesla B1 | L | 620 | 4,151 | 9.4 | 13.6 | 64.0 | 87 | 2,491 | 7,539 | 10,030 |
| 8 | Nikola Tesla B2 | L | 620 | 4,004 | 0.0 | 13.6 | 64.0 | 78 | 2,402 | 7,271 | 9,674 |
| 9 | Kolubara 1 | L | 32 | 175 | 1.7 | 0.0 | 0.0 | 2 | 0 | 0 | 0 |
| 10 | Kolubara 2 | L | 32 | 116 | 1.7 | 0.0 | 0.0 | 2 | 0 | 0 | 0 |
| 11 | Kolubara 3 | L | 64 | 135 | 3.2 | 0.0 | 5.0 | 8 | 0 | 317 | 317 |
| 12 | Kolubara 4 | L | 32 | 0 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 | 0 |
| 13 | Kolubara 5 | L | 110 | 626 | 0.0 | 0.0 | 8.6 | 9 | 0 | 1,468 | 1,468 |
| 14 | Morava | L | 125 | 566 | 7.2 | 0.0 | 9.8 | 17 | 0 | 1,541 | 1,541 |
| 15 | Kostolac A1 | L | 100 | 560 | 2.5 | 0.0 | 45.0 | 48 | 0 | 1,479 | 1,479 |
| 16 | Kostolac A2 | L | 210 | 1,196 | 5.4 | 4.2 | 0.0 | 10 | 718 | 3,154 | 3,872 |
| 17 | Kostolac B1 | L | 348 | 1,937 | 10.0 | 9.8 | 51.0 | 71 | 2,493 | 5,164 | 7,657 |
| 18 | Kostolac B2 | L | 348 | 1,895 | 5.7 | 9.1 | 51.0 | 66 | 2,307 | 4,835 | 7,142 |
| 19 | Novi Sad 1 | NG | 135 | 189 | 0.0 | 4.0 | 0.0 | 4 | 131 | 0 | 131 |
| 20 | Novi Sad 2 | NG | 110 | 175 | 0.0 | 3.3 | 0.0 | 3 | 121 | 0 | 121 |
| 21 | Zrenjanin | NG | 110 | 66 | 0.0 | 3.3 | 0.0 | 3 | 45 | 0 | 45 |
| 22 | Sr. Mitrovica 1 | NG | 32 | 123 | 0.0 | 1.0 | 0.0 | 1 | 74 | 0 | 74 |
| Total | | | 4,679 | 26,240 | 62 | 95 | 486 | 644 | 16,978 | 51,393 | 68,371 |

Table A3-11: Scenario 2 - IED compliance costs for Serbia

| Code | Plant name | Fuel type | Power MW | Energy GWh/a | IED Scenario | | | | | | |
|-------|-----------------|-----------|----------|--------------|------------------------------|-----------------|-----------------|-------|-----------------------|-----------------|--------|
| | | | | | Investment costs /million €/ | | | | O&M costs /000€/year/ | | |
| | | | | | Dust | NO _x | SO ₂ | Total | NO _x | SO ₂ | Total |
| 1 | Nikola Tesla A1 | L | 210 | 1,231 | 2.9 | 4.0 | 18.0 | 25 | 739 | 2,216 | 2,955 |
| 2 | Nikola Tesla A2 | L | 210 | 1,198 | 3.7 | 4.0 | 17.0 | 25 | 719 | 2,156 | 2,874 |
| 3 | Nikola Tesla A3 | L | 305 | 1,923 | 10.5 | 5.7 | 43.0 | 59 | 1,154 | 3,460 | 4,614 |
| 4 | Nikola Tesla A4 | L | 309 | 1,989 | 0.0 | 6.6 | 43.0 | 50 | 1,194 | 3,593 | 4,786 |
| 5 | Nikola Tesla A5 | L | 309 | 1,999 | 0.0 | 6.6 | 43.0 | 50 | 1,199 | 3,611 | 4,810 |
| 6 | Nikola Tesla A6 | L | 309 | 1,987 | 0.0 | 6.6 | 43.0 | 50 | 1,192 | 3,589 | 4,781 |
| 7 | Nikola Tesla B1 | L | 620 | 4,151 | 9.4 | 13.6 | 71.0 | 94 | 2,491 | 7,539 | 10,030 |
| 8 | Nikola Tesla B2 | L | 620 | 4,004 | 0.0 | 13.6 | 71.0 | 85 | 2,402 | 7,271 | 9,674 |
| 9 | Kolubara 1 | L | 32 | 175 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 | 0 |
| 10 | Kolubara 2 | L | 32 | 116 | 0.0 | 0.0 | 0.0 | 0 | 0 | 0 | 0 |
| 11 | Kolubara 3 | L | 64 | 135 | 3.6 | 0.8 | 7.0 | 11 | 40.4 | 254 | 294 |
| 12 | Kolubara 4 | L | 32 | 0 | 0.0 | 0.0 | 0.0 | 0 | 0.0 | 0 | 0 |
| 13 | Kolubara 5 | L | 110 | 626 | 0.4 | 2.2 | 9.5 | 12 | 375.8 | 1,175 | 1,550 |
| 14 | Morava | L | 125 | 566 | 8.0 | 3.4 | 11.0 | 22 | 0.0 | 1,233 | 1,233 |
| 15 | Kostolac A1 | L | 100 | 560 | 2.8 | 2.0 | 50.0 | 55 | 335.9 | 1,479 | 1,815 |
| 16 | Kostolac A2 | L | 210 | 1,196 | 5.9 | 4.2 | 0.0 | 10 | 717.8 | 3,154 | 3,872 |
| 17 | Kostolac B1 | L | 348 | 1,937 | 11.0 | 9.8 | 55.0 | 76 | 0.0 | 5,164 | 5,164 |
| 18 | Kostolac B2 | L | 348 | 1,895 | 6.5 | 9.1 | 55.0 | 71 | 2,306.6 | 4,835 | 7,142 |
| 19 | Novi Sad 1 | NG | 135 | 189 | 0.0 | 5.9 | 0.0 | 6 | 554.1 | 0 | 554 |
| 20 | Novi Sad 2 | NG | 110 | 175 | 0.0 | 4.8 | 0.0 | 5 | 513.0 | 0 | 513 |
| 21 | Zrenjanin | NG | 110 | 66 | 0.0 | 4.8 | 0.0 | 5 | 96.2 | 0 | 96 |
| 22 | Sr. Mitrovica 1 | NG | 32 | 123 | 0.0 | 1.8 | 0.0 | 2 | 73.6 | 0 | 74 |
| Total | | | 4,679 | 26,240 | 65 | 110 | 537 | 711 | 16,103 | 50,728 | 66,830 |

Table A3-12: Scenario 1 - LCPD compliance costs for Ukraine

| Code | Plant name | Fuel type | Power MW | Energy GWh/a | LCPD Scenario | | | | | | |
|------|-------------------|-----------|----------|--------------|------------------------------|-----------------|-----------------|-------|-----------------------|-----------------|-------|
| | | | | | Investment costs /Million €/ | | | | O&M costs /000€/year/ | | |
| | | | | | Dust | NO _x | SO ₂ | Total | NO _x | SO ₂ | Total |
| 1 | Prydniprovsk 7 | HC | 150 | 439 | 5 | 13 | 17 | 35 | 439 | 1,113 | 1,552 |
| 2 | Prydniprovsk 8 | HC | 150 | 682 | 5 | 13 | 17 | 35 | 682 | 1,774 | 2,456 |
| 3 | Prydniprovsk 9 | HC | 150 | 0 | 2 | 13 | 17 | 32 | 0 | 0 | 0 |
| 4 | Prydniprovsk 10 | HC | 150 | 590 | 5 | 12 | 17 | 34 | 590 | 1,482 | 2,072 |
| 5 | Prydniprovsk 11 | HC | 310 | 1,186 | 9 | 24 | 36 | 69 | 1,186 | 3,068 | 4,253 |
| 6 | Prydniprovsk 12 | HC | 285 | 0 | 9 | 24 | 33 | 65 | 0 | 0 | 0 |
| 7 | Prydniprovsk 13 | HC | 285 | 774 | 12 | 24 | 33 | 68 | 774 | 1,967 | 2,741 |
| 8 | Prydniprovsk 14 | HC | 285 | 0 | 12 | 24 | 33 | 68 | 0 | 0 | 0 |
| 9 | Kryvorizka 1 | HC | 282 | 1,106 | 6 | 24 | 32 | 62 | 1,106 | 2,942 | 4,047 |
| 10 | Kryvorizka 2 | HC | 282 | 1,382 | 8 | 24 | 32 | 65 | 1,382 | 3,691 | 5,073 |
| 11 | Kryvorizka 3 | HC | 282 | 0 | 0 | 24 | 34 | 58 | 0 | 0 | 0 |
| 12 | Kryvorizka 4 | HC | 282 | 1,221 | 2 | 24 | 32 | 59 | 1,221 | 3,242 | 4,463 |
| 13 | Kryvorizka 5 | HC | 282 | 1,221 | 6 | 25 | 32 | 63 | 1,221 | 3,294 | 4,515 |
| 14 | Kryvorizka 6 | HC | 282 | 714 | 8 | 25 | 32 | 65 | 714 | 1,935 | 2,650 |
| 15 | Kryvorizka 7 | HC | 282 | 0 | 7 | 25 | 32 | 64 | 0 | 0 | 0 |
| 16 | Kryvorizka 8 | HC | 282 | 1,014 | 7 | 25 | 32 | 64 | 1,014 | 2,750 | 3,763 |
| 17 | Kryvorizka 9 | HC | 282 | 0 | 6 | 25 | 32 | 63 | 0 | 0 | 0 |
| 18 | Kryvorizka 10 | HC | 282 | 1,198 | 7 | 25 | 32 | 64 | 1,198 | 3,250 | 4,448 |
| 19 | Zaporiska 1 | HC | 325 | 1,048 | 0 | 29 | 37 | 66 | 1,048 | 2,839 | 3,887 |
| 20 | Zaporiska 2 | HC | 300 | 1,277 | 9 | 26 | 35 | 70 | 1,277 | 3,492 | 4,768 |
| 21 | Zaporiska 3 | HC | 300 | 1,301 | 6 | 26 | 35 | 66 | 1,301 | 3,606 | 4,907 |
| 22 | Zaporiska 4 | HC | 300 | 1,205 | 9 | 27 | 35 | 70 | 1,205 | 3,294 | 4,499 |
| 23 | Zaporiska 5 | NG | 800 | 0 | 0 | 24 | 0 | 24 | 0 | 0 | 0 |
| 24 | Zaporiska 6 | NG | 800 | 0 | 0 | 25 | 0 | 25 | 0 | 0 | 0 |
| 25 | Zaporiska 7 | NG | 800 | 0 | 0 | 26 | 0 | 26 | 0 | 0 | 0 |
| 26 | Starobeshivska 4 | HC | 175 | 715 | 5 | 2.0 | 20 | 25 | 429 | 1,252 | 1,681 |
| 27 | Starobeshivska 5 | HC | 175 | 715 | 16 | 4 | 20 | 40 | 930 | 1,252 | 2,181 |
| 28 | Starobeshivska 6 | HC | 175 | 715 | 14 | 4 | 20 | 38 | 930 | 1,252 | 2,181 |
| 29 | Starobeshivska 7 | HC | 175 | 715 | 14 | 4 | 20 | 37 | 930 | 1,252 | 2,181 |
| 30 | Starobeshivska 8 | HC | 175 | 715 | 14 | 4 | 20 | 37 | 930 | 1,252 | 2,181 |
| 31 | Starobeshivska 9 | HC | 175 | 715 | 15 | 4 | 20 | 38 | 930 | 1,252 | 2,181 |
| 32 | Starobeshivska 10 | HC | 175 | 715 | 16 | 4 | 20 | 39 | 930 | 1,252 | 2,181 |
| 33 | Starobeshivska 11 | HC | 175 | 715 | 16 | 4 | 20 | 39 | 930 | 1,252 | 2,181 |
| 34 | Starobeshivska 12 | HC | 175 | 715 | 10 | 4 | 20 | 34 | 930 | 1,252 | 2,181 |
| 35 | Starobeshivska 13 | HC | 175 | 715 | 8 | 4 | 20 | 32 | 930 | 1,252 | 2,181 |
| 36 | Slovianska 7 | HC | 800 | 3,269 | 22 | 52 | 95 | 169 | 4,250 | 5,721 | 9,971 |
| 37 | Burshtynska 1 | HC | 195 | 915 | 5 | 6 | 25 | 36 | 1,209 | 2,590 | 3,800 |
| 38 | Burshtynska 2 | HC | 185 | 397 | 5 | 5 | 24 | 34 | 523 | 1,121 | 1,644 |
| 39 | Burshtynska 3 | HC | 185 | 662 | 5 | 5 | 24 | 34 | 851 | 1,874 | 2,725 |
| 40 | Burshtynska 4 | HC | 195 | 884 | 5 | 5 | 25 | 36 | 1,153 | 2,519 | 3,672 |
| 41 | Burshtynska 5 | HC | 195 | 465 | 8 | 5 | 26 | 39 | 598 | 1,351 | 1,949 |
| 42 | Burshtynska 6 | HC | 185 | 986 | 5 | 5 | 24 | 34 | 1,242 | 2,811 | 4,053 |
| 43 | Burshtynska 7 | HC | 185 | 508 | 5 | 5 | 24 | 34 | 671 | 1,484 | 2,156 |
| 44 | Burshtynska 8 | HC | 195 | 806 | 8 | 5 | 26 | 39 | 1,052 | 2,393 | 3,444 |
| 45 | Burshtynska 9 | HC | 195 | 961 | 5 | 6 | 25 | 36 | 1,282 | 2,712 | 3,993 |
| 46 | Burshtynska 10 | HC | 195 | 930 | 5 | 6 | 25 | 36 | 1,251 | 2,637 | 3,887 |
| 47 | Burshtynska 11 | HC | 195 | 992 | 5 | 5 | 25 | 35 | 1,191 | 2,798 | 3,989 |
| 48 | Burshtynska 12 | HC | 195 | 667 | 2 | 5 | 25 | 32 | 811 | 1,884 | 2,695 |
| 49 | Dobrotvirska 5 | HC | 100 | 402 | 3 | 1 | 11 | 15 | 241 | 1,178 | 1,419 |
| 50 | Dobrotvirska 6 | HC | 100 | 402 | 3 | 1 | 11 | 15 | 241 | 1,178 | 1,419 |
| 51 | Dobrotvirska 7 | HC | 150 | 786 | 6 | 13 | 17 | 35 | 471 | 2,377 | 2,848 |
| 52 | Dobrotvirska 8 | HC | 150 | 568 | 8 | 13 | 17 | 37 | 341 | 1,719 | 2,060 |
| 53 | Ladyzhinska 1 | HC | 300 | 874 | 8 | 24 | 33 | 65 | 874 | 2,228 | 3,101 |
| 54 | Ladyzhinska 2 | HC | 300 | 1,092 | 7 | 24 | 33 | 64 | 1,092 | 2,812 | 3,904 |
| 55 | Ladyzhinska 3 | HC | 300 | 1,262 | 7 | 24 | 33 | 64 | 1,262 | 3,290 | 4,552 |
| 56 | Ladyzhinska 4 | HC | 300 | 752 | 7 | 24 | 33 | 64 | 752 | 1,931 | 2,684 |
| 57 | Ladyzhinska 5 | HC | 300 | 582 | 7 | 24 | 33 | 64 | 582 | 1,516 | 2,098 |
| 58 | Ladyzhinska 6 | HC | 300 | 558 | 7 | 24 | 33 | 64 | 558 | 1,446 | 2,005 |
| 59 | Trypilska 1 | HC | 300 | 1,250 | 11 | 22 | 31 | 64 | 1250 | 3,009 | 4260 |
| 60 | Trypilska 2 | HC | 300 | 1,250 | 9 | 23 | 31 | 63 | 1250 | 3,026 | 4277 |
| 61 | Trypilska 3 | HC | 300 | 1,250 | 11 | 22 | 31 | 64 | 1250 | 3,004 | 4255 |

| Code | Plant name | Fuel type | Power MW | Energy GWh/a | LCPD Scenario | | | | | | |
|-------|--------------------|-----------|----------|--------------|------------------------------|-----------------|-----------------|-------|-----------------------|-----------------|---------|
| | | | | | Investment costs /Million €/ | | | | O&M costs /000€/year/ | | |
| | | | | | Dust | NO _x | SO ₂ | Total | NO _x | SO ₂ | Total |
| 62 | Trypilska 4 | HC | 300 | 1,250 | 11 | 22 | 31 | 64 | 1,250 | 3,014 | 4,264 |
| 63 | Trypilska 5 | NG | 300 | 0 | 0 | 22 | 0 | 22 | 0 | 0 | 0 |
| 64 | Trypilska 6 | NG | 300 | 0 | 0 | 22 | 0 | 22 | 0 | 0 | 0 |
| 65 | Zmiivska 1 | HC | 175 | 548 | 9 | 25 | 19 | 53 | 548 | 1,353 | 1,900 |
| 66 | Zmiivska 2 | HC | 175 | 548 | 0 | 25 | 19 | 44 | 548 | 1,341 | 1,889 |
| 67 | Zmiivska 3 | HC | 175 | 548 | 12 | 25 | 19 | 55 | 548 | 1,348 | 1,895 |
| 68 | Zmiivska 4 | HC | 175 | 548 | 0 | 25 | 19 | 44 | 548 | 1,343 | 1,891 |
| 69 | Zmiivska 5 | HC | 175 | 548 | 12 | 25 | 19 | 55 | 548 | 1,363 | 1,911 |
| 70 | Zmiivska 6 | HC | 175 | 548 | 0 | 25 | 19 | 44 | 548 | 1,316 | 1,863 |
| 71 | Zmiivska 7 | HC | 275 | 793 | 9 | 27 | 32 | 67 | 793 | 2,126 | 2,918 |
| 72 | Zmiivska 8 | HC | 325 | 937 | 9 | 28 | 38 | 75 | 937 | 2,882 | 3,819 |
| 73 | Zmiivska 9 | HC | 275 | 793 | 9 | 25 | 32 | 65 | 793 | 2,113 | 2,905 |
| 74 | Zmiivska 10 | HC | 275 | 793 | 9 | 25 | 33 | 67 | 793 | 2,061 | 2,853 |
| 75 | Vuglegirska 1 | HC | 300 | 1,359 | 9 | 24 | 35 | 69 | 1,359 | 3,967 | 5,326 |
| 76 | Vuglegirska 2 | HC | 300 | 1,359 | 9 | 24 | 35 | 69 | 1,359 | 3,967 | 5,326 |
| 77 | Vuglegirska 3 | HC | 300 | 1,359 | 9 | 24 | 35 | 69 | 1,359 | 3,967 | 5,326 |
| 78 | Vuglegirska 4 | HC | 300 | 1,359 | 9 | 24 | 35 | 69 | 1,359 | 3,967 | 5,326 |
| 79 | Vuglegirska 5 | NG | 800 | 0 | 0 | 65 | 0 | 65 | 0 | 0 | 0 |
| 80 | Vuglegirska 6 | NG | 800 | 0 | 0 | 65 | 0 | 65 | 0 | 0 | 0 |
| 81 | Vuglegirska 7 | NG | 800 | 0 | 0 | 65 | 0 | 65 | 0 | 0 | 0 |
| 82 | Zuevvskaia 1 | HC | 325 | 1,606 | 10 | 28 | 38 | 75 | 1,606 | 4,854 | 6,460 |
| 83 | Zuevvskaia 2 | HC | 320 | 1,660 | 10 | 28 | 38 | 75 | 1,660 | 5,010 | 6,670 |
| 84 | Zuevvskaia 3 | HC | 300 | 1,606 | 10 | 25 | 37 | 72 | 1,606 | 4,729 | 6,335 |
| 85 | Zuevvskaia 4 | HC | 325 | 1,740 | 0 | 26 | 38 | 64 | 1,740 | 5,136 | 6,875 |
| 86 | Kurakhovskaya 3 | HC | 200 | 1,005 | 10 | 6 | 23 | 40 | 1,407 | 2,951 | 4,358 |
| 87 | Kurakhovskaya 4 | HC | 210 | 1,003 | 8 | 7 | 25 | 39 | 1,410 | 2,974 | 4,384 |
| 88 | Kurakhovskaya 5 | HC | 222 | 969 | 10 | 7 | 26 | 43 | 1,341 | 2,916 | 4,257 |
| 89 | Kurakhovskaya 6 | HC | 210 | 640 | 6 | 6 | 25 | 36 | 859 | 1,897 | 2,756 |
| 90 | Kurakhovskaya 7 | HC | 225 | 982 | 10 | 7 | 26 | 43 | 1,361 | 2,855 | 4,216 |
| 91 | Kurakhovskaya 8 | HC | 210 | 674 | 0 | 6 | 25 | 31 | 921 | 2,006 | 2,928 |
| 92 | Kurakhovskaya 9 | HC | 221 | 1,019 | 10 | 6 | 26 | 42 | 1,355 | 3,022 | 4,377 |
| 93 | Luganskaya 9 | HC | 200 | 1,070 | 8 | 17 | 23 | 49 | 1,070 | 2,850 | 3,921 |
| 94 | Luganskaya 10 | HC | 200 | 642 | 0 | 17 | 23 | 40 | 642 | 1,687 | 2,329 |
| 95 | Luganskaya 11 | HC | 200 | 988 | 11 | 17 | 23 | 52 | 988 | 2,617 | 3,605 |
| 96 | Luganskaya 12 | HC | 175 | 0 | 5 | 4 | 20 | 29 | 0 | 0 | 0 |
| 97 | Luganskaya 13 | HC | 175 | 951 | 7 | 16 | 20 | 43 | 571 | 2,591 | 3,162 |
| 98 | Luganskaya 14 | HC | 200 | 1,070 | 8 | 17 | 23 | 49 | 1,070 | 2,905 | 3,976 |
| 99 | Luganskaya 15 | HC | 200 | 988 | 10 | 17 | 23 | 51 | 988 | 2,707 | 3,696 |
| 100 | Bilotserkivska CHP | NG | 120 | 494 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 101 | Darnytska CHP 5,10 | NG | 50 | 212 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 102 | Darnytska CHP 6-9 | HC | 110 | 453 | 2 | 2 | 0 | 5 | 272 | 1,059 | 1,330 |
| 103 | Kaluska CHP 1, 2 | HC | 100 | 412 | 3 | 0 | 8 | 11 | 0 | 988 | 988 |
| 104 | Kaluska CHP 3, 4 | NG | 100 | 425 | 0 | 0 | 0 | 0 | 127 | 0 | 127 |
| 105 | Kyivska CHP-5 | NG | 540 | 1,147 | 0 | 9 | 0 | 9 | 688 | 0 | 688 |
| 105a | Kyivska CHP-5 | FO | 540 | 1,147 | 0 | 9 | 0 | 9 | 688 | 0 | 688 |
| 106 | Kyivska CHP-6 | NG | 500 | 1,062 | 0 | 8 | 0 | 8 | 637 | 0 | 637 |
| 106a | Kyivska CHP-6 | FO | 500 | 1,062 | 0 | 10 | 9 | 19 | 637 | 0 | 637 |
| 107 | Kramatorska CHP | HC | 120 | 494 | 5* | 0 | 11 | 11 | 0 | 1,288 | 1,288 |
| 108 | Myronivska 4 | HC | 60 | 247 | 2 | 0 | 4 | 6 | 0 | 642 | 642 |
| 109 | Myronivska 9 | HC | 115 | 616 | 4 | 0 | 9 | 13 | 185 | 1,504 | 1,689 |
| 110 | Odeska CHP-2 | NG | 68 | 289 | 0 | 2 | 0 | 2 | 173 | 0 | 173 |
| 111 | Sevastopolska CHP | NG | 55 | 234 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 112 | Simferopilska CHP | NG | 278 | 1,181 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 113 | Kharkivska CHP-2 | HC | 74 | 314 | 2 | 2 | 9 | 13 | 189 | 995 | 1,184 |
| Total | | | 29,368 | 88,669 | 709 | 1,871 | 2,558 | 5,139 | 88,879 | 213,173 | 302,053 |

Table A3-13: Scenario 2 - IED compliance costs for Ukraine

| Code | Plant name | Fuel type | Power MW | Energy GWh/a | IED Scenario | | | | | | |
|------|-------------------|-----------|----------|--------------|-------------------------------|-----------------|-----------------|-------|-----------------------|-----------------|-------|
| | | | | | Investment costs /mMillion €/ | | | | O&M costs /000€/year/ | | |
| | | | | | Dust | NO _x | SO ₂ | Total | NO _x | SO ₂ | Total |
| 1 | Prydniprovsk 7 | HC | 150 | 439 | 5 | 14 | 19 | 38 | 513 | 1,113 | 1,625 |
| 2 | Prydniprovsk 8 | HC | 150 | 682 | 5 | 14 | 19 | 38 | 823 | 1,774 | 2,597 |
| 3 | Prydniprovsk 9 | HC | 150 | 0 | 2 | 14 | 19 | 36 | 0 | 0 | 0 |
| 4 | Prydniprovsk 10 | HC | 150 | 590 | 5 | 14 | 19 | 38 | 680 | 1,482 | 2,162 |
| 5 | Prydniprovsk 11 | HC | 310 | 1,186 | 11 | 26 | 39 | 77 | 1,449 | 3,068 | 4,517 |
| 6 | Prydniprovsk 12 | HC | 285 | 0 | 10 | 24 | 36 | 70 | 0 | 0 | 0 |
| 7 | Prydniprovsk 13 | HC | 285 | 774 | 14 | 24 | 36 | 74 | 960 | 1,967 | 2,927 |
| 8 | Prydniprovsk 14 | HC | 285 | 0 | 14 | 24 | 36 | 74 | 0 | 0 | 0 |
| 9 | Kryvorizka 1 | HC | 282 | 1,106 | 7 | 24 | 36 | 67 | 1,410 | 2,942 | 4,352 |
| 10 | Kryvorizka 2 | HC | 282 | 1,382 | 10 | 24 | 36 | 70 | 1,791 | 3,691 | 5,482 |
| 11 | Kryvorizka 3 | HC | 282 | 0 | 1 | 24 | 36 | 61 | 0 | 0 | 0 |
| 12 | Kryvorizka 4 | HC | 282 | 1,221 | 3 | 24 | 36 | 63 | 1,611 | 3,242 | 4,853 |
| 13 | Kryvorizka 5 | HC | 282 | 1,221 | 7 | 25 | 36 | 68 | 1,633 | 3,294 | 4,927 |
| 14 | Kryvorizka 6 | HC | 282 | 714 | 10 | 25 | 36 | 70 | 979 | 1,935 | 2,915 |
| 15 | Kryvorizka 7 | HC | 282 | 0 | 9 | 25 | 36 | 69 | 0 | 0 | 0 |
| 16 | Kryvorizka 8 | HC | 282 | 1,014 | 9 | 25 | 36 | 69 | 1,395 | 2,750 | 4,145 |
| 17 | Kryvorizka 9 | HC | 282 | 0 | 7 | 25 | 36 | 67 | 0 | 0 | 0 |
| 18 | Kryvorizka 10 | HC | 282 | 1,198 | 9 | 25 | 36 | 69 | 1,649 | 3,250 | 4,898 |
| 19 | Zaporiska 1 | HC | 325 | 1,048 | 1 | 29 | 41 | 70 | 1,419 | 2,839 | 4,259 |
| 20 | Zaporiska 2 | HC | 300 | 1,277 | 10 | 26 | 38 | 74 | 1,697 | 3,492 | 5,188 |
| 21 | Zaporiska 3 | HC | 300 | 1,301 | 6 | 26 | 38 | 70 | 1,725 | 3,606 | 5,331 |
| 22 | Zaporiska 4 | HC | 300 | 1,205 | 10 | 27 | 38 | 75 | 1,656 | 3,294 | 4,950 |
| 23 | Zaporiska 5 | NG | 800 | 0 | 0 | 24 | 0 | 24 | 0 | 0 | 0 |
| 24 | Zaporiska 6 | NG | 800 | 0 | 0 | 25 | 0 | 25 | 0 | 0 | 0 |
| 25 | Zaporiska 7 | NG | 800 | 0 | 0 | 26 | 0 | 26 | 0 | 0 | 0 |
| 26 | Starobeshivska 4 | HC | 175 | 715 | 5 | 30 | 22 | 57 | 930 | 1,252 | 2,181 |
| 27 | Starobeshivska 5 | HC | 175 | 715 | 18 | 28 | 22 | 68 | 930 | 1,252 | 2,181 |
| 28 | Starobeshivska 6 | HC | 175 | 715 | 16 | 28 | 22 | 66 | 930 | 1,252 | 2,181 |
| 29 | Starobeshivska 7 | HC | 175 | 715 | 15 | 28 | 22 | 65 | 930 | 1,252 | 2,181 |
| 30 | Starobeshivska 8 | HC | 175 | 715 | 15 | 28 | 22 | 65 | 930 | 1,252 | 2,181 |
| 31 | Starobeshivska 9 | HC | 175 | 715 | 16 | 28 | 22 | 66 | 930 | 1,252 | 2,181 |
| 32 | Starobeshivska 10 | HC | 175 | 715 | 17 | 28 | 22 | 67 | 930 | 1,252 | 2,181 |
| 33 | Starobeshivska 11 | HC | 175 | 715 | 17 | 28 | 22 | 67 | 930 | 1,252 | 2,181 |
| 34 | Starobeshivska 12 | HC | 175 | 715 | 11 | 28 | 22 | 61 | 930 | 1,252 | 2,181 |
| 35 | Starobeshivska 13 | HC | 175 | 715 | 9 | 28 | 22 | 59 | 930 | 1,252 | 2,181 |
| 36 | Slovianska 7 | HC | 800 | 3,269 | 25 | 52 | 104 | 181 | 4,250 | 5,721 | 9,971 |
| 37 | Burshtynska 1 | HC | 195 | 915 | 6 | 6 | 28 | 39 | 1,209 | 2,590 | 3,800 |
| 38 | Burshtynska 2 | HC | 185 | 397 | 5 | 5 | 26 | 37 | 523 | 1,121 | 1,644 |
| 39 | Burshtynska 3 | HC | 185 | 662 | 5 | 5 | 26 | 36 | 851 | 1,874 | 2,725 |
| 40 | Burshtynska 4 | HC | 195 | 884 | 6 | 5 | 28 | 39 | 1,153 | 2,519 | 3,672 |
| 41 | Burshtynska 5 | HC | 195 | 465 | 8 | 5 | 28 | 41 | 598 | 1,351 | 1,949 |
| 42 | Burshtynska 6 | HC | 185 | 986 | 5 | 5 | 26 | 36 | 1,242 | 2,811 | 4,053 |
| 43 | Burshtynska 7 | HC | 185 | 508 | 5 | 5 | 26 | 37 | 671 | 1,484 | 2,156 |
| 44 | Burshtynska 8 | HC | 195 | 806 | 8 | 5 | 29 | 42 | 1,052 | 2,393 | 3,444 |
| 45 | Burshtynska 9 | HC | 195 | 961 | 6 | 6 | 28 | 39 | 1,282 | 2,712 | 3,993 |
| 46 | Burshtynska 10 | HC | 195 | 930 | 6 | 6 | 28 | 39 | 1,251 | 2,637 | 3,887 |
| 47 | Burshtynska 11 | HC | 195 | 992 | 6 | 5 | 28 | 38 | 1,191 | 2,798 | 3,989 |
| 48 | Burshtynska 12 | HC | 195 | 667 | 3 | 5 | 28 | 35 | 811 | 1,884 | 2,695 |
| 49 | Dobrotvirska 5 | HC | 100 | 402 | 4 | 10 | 24 | 38 | 285 | 1,178 | 1,463 |
| 50 | Dobrotvirska 6 | HC | 100 | 402 | 4 | 10 | 0 | 14 | 285 | 1,178 | 1,463 |
| 51 | Dobrotvirska 7 | HC | 150 | 786 | 6 | 13 | 37 | 56 | 571 | 2,377 | 2,948 |
| 52 | Dobrotvirska 8 | HC | 150 | 568 | 8 | 13 | 0 | 21 | 413 | 1,719 | 2,131 |
| 53 | Ladyzhinska 1 | HC | 300 | 874 | 10 | 25 | 36 | 72 | 1,068 | 2,228 | 3,296 |
| 54 | Ladyzhinska 2 | HC | 300 | 1,092 | 9 | 25 | 36 | 70 | 1,333 | 2,812 | 4,145 |
| 55 | Ladyzhinska 3 | HC | 300 | 1,262 | 9 | 25 | 36 | 70 | 1,545 | 3,290 | 4,836 |
| 56 | Ladyzhinska 4 | HC | 300 | 752 | 9 | 25 | 36 | 70 | 915 | 1,931 | 2,846 |
| 57 | Ladyzhinska 5 | HC | 300 | 582 | 9 | 25 | 36 | 70 | 709 | 1,516 | 2,225 |
| 58 | Ladyzhinska 6 | HC | 300 | 558 | 9 | 25 | 36 | 70 | 682 | 1,446 | 2,129 |
| 59 | Trypilska 1 | HC | 300 | 1,250 | 13 | 22 | 34 | 70 | 802 | 3,009 | 3,811 |
| 60 | Trypilska 2 | HC | 300 | 1,250 | 11 | 23 | 34 | 68 | 1,288 | 3,026 | 4,314 |
| 61 | Trypilska 3 | HC | 300 | 1,250 | 13 | 22 | 34 | 70 | 829 | 3,004 | 3,833 |

| Code | Plant name | Fuel type | Power MW | Energy GWh/a | IED Scenario | | | | | | |
|-------|--------------------|-----------|----------|--------------|-------------------------------|-----------------|-----------------|-------|-----------------------|-----------------|---------|
| | | | | | Investment costs /mMillion €/ | | | | O&M costs /000€/year/ | | |
| | | | | | Dust | NO _x | SO ₂ | Total | NO _x | SO ₂ | Total |
| 62 | Trypilska 4 | HC | 300 | 1,250 | 13 | 22 | 34 | 70 | 809 | 3,014 | 3,822 |
| 63 | Trypilska 5 | NG | 300 | 0 | 0 | 22 | 0 | 22 | 0 | 0 | 0 |
| 64 | Trypilska 6 | NG | 300 | 0 | 0 | 22 | 0 | 22 | 0 | 0 | 0 |
| 65 | Zmiivska 1 | HC | 175 | 548 | 12 | 25 | 21 | 57 | 500 | 1,353 | 1,853 |
| 66 | Zmiivska 2 | HC | 175 | 548 | 0 | 25 | 21 | 46 | 502 | 1,341 | 1,843 |
| 67 | Zmiivska 3 | HC | 175 | 548 | 14 | 25 | 21 | 60 | 488 | 1,348 | 1,836 |
| 68 | Zmiivska 4 | HC | 175 | 548 | 0 | 25 | 21 | 46 | 472 | 1,343 | 1,816 |
| 69 | Zmiivska 5 | HC | 175 | 548 | 14 | 25 | 21 | 60 | 443 | 1,363 | 1,806 |
| 70 | Zmiivska 6 | HC | 175 | 548 | 0 | 25 | 21 | 46 | 379 | 1,316 | 1,695 |
| 71 | Zmiivska 7 | HC | 275 | 793 | 11 | 27 | 35 | 72 | 1,108 | 2,126 | 3,234 |
| 72 | Zmiivska 8 | HC | 325 | 937 | 11 | 28 | 42 | 81 | 1,450 | 2,882 | 4,332 |
| 73 | Zmiivska 9 | HC | 275 | 793 | 11 | 25 | 35 | 70 | 1,046 | 2,113 | 3,159 |
| 74 | Zmiivska 10 | HC | 275 | 793 | 11 | 25 | 36 | 72 | 1,042 | 2,061 | 3,103 |
| 75 | Vuglegirska 1 | HC | 300 | 1,359 | 11 | 24 | 39 | 74 | 1,614 | 3,967 | 5,581 |
| 76 | Vuglegirska 2 | HC | 300 | 1,359 | 11 | 24 | 39 | 74 | 1,614 | 3,967 | 5,581 |
| 77 | Vuglegirska 3 | HC | 300 | 1,359 | 11 | 24 | 39 | 74 | 1,614 | 3,967 | 5,581 |
| 78 | Vuglegirska 4 | HC | 300 | 1,359 | 11 | 24 | 39 | 74 | 1,614 | 3,967 | 5,581 |
| 79 | Vuglegirska 5 | NG | 800 | 0 | 0 | 65 | 0 | 65 | 0 | 0 | 0 |
| 80 | Vuglegirska 6 | NG | 800 | 0 | 0 | 65 | 0 | 65 | 0 | 0 | 0 |
| 81 | Vuglegirska 7 | NG | 800 | 0 | 0 | 65 | 0 | 65 | 0 | 0 | 0 |
| 82 | Zuevskaya 1 | HC | 325 | 1,606 | 0 | 28 | 42 | 70 | 2,354 | 4,854 | 7,208 |
| 83 | Zuevskaya 2 | HC | 320 | 1,660 | 0 | 28 | 41 | 69 | 2,413 | 5,010 | 7,423 |
| 84 | Zuevskaya 3 | HC | 300 | 1,606 | 0 | 25 | 41 | 66 | 2,225 | 4,729 | 6,953 |
| 85 | Zuevskaya 4 | HC | 325 | 1,740 | 0 | 26 | 41 | 67 | 2,439 | 5,136 | 7,575 |
| 86 | Kurakhovskaya 3 | HC | 200 | 1,005 | 15 | 6 | 26 | 47 | 1,407 | 2,951 | 4,358 |
| 87 | Kurakhovskaya 4 | HC | 210 | 1,003 | 10 | 7 | 27 | 44 | 1,410 | 2,974 | 4,384 |
| 88 | Kurakhovskaya 5 | HC | 222 | 969 | 11 | 7 | 29 | 47 | 1,341 | 2,916 | 4,257 |
| 89 | Kurakhovskaya 6 | HC | 210 | 640 | 7 | 6 | 27 | 40 | 859 | 1,897 | 2,756 |
| 90 | Kurakhovskaya 7 | HC | 225 | 982 | 12 | 7 | 29 | 48 | 1,361 | 2,855 | 4,216 |
| 91 | Kurakhovskaya 8 | HC | 210 | 674 | 8 | 2 | 27 | 36 | 921 | 2,006 | 2,928 |
| 92 | Kurakhovskaya 9 | HC | 221 | 1,019 | 13 | 6 | 29 | 47 | 1,355 | 3,022 | 4,377 |
| 93 | Luganskaya 9 | HC | 200 | 1,070 | 10 | 17 | 23 | 50 | 1,179 | 2,850 | 4,029 |
| 94 | Luganskaya 10 | HC | 200 | 642 | 1 | 17 | 23 | 40 | 649 | 1,687 | 2,336 |
| 95 | Luganskaya 11 | HC | 200 | 988 | 14 | 17 | 23 | 54 | 1,139 | 2,617 | 3,756 |
| 96 | Luganskaya 12 | HC | 175 | 0 | 7 | 16 | 20 | 42 | 0 | 0 | 0 |
| 97 | Luganskaya 13 | HC | 175 | 951 | 9 | 16 | 20 | 45 | 1,112 | 2,591 | 3,703 |
| 98 | Luganskaya 14 | HC | 200 | 1,070 | 10 | 17 | 23 | 50 | 1,307 | 2,905 | 4,212 |
| 99 | Luganskaya 15 | HC | 200 | 988 | 13 | 17 | 23 | 53 | 1,158 | 2,707 | 3,866 |
| 100 | Bilotserkivska CHP | NG | 120 | 494 | 0 | 4 | 0 | 4 | 296 | 0 | 296 |
| 101 | Darnytska CHP 5,10 | NG | 50 | 212 | 0 | 5 | 0 | 5 | 212 | 0 | 212 |
| 102 | Darnytska CHP 6-9 | HC | 110 | 453 | 3 | 11 | 13 | 27 | 453 | 1,059 | 1,512 |
| 103 | Kaluska CHP 1, 2 | HC | 100 | 412 | 4 | 0 | 11 | 15 | 0 | 988 | 988 |
| 104 | Kaluska CHP 3, 4 | NG | 100 | 425 | 0 | 10 | 0 | 10 | 425 | 0 | 425 |
| 105 | Kyivska CHP-5 | NG | 540 | 1,147 | 0 | 35 | 0 | 35 | 1,147 | 0 | 1,147 |
| 105a | Kyivska CHP-5 | FO | 540 | 1,147 | 0 | 35 | 59 | 94 | 1,147 | 2,007 | 3,155 |
| 106 | Kyivska CHP-6 | NG | 500 | 1,062 | 0 | 33 | 0 | 33 | 1,062 | 0 | 1,062 |
| 106a | Kyivska CHP-6 | FO | 500 | 1,062 | 0 | 32 | 55 | 87 | 1,062 | 2,656 | 3,718 |
| 107 | Kramatorska CHP | HC | 120 | 494 | 6 | 0 | 17 | 23 | 0 | 1,288 | 1,288 |
| 108 | Myronivska 4 | HC | 60 | 247 | 2 | 2 | 7 | 11 | 330 | 642 | 972 |
| 109 | Myronivska 9 | HC | 115 | 616 | 4 | 3 | 13 | 21 | 873 | 1,504 | 2,377 |
| 110 | Odeska CHP-2 | NG | 68 | 289 | 0 | 8 | 0 | 8 | 289 | 0 | 289 |
| 111 | Sevastopolska CHP | NG | 55 | 234 | 0 | 1 | 0 | 1 | 140 | 0 | 140 |
| 112 | Simferopilska CHP | NG | 278 | 1,181 | 0 | 1 | 0 | 1 | 354 | 0 | 354 |
| 113 | Kharkivska CHP-2 | HC | 74 | 314 | 3 | 2 | 10 | 15 | 444 | 995 | 1,439 |
| Total | | | 29,368 | 88,669 | 812 | 2,301 | 2,921 | 6,033 | 105,054 | 217,837 | 32,2890 |

NB: Units No 105-106 and 107-108 are presented with alternative fuels

Table A3-14: Scenario 1 - LCPD compliance costs for Kosovo*

| Code | Plant name | Fuel type | Power MW | Energy GWh/a | LCPD Scenario | | | | | | |
|-------|------------|-----------|----------|--------------|------------------------------|-----------------|-----------------|-------|------------------------|-----------------|-------|
| | | | | | Investment costs /million €/ | | | | O&M costs /000 €/year/ | | |
| | | | | | Dust | NO _x | SO ₂ | Total | NO _x | SO ₂ | Total |
| 1 | Kosovo A3 | L | 200 | 590 | | | | 0 | | | 0 |
| 2 | Kosovo A4 | L | 200 | 590 | | | | 0 | | | 0 |
| 3 | Kosovo A5 | L | 210 | 606 | | | | 0 | | | 0 |
| 4 | Kosovo B1 | L | 339 | 1,083 | 10.0 | 13.0 | 16.0 | 39 | 1,617 | 2,063 | 3,680 |
| 5 | Kosovo B2 | L | 339 | 1,083 | 10.0 | 13.0 | 16.0 | 39 | 1,627 | 2,060 | 3,688 |
| Total | | | 1,288 | 3,951 | 20 | 26 | 32 | 78 | 3,244 | 4,124 | 7,368 |

Table A3-15: Scenario 2 - IED compliance costs for Kosovo*

| Code | Plant name | Fuel type | Power MW | Energy GWh/a | IED Scenario | | | | | | |
|-------|------------|-----------|----------|--------------|------------------------------|-----------------|-----------------|-------|-----------------------|-----------------|-------|
| | | | | | Investment costs /million €/ | | | | O&M costs /000€/year/ | | |
| | | | | | Dust | NO _x | SO ₂ | Total | NO _x | SO ₂ | Total |
| 1 | Kosovo A3 | L | 200 | 590 | | | | 0 | | | 0 |
| 2 | Kosovo A4 | L | 200 | 590 | | | | 0 | | | 0 |
| 3 | Kosovo A5 | L | 210 | 606 | | | | 0 | | | 0 |
| 4 | Kosovo B1 | L | 339 | 1,083 | 11.5 | 13.0 | 17.6 | 42 | 1,617 | 2,063 | 3,680 |
| 5 | Kosovo B2 | L | 339 | 1,083 | 11.5 | 13.0 | 17.6 | 42 | 1,627 | 2,060 | 3,688 |
| Total | | | 1,288 | 3,951 | 23 | 26 | 35 | 84 | 3,244 | 4,124 | 7,368 |

Annex 4 Ranking of LCPs in accordance to the impact to the environment

A4.1. Ranking of estimated external costs of pollutants emission in 2014

Table A4-1.1: Albania – LCPs ranking related to the estimated external costs in 2014

| Rank No | Code | Plant name | Fuel type | Power MW | Energy GWh/a | Emission - BAU | | | External costs - BAU | | | | |
|---------|------|------------|-----------|----------|--------------|-----------------------------|-----------------|-----------------|-----------------------------|-----------------|-----------------|-----------|-------|
| | | | | | | Pollutants emission, t/year | | | Total costs, million €/year | | | Unit cost | |
| | | | | | | Dust | NO _x | SO ₂ | Dust | NO _x | SO ₂ | Total | €/kWh |
| 1 | 1 | Vlora | NG | 100 | 722 | 2 | 98 | 70 | 0.0 | 0.50 | 0.46 | 0.96 | 0.1 |

Table A4-1.2: Bosnia and Herzegovina - LCPs ranking related to the estimated external costs in 2014

| Rank No | Code | Plant name | Fuel type | Power MW | Energy GWh/a | Emission - BAU | | | External costs - BAU | | | | |
|---------|------|------------|-----------|----------|--------------|-----------------------------|-----------------|-----------------|-----------------------------|-----------------|-----------------|-----------|-------|
| | | | | | | Pollutants emission, t/year | | | Total costs, million €/year | | | Unit cost | |
| | | | | | | Dust | NO _x | SO ₂ | Dust | NO _x | SO ₂ | Total | €/kWh |
| 1 | 2 | Ugljevik | L | 300 | 2,176 | 2 | 4,937 | 159,958 | 1.0 | 37.9 | 1,110 | 1,149 | 52.8 |
| 2 | 7 | Kakanj 5 | L | 110 | 598 | 30 | 2,785 | 21,055 | 0.0 | 21.4 | 146.1 | 168 | 28.0 |
| 3 | 9 | Kakanj 7 | L | 230 | 1,342 | 1,036 | 4,756 | 46,917 | 0.5 | 36.5 | 325.6 | 363 | 27.0 |
| 4 | 8 | Kakanj 6 | L | 110 | 312 | 27 | 1,016 | 10,523 | 0.0 | 7.8 | 73.0 | 81 | 25.9 |
| 5 | 6 | Tuzla 6 | L | 215 | 1,008 | 129 | 1,508 | 17,003 | 0.1 | 11.6 | 118.0 | 130 | 12.9 |
| 6 | 4 | Tuzla 4 | L | 200 | 1,196 | 460 | 2,030 | 12,807 | 0.2 | 15.6 | 88.9 | 105 | 8.8 |
| 7 | 3 | Tuzla 3 | L | 110 | 473 | 71 | 881 | 4,499 | 0.0 | 6.8 | 31.2 | 38 | 8.0 |
| 8 | 5 | Tuzla 5 | L | 200 | 1,004 | 281 | 903 | 9,505 | 0.1 | 6.9 | 66.0 | 73 | 7.3 |
| 9 | 1 | Gacko | L | 300 | 1,934 | 2,299 | 5,517 | 13,793 | 1.1 | 42.4 | 95.7 | 139 | 7.2 |

Table A4-1.3: Croatia - LCPs ranking related to the estimated external costs in 2014

| Rank No | Code | Plant name | Fuel type | Power MW | Energy GWh/a | Emission - BAU | | | External costs - BAU | | | | |
|---------|------|-------------------|-----------|----------|--------------|-----------------------------|-----------------|-----------------|-----------------------------|-----------------|-----------------|-----------|-------|
| | | | | | | Pollutants emission, t/year | | | Total costs, million €/year | | | Unit cost | |
| | | | | | | Dust | NO _x | SO ₂ | Dust | NO _x | SO ₂ | Total | €/kWh |
| 1 | 11 | CHP Zagreb ELTOK6 | NG | 11 | 21 | 8 | 71 | 353 | 0.0 | 0.8 | 3.0 | 4 | 17.6 |
| 2 | 4 | TPP Sisak A | FO | 210 | 1,214 | 454 | 3,042 | 14,994 | 0.4 | 32.1 | 128.8 | 161 | 13.3 |
| 3 | 5 | TPP Sisak B | FO | 210 | 1,214 | 454 | 3,042 | 14,994 | 0.4 | 32.1 | 128.8 | 161 | 13.3 |
| 4 | 3 | TPP Rijeka | FO | 320 | 1,725 | 594 | 4,803 | 19,335 | 0.5 | 50.7 | 166.2 | 217 | 12.6 |
| 5 | 12 | CHP Zagreb ELTOK8 | NG | 30 | 82 | 66 | 148 | 910 | 0.1 | 1.6 | 7.8 | 9 | 11.6 |
| 6 | 8 | CHP Zagreb C | NG | 120 | 469 | 129 | 1,056 | 4,218 | 0.1 | 11.2 | 36.2 | 48 | 10.1 |
| 7 | 1 | TPP Plomin 1 | HC | 125 | 915 | 122 | 1,861 | 5,357 | 0.1 | 19.7 | 46.0 | 66 | 7.2 |
| 8 | 2 | TPP Plomin 2 | HC | 210 | 1,631 | 116 | 1,888 | 873 | 0.1 | 19.9 | 7.5 | 28 | 1.7 |
| 9 | 13 | CHP Zagreb ELTOH | NG | 25 | 161 | 0 | 174 | 4 | 0.0 | 1.8 | 0.0 | 2 | 1.2 |
| 10 | 14 | CHP Zagreb ELTOJ | NG | 25 | 161 | 0 | 151 | 8 | 0.0 | 1.6 | 0.1 | 2 | 1.0 |
| 11 | 16 | CHP Osijek B | NG | 25 | 42 | 0 | 38 | 3 | 0.0 | 0.4 | 0.0 | 0 | 1.0 |
| 12 | 17 | CHP Osijek C | NG | 25 | 21 | 0 | 19 | 1 | 0.0 | 0.2 | 0.0 | 0 | 1.0 |
| 13 | 15 | CHP Osijek A | NG | 46 | 256 | 4 | 217 | 15 | 0.0 | 2.3 | 0.1 | 2 | 0.9 |
| 14 | 7 | TPP Jertovac 2 | NG | 40 | 47 | 0 | 33 | 1 | 0.0 | 0.3 | 0.0 | 0 | 0.8 |
| 15 | 6 | TPP Jertovac 1 | NG | 40 | 47 | 0 | 32 | 1 | 0.0 | 0.3 | 0.0 | 0 | 0.7 |
| 16 | 9 | CHP Zagreb K | NG | 208 | 1,591 | 20 | 123 | 20 | 0.0 | 1.3 | 0.2 | 1 | 0.1 |
| 17 | 10 | CHP Zagreb L | NG | 112 | 866 | 11 | 47 | 4 | 0.0 | 0.5 | 0.0 | 1 | 0.1 |

Table A4-1.4: FYR of Macedonia – LCPs ranking related to the estimated external costs in 2014

| Rank No | Code | Plant name | Fuel type | Power MW | Energy GWh/a | Emission - BAU | | | External costs - BAU | | | | |
|---------|------|------------|-----------|----------|--------------|-----------------------------|-----------------|-----------------|-----------------------------|-----------------|-----------------|-----------|-------|
| | | | | | | Pollutants emission, t/year | | | Total costs, million €/year | | | Unit cost | |
| | | | | | | Dust | NO _x | SO ₂ | Dust | NO _x | SO ₂ | Total | €/kWh |
| 1 | 1 | Bitola 1 | L | 233 | 1,387 | 2,571 | 5,629 | 33,359 | 1.2 | 26.9 | 189.2 | 217 | 15.7 |
| 2 | 2 | Bitola 2 | L | 233 | 1,387 | 4,448 | 5,699 | 27,104 | 2.0 | 27.3 | 153.7 | 183 | 13.2 |
| 3 | 3 | Bitola 3 | L | 233 | 1,387 | 4,448 | 5,699 | 27,104 | 2.0 | 27.3 | 153.7 | 183 | 13.2 |
| 4 | 4 | Oslomej | L | 125 | 604 | 1,722 | 1,087 | 12,383 | 0.8 | 5.2 | 70.2 | 76 | 12.6 |
| 5 | 7 | Kogel CHP | NG | 30 | 185 | 4 | 72 | 0 | 0.0 | 0.3 | 0.0 | 0 | 0.2 |
| 6 | 6 | Skopje CHP | NG | 227 | 1394 | 28 | 456 | 2 | 0.0 | 2.2 | 0.0 | 2 | 0.2 |
| 7 | 5 | Negotino | FO | 210 | 17 | 0 | 0 | 0 | 0.0 | 0.0 | 0.0 | 0 | 0.0 |

Table A4-1.5: Moldova – LCPs ranking related to the estimated external costs in 2014

| Rank No | Code | Plant name | Fuel type | Power MW | Energy GWh/a | Emission - BAU | | | External costs - BAU | | | | |
|---------|------|------------|-----------|----------|--------------|-----------------------------|-----------------|-----------------|-----------------------------|-----------------|-----------------|-----------|-------|
| | | | | | | Pollutants emission, t/year | | | Total costs, million €/year | | | Unit cost | |
| | | | | | | Dust | NO _x | SO ₂ | Dust | NO _x | SO ₂ | Total | €/kWh |
| 1 | 7 | CET-2, No2 | NG | 80 | 371 | 0 | 185 | 0 | 0.0 | 1.5 | 0.0 | 1.5 | 0.4 |
| 2 | 8 | CET-2, No3 | NG | 80 | 371 | 0 | 170 | 0 | 0.0 | 1.4 | 0.0 | 1.4 | 0.4 |
| 3 | 6 | CET-2, No1 | NG | 80 | 398 | 0 | 175 | 0 | 0.0 | 1.4 | 0.0 | 1.4 | 0.4 |
| 4 | 3 | CET-1, No3 | NG | 10 | 49 | 0 | 21 | 0 | 0.0 | 0.2 | 0.0 | 0.2 | 0.4 |
| 5 | 2 | CET-1, No2 | NG | 12 | 59 | 0 | 25 | 0 | 0.0 | 0.2 | 0.0 | 0.2 | 0.3 |
| 6 | 4 | CET-1, No4 | NG | 27 | 132 | 0 | 49 | 0 | 0.0 | 0.4 | 0.0 | 0.4 | 0.3 |
| 7 | 1 | CET-1, No1 | NG | 12 | 59 | 0 | 21 | 0 | 0.0 | 0.2 | 0.0 | 0.2 | 0.3 |
| 8 | 5 | CET-1, No5 | NG | 5 | 24 | 0 | 7 | 0 | 0.0 | 0.1 | 0.0 | 0.1 | 0.2 |

Table A4-1.6: Montenegro – LCPs ranking related to the estimated external costs in 2014

| Rank No | Code | Plant name | Fuel type | Power MW | Energy GWh/a | Emission - BAU | | | External costs - BAU | | | | |
|---------|------|------------|-----------|----------|--------------|-----------------------------|-----------------|-----------------|-----------------------------|-----------------|-----------------|-----------|------|
| | | | | | | Pollutants emission, t/year | | | Total costs, million €/year | | | Unit cost | |
| | | | | | | Dust | NO _x | SO ₂ | Dust | NO _x | SO ₂ | Total | €/kW |
| 1 | 1 | Pljevlja | L | 219 | 1,489 | 221 | 3,322 | 44,295 | 0.2 | 28.8 | 369.4 | 398.3 | 26.7 |

Table A4-1.7: Serbia - LCPs ranking related to the estimated external costs in 2014

| Rank No | Code | Plant name | Fuel type | Power MW | Energy GWh/a | Emission - BAU | | | External costs - BAU | | | | |
|---------|------|----------------|-----------|----------|--------------|-----------------------------|-----------------|-----------------|-----------------------------|-----------------|-----------------|-----------|-------|
| | | | | | | Pollutants emission, t/year | | | Total costs, million €/year | | | Unit Cost | |
| | | | | | | Dust | NO _x | SO ₂ | Dust | NO _x | SO ₂ | Total | €/kWh |
| 1 | 15 | Kostolac A1 | L | 100 | 560 | 1,282 | 1,218 | 19,052 | 1.0 | 10.5 | 158.9 | 170 | 30.5 |
| 2 | 16 | Kostolac A2 | L | 210 | 1,196 | 672 | 2,285 | 37,078 | 0.5 | 19.8 | 309.2 | 330 | 27.5 |
| 3 | 17 | Kostolac B1 | L | 348 | 1,937 | 5,489 | 5,132 | 57,898 | 4.5 | 44.4 | 482.8 | 532 | 27.5 |
| 4 | 18 | Kostolac B2 | L | 348 | 1,895 | 2,361 | 4,553 | 51,300 | 1.9 | 39.4 | 427.8 | 469 | 24.8 |
| 5 | 14 | Morava | L | 125 | 566 | 3,283 | 1,513 | 11,018 | 2.7 | 13.1 | 91.9 | 108 | 19.0 |
| 6 | 10 | Kolubara 2 | L | 32 | 116 | 1,013 | 325 | 1,974 | 0.8 | 2.8 | 16.5 | 20 | 17.4 |
| 7 | 11 | Kolubara 3 | L | 64 | 135 | 1,180 | 379 | 2,300 | 1.0 | 3.3 | 19.2 | 23 | 17.4 |
| 8 | 9 | Kolubara 1 | L | 32 | 175 | 1,534 | 492 | 2,990 | 1.3 | 4.3 | 24.9 | 30 | 17.4 |
| 9 | 13 | Kolubara 5 | L | 110 | 626 | 192 | 1,356 | 7,876 | 0.2 | 11.7 | 65.7 | 78 | 12.4 |
| 10 | 1 | Nikola TeslaA1 | L | 210 | 1,231 | 852 | 2,336 | 11,901 | 0.7 | 20.2 | 99.2 | 120 | 9.8 |
| 11 | 2 | Nikola TeslaA2 | L | 210 | 1,198 | 829 | 2,273 | 11,578 | 0.7 | 19.7 | 96.5 | 117 | 9.8 |
| 12 | 4 | Nikola TeslaA4 | L | 309 | 1,989 | 353 | 3,973 | 18,855 | 0.3 | 34.4 | 157.2 | 192 | 9.6 |
| 13 | 8 | Nikola TeslaB2 | L | 620 | 4,004 | 743 | 8,157 | 37,723 | 0.6 | 70.6 | 314.6 | 386 | 9.6 |
| 14 | 5 | Nikola TeslaA5 | L | 309 | 1,999 | 351 | 3,957 | 18,776 | 0.3 | 34.3 | 156.6 | 191 | 9.6 |
| 15 | 6 | Nikola TeslaA6 | L | 309 | 1,987 | 349 | 3,932 | 18,661 | 0.3 | 34.1 | 155.6 | 190 | 9.6 |
| 16 | 7 | Nikola TeslaB1 | L | 620 | 4,151 | 763 | 8,378 | 38,742 | 0.6 | 72.6 | 323.1 | 396 | 9.5 |
| 17 | 3 | Nikola TeslaA3 | L | 305 | 1,923 | 1,295 | 3,551 | 18,092 | 1.1 | 30.8 | 150.9 | 183 | 9.5 |
| 18 | 21 | Zrenjanin | NG | 110 | 66 | 2 | 248 | 41 | 0.0 | 2.1 | 0.3 | 2 | 3.8 |
| 19 | 20 | Novi Sad2 | NG | 110 | 175 | 4 | 601 | 99 | 0.0 | 5.2 | 0.8 | 6 | 3.4 |
| 20 | 19 | Novi Sad1 | NG | 135 | 189 | 4 | 649 | 107 | 0.0 | 5.6 | 0.9 | 7 | 3.4 |
| 21 | 22 | Sr, Mitrovica1 | NG | 32 | 123 | 0 | 230 | 0 | 0.0 | 2.0 | 0.0 | 2 | 1.6 |
| 22 | 12 | Kolubara 4 | L | 32 | 0 | 0 | 0 | 0 | 0.0 | 0.0 | 0.0 | 0 | |

Table A4-1.8: Ukraine – LCPs ranking related to the estimated external costs in 2014

| Rank No | Code | Plant name | Fuel type | Power MW | Energy GWh/a | Emission - BAU | | | External costs - BAU | | | | |
|---------|------|----------------|-----------|----------|--------------|-----------------------------|-----------------|-----------------|-----------------------------|-----------------|-----------------|-----------|-------|
| | | | | | | Pollutants emission, t/year | | | Total costs, million €/year | | | Unit cost | |
| | | | | | | Dust | NO _x | SO ₂ | Dust | NO _x | SO ₂ | Total | €/kWh |
| 1 | 113 | KharkivskaCHP2 | HC | 74 | 314 | 3,108 | 837 | 6,967 | 4 | 4 | 50 | 58 | 18.6 |
| 2 | 72 | Zmiivska8 | HC | 325 | 937 | 925 | 7,093 | 16,995 | 1 | 38 | 122 | 161 | 17.2 |
| 3 | 89 | Kurakhovskaya6 | HC | 210 | 640 | 9,898 | 1,520 | 12,148 | 13 | 8 | 87 | 108 | 16.9 |
| 4 | 82 | Zuevskaya1 | HC | 325 | 1,606 | 1,067 | 10,517 | 28,607 | 1 | 56 | 205 | 262 | 16.3 |
| 5 | 88 | Kurakhovskaya5 | HC | 222 | 969 | 9,818 | 2,369 | 18,395 | 13 | 13 | 132 | 157 | 16.2 |
| 6 | 83 | Zuevskaya2 | HC | 320 | 1,660 | 1,161 | 10,567 | 29,282 | 2 | 57 | 209 | 268 | 16.1 |
| 7 | 87 | Kurakhovskaya4 | HC | 210 | 1,003 | 10,962 | 2,571 | 18,563 | 14 | 14 | 133 | 161 | 16.0 |
| 8 | 91 | Kurakhovskaya8 | HC | 210 | 674 | 6,228 | 1,611 | 12,507 | 8 | 9 | 89 | 106 | 15.7 |
| 9 | 86 | Kurakhovskaya3 | HC | 200 | 1,005 | 10,815 | 2,531 | 18,025 | 14 | 14 | 129 | 157 | 15.6 |
| 10 | 52 | Dobrotvirska8 | HC | 150 | 568 | 2,705 | 1,633 | 10,610 | 4 | 9 | 76 | 88 | 15.5 |
| 11 | 85 | Zuevskaya4 | HC | 325 | 1,740 | 284 | 10,326 | 29,707 | 0 | 55 | 213 | 268 | 15.4 |
| 12 | 92 | Kurakhovskaya9 | HC | 221 | 1,019 | 7,711 | 2,302 | 18,738 | 10 | 12 | 134 | 156 | 15.3 |
| 13 | 49 | Dobrotvirska5 | HC | 100 | 402 | 1,110 | 1,231 | 7,495 | 1 | 7 | 54 | 62 | 15.3 |
| 14 | 50 | Dobrotvirska6 | HC | 100 | 402 | 1,110 | 1,231 | 7,495 | 1 | 7 | 54 | 62 | 15.3 |
| 15 | 51 | Dobrotvirska7 | HC | 150 | 786 | 3,683 | 2,224 | 14,448 | 5 | 12 | 103 | 120 | 15.3 |

| Rank No | Code | Plant name | Fuel type | Power MW | Energy GWh/a | Emission - BAU | | | External costs - BAU | | | | |
|---------|------|-------------------|-----------|----------|--------------|-----------------------------|-----------------|-----------------|-----------------------------|-----------------|-----------------|-----------|-------|
| | | | | | | Pollutants emission, t/year | | | Total costs, million €/year | | | Unit cost | |
| | | | | | | Dust | NO _x | SO ₂ | Dust | NO _x | SO ₂ | Total | €/kWh |
| 16 | 84 | Zuevskaya3 | HC | 300 | 1,606 | 1,967 | 9,117 | 26,786 | 3 | 49 | 192 | 243 | 15.1 |
| 17 | 71 | Zmiivska7 | HC | 275 | 793 | 7,504 | 5,140 | 11,535 | 10 | 28 | 83 | 120 | 15.1 |
| 18 | 90 | Kurakhovskaya7 | HC | 225 | 982 | 6,937 | 2,402 | 17,084 | 9 | 13 | 122 | 144 | 14.7 |
| 19 | 99 | Luganskaya15 | HC | 200 | 988 | 8,975 | 4,627 | 15,168 | 12 | 25 | 109 | 145 | 14.7 |
| 20 | 98 | Luganskaya14 | HC | 200 | 1,070 | 10,424 | 5,265 | 15,825 | 14 | 28 | 113 | 155 | 14.5 |
| 21 | 77 | Vuglegirsk3 | HC | 300 | 1,359 | 1,889 | 5,947 | 22,603 | 2 | 32 | 162 | 196 | 14.4 |
| 22 | 78 | Vuglegirsk4 | HC | 300 | 1,359 | 1,887 | 5,941 | 22,580 | 2 | 32 | 162 | 196 | 14.4 |
| 23 | 75 | Vuglegirsk | HC | 300 | 1,359 | 1,882 | 5,925 | 22,520 | 2 | 32 | 161 | 195 | 14.4 |
| 24 | 76 | Vuglegirsk2 | HC | 300 | 1,359 | 1,878 | 5,913 | 22,476 | 2 | 32 | 161 | 195 | 14.3 |
| 25 | 97 | Luganskaya13 | HC | 175 | 951 | 8,324 | 4,331 | 14,037 | 11 | 23 | 100 | 134 | 14.1 |
| 26 | 43 | Burshtynska7 | HC | 185 | 508 | 2,362 | 1,079 | 8,582 | 3 | 6 | 61 | 70 | 13.8 |
| 27 | 44 | Burshtynska8 | HC | 195 | 806 | 2,160 | 1,634 | 13,846 | 3 | 9 | 99 | 111 | 13.7 |
| 28 | 41 | Burshtynska5 | HC | 195 | 465 | 2,262 | 942 | 7,763 | 3 | 5 | 56 | 64 | 13.7 |
| 29 | 93 | Luganskaya9 | HC | 200 | 1,070 | 10,262 | 4,567 | 14,977 | 13 | 24 | 107 | 145 | 13.5 |
| 30 | 21 | Zaporiska3 | HC | 300 | 1,301 | 3,817 | 6,680 | 18,406 | 5 | 36 | 132 | 172 | 13.3 |
| 31 | 73 | Zmiivska9 | HC | 275 | 793 | 7,128 | 4,130 | 10,292 | 9 | 22 | 74 | 105 | 13.3 |
| 32 | 95 | Luganskaya11 | HC | 200 | 988 | 8,781 | 4,402 | 13,410 | 11 | 24 | 96 | 131 | 13.3 |
| 33 | 40 | Burshtynska 4 | HC | 195 | 884 | 4,462 | 1,833 | 14,031 | 6 | 10 | 100 | 116 | 13.1 |
| 34 | 22 | Zaporiska4 | HC | 300 | 1,205 | 3,509 | 6,669 | 16,417 | 5 | 36 | 117 | 158 | 13.1 |
| 35 | 39 | Burshtynska3 | HC | 185 | 662 | 3,463 | 1,347 | 10,385 | 5 | 7 | 74 | 86 | 13.0 |
| 36 | 42 | Burshtynska 6 | HC | 185 | 986 | 4,495 | 1,911 | 15,591 | 6 | 10 | 112 | 128 | 12.9 |
| 37 | 20 | Zaporiska 2 | HC | 300 | 1,277 | 3,799 | 6,583 | 17,402 | 5 | 35 | 125 | 165 | 12.9 |
| 38 | 19 | Zaporiska 1 | HC | 325 | 1,048 | 3,572 | 5,616 | 13,912 | 5 | 30 | 100 | 134 | 12.8 |
| 39 | 74 | Zmiivska 10 | HC | 275 | 793 | 7,153 | 4,187 | 9,754 | 9 | 22 | 70 | 102 | 12.8 |
| 40 | 38 | Burshtynska 2 | HC | 185 | 397 | 1,830 | 836 | 6,128 | 2 | 4 | 44 | 51 | 12.8 |
| 41 | 14 | Kryvorizka 6 | HC | 282 | 714 | 3,785 | 3,785 | 9,141 | 5 | 20 | 65 | 91 | 12.7 |
| 42 | 18 | Kryvorizka 10 | HC | 282 | 1,198 | 5,937 | 6,345 | 15,239 | 8 | 34 | 109 | 151 | 12.6 |
| 43 | 16 | Kryvorizka 8 | HC | 282 | 1,014 | 4,684 | 5,364 | 12,882 | 6 | 29 | 92 | 127 | 12.5 |
| 44 | 94 | Luganskaya 10 | HC | 200 | 642 | 1,912 | 2,528 | 8,775 | 2 | 14 | 63 | 79 | 12.3 |
| 45 | 46 | Burshtynska 10 | HC | 195 | 930 | 165 | 2,018 | 14,347 | 0 | 11 | 103 | 114 | 12.2 |
| 46 | 13 | Kryvorizka 5 | HC | 282 | 1,221 | 6,234 | 5,996 | 15,050 | 8 | 32 | 108 | 148 | 12.1 |
| 47 | 48 | Burshtynska 12 | HC | 195 | 667 | 590 | 1,205 | 10,170 | 1 | 6 | 73 | 80 | 12.0 |
| 48 | 45 | Burshtynska 9 | HC | 195 | 961 | 170 | 2,038 | 14,551 | 0 | 11 | 104 | 115 | 12.0 |
| 49 | 65 | Zmiivska 1 | HC | 175 | 548 | 7,494 | 1,966 | 6,158 | 10 | 11 | 44 | 64 | 11.7 |
| 50 | 9 | Kryvorizka 1 | HC | 282 | 1,106 | 5,226 | 5,079 | 13,397 | 7 | 27 | 96 | 130 | 11.7 |
| 51 | 37 | Burshtynska 1 | HC | 195 | 915 | 3,929 | 1,769 | 12,973 | 5 | 9 | 93 | 107 | 11.7 |
| 52 | 2 | Prydniprovsk 8 | HC | 150 | 682 | 2,727 | 3,090 | 8,338 | 4 | 17 | 60 | 80 | 11.7 |
| 53 | 47 | Burshtynska 11 | HC | 195 | 992 | 173 | 1,727 | 14,777 | 0 | 9 | 106 | 115 | 11.6 |
| 54 | 10 | Kryvorizka 2 | HC | 282 | 1,382 | 5,800 | 6,336 | 16,420 | 8 | 34 | 117 | 159 | 11.5 |
| 55 | 66 | Zmiivska 2 | HC | 175 | 548 | 7,565 | 1,963 | 5,950 | 10 | 11 | 43 | 63 | 11.5 |
| 56 | 108 | Myronivska 4 | HC | 60 | 247 | 232 | 613 | 3,453 | 0 | 3 | 25 | 28 | 11.5 |
| 57 | 1 | Prydniprovsk 7 | HC | 150 | 439 | 1,794 | 1,990 | 5,189 | 2 | 11 | 37 | 50 | 11.4 |
| 58 | 69 | Zmiivska 5 | HC | 175 | 548 | 6,768 | 1,741 | 6,141 | 9 | 9 | 44 | 62 | 11.3 |
| 59 | 67 | Zmiivska 3 | HC | 175 | 548 | 7,265 | 1,881 | 5,934 | 9 | 10 | 42 | 62 | 11.3 |
| 60 | 58 | Ladyzhinska 6 | HC | 300 | 558 | 3,377 | 2,425 | 6,349 | 4 | 13 | 45 | 63 | 11.3 |
| 61 | 57 | Ladyzhinska 5 | HC | 300 | 582 | 2,932 | 2,517 | 6,710 | 4 | 13 | 48 | 65 | 11.2 |
| 62 | 68 | Zmiivska 4 | HC | 175 | 548 | 7,074 | 1,843 | 5,897 | 9 | 10 | 42 | 61 | 11.2 |
| 63 | 7 | Prydniprovsk 13 | HC | 285 | 774 | 3,819 | 3,561 | 8,555 | 5 | 19 | 61 | 85 | 11.0 |
| 64 | 107 | Kramatorska CHP | HC | 120 | 494 | 918 | 945 | 6,727 | 1 | 5 | 48 | 54 | 11.0 |
| 65 | 12 | Kryvorizka 4 | HC | 282 | 1,221 | 1,144 | 5,741 | 14,139 | 1 | 31 | 101 | 133 | 10.9 |
| 66 | 55 | Ladyzhinska 3 | HC | 300 | 1,262 | 1,612 | 5,500 | 14,624 | 2 | 29 | 105 | 136 | 10.8 |
| 67 | 56 | Ladyzhinska 4 | HC | 300 | 752 | 3,027 | 3,243 | 8,311 | 4 | 17 | 59 | 81 | 10.7 |
| 68 | 5 | Prydniprovsk 11 | HC | 310 | 1,186 | 4,955 | 5,030 | 13,094 | 6 | 27 | 94 | 127 | 10.7 |
| 69 | 4 | Prydniprovsk 10 | HC | 150 | 590 | 2,042 | 2,523 | 6,532 | 3 | 14 | 47 | 63 | 10.7 |
| 70 | 53 | Ladyzhinska 1 | HC | 300 | 874 | 3,515 | 3,799 | 9,445 | 5 | 20 | 68 | 93 | 10.6 |
| 71 | 54 | Ladyzhinska 2 | HC | 300 | 1,092 | 1,468 | 4,737 | 12,175 | 2 | 25 | 87 | 114 | 10.5 |
| 72 | 70 | Zmiivska 6 | HC | 175 | 548 | 6,547 | 1,606 | 5,484 | 9 | 9 | 39 | 56 | 10.3 |
| 73 | 102 | Darnytska CHP 6-9 | HC | 110 | 453 | 2,011 | 2,228 | 4,258 | 3 | 12 | 30 | 45 | 9.9 |
| 74 | 109 | Myronivska 9 | HC | 115 | 616 | 460 | 1,725 | 6,972 | 1 | 9 | 50 | 60 | 9.7 |
| 75 | 103 | Kaluska CHP 1, 2 | HC | 100 | 412 | 1,982 | 291 | 4,285 | 3 | 2 | 31 | 35 | 8.5 |
| 76 | 106 | Kyivska CHP-6 | NG | 500 | 1,062 | 682 | 1,803 | 10,152 | 1 | 10 | 73 | 83 | 7.8 |
| 77 | 106a | Kyivska CHP-6 | FO | 500 | 1,062 | 535 | 2,007 | 8,108 | 1 | 11 | 58 | 69 | 6.5 |
| 78 | 60 | Trypilska 2 | HC | 300 | 1,250 | 6,857 | 4,615 | 4,615 | 9 | 25 | 33 | 67 | 5.3 |

| Rank No | Code | Plant name | Fuel type | Power MW | Energy GWh/a | Emission - BAU | | | External costs - BAU | | | | |
|---------|------|--------------------|-----------|----------|--------------|-----------------------------|-----------------|-----------------|-----------------------------|-----------------|-----------------|-------|-----------|
| | | | | | | Pollutants emission, t/year | | | Total costs, million €/year | | | | Unit cost |
| | | | | | | Dust | NO _x | SO ₂ | Dust | NO _x | SO ₂ | Total | €/kWh |
| 79 | 61 | Trypilska3 | HC | 300 | 1,250 | 6,486 | 3,348 | 3,348 | 8 | 18 | 24 | 50 | 4.0 |
| 80 | 62 | Trypilska 4 | HC | 300 | 1,250 | 6,311 | 3,308 | 3,308 | 8 | 18 | 24 | 50 | 4.0 |
| 81 | 59 | Trypilska 1 | HC | 300 | 1,250 | 5,004 | 3,294 | 3,294 | 7 | 18 | 24 | 48 | 3.8 |
| 82 | 110 | Odeska CHP-2 | NG | 68 | 289 | 0 | 941 | 0 | 0 | 5 | 0 | 5 | 1.7 |
| 83 | 104 | Kaluska CHP 3, 4 | NG | 100 | 425 | 0 | 476 | 0 | 0 | 3 | 0 | 3 | 0.6 |
| 84 | 101 | Darnytska CHP 5,10 | NG | 50 | 212 | 0 | 207 | 0 | 0 | 1 | 0 | 1 | 0.5 |
| 85 | 100 | Bilotserkivska CHP | NG | 120 | 494 | 0 | 470 | 0 | 0 | 3 | 0 | 3 | 0.5 |
| 86 | 111 | Sevastopolska CHP | NG | 55 | 234 | 0 | 167 | 0 | 0 | 1 | 0 | 1 | 0.4 |
| 87 | 112 | Simferopilska CHP | NG | 278 | 1,181 | 0 | 458 | 0 | 0 | 2 | 0 | 2 | 0.2 |
| 88 | 26 | Starobeshivska 4 | HC | 175 | 715 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| 89 | 27 | Starobeshivska 5 | HC | 175 | 715 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| 90 | 28 | Starobeshivska 6 | HC | 175 | 715 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| 91 | 29 | Starobeshivska 7 | HC | 175 | 715 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| 92 | 30 | Starobeshivska 8 | HC | 175 | 715 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| 93 | 31 | Starobeshivska 9 | HC | 175 | 715 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| 94 | 32 | Starobeshivska 10 | HC | 175 | 715 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| 95 | 33 | Starobeshivska 11 | HC | 175 | 715 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| 96 | 34 | Starobeshivska 12 | HC | 175 | 715 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| 97 | 35 | Starobeshivska 13 | HC | 175 | 715 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| 98 | 36 | Slovianska 7 | HC | 800 | 3,269 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| 99 | 105 | Kyivska CHP-5 | NG | 540 | 1,147 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| 100 | 105a | Kyivska CHP-5 | FO | 540 | 1,147 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| 101 | 3 | Prydniprovska 9 | HC | 150 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| 102 | 6 | Prydniprovska 12 | HC | 285 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| 103 | 8 | Prydniprovska 14 | HC | 285 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| 104 | 11 | Kryvorizka 3 | HC | 282 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| 105 | 15 | Kryvorizka 7 | HC | 282 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| 106 | 17 | Kryvorizka 9 | HC | 282 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| 107 | 23 | Zaporiska 5 | NG | 800 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| 108 | 24 | Zaporiska 6 | NG | 800 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| 109 | 25 | Zaporiska 7 | NG | 800 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| 110 | 63 | Trypilska 5 | NG | 300 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| 111 | 64 | Trypilska 6 | NG | 300 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| 112 | 79 | Vuglegirska 5 | NG | 800 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| 113 | 80 | Vuglegirska 6 | NG | 800 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| 114 | 81 | Vuglegirska 7 | NG | 800 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| 115 | 96 | Luganskaya 12 | HC | 175 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |

Table A4-1.9 Kosovo* - LCPs ranking related to the estimated external costs in 2014

| Rank No | Code | Plant name | Fuel type | Power MW | Energy GWh/a | Emission - BAU | | | External costs - BAU | | | | |
|---------|------|------------|-----------|----------|--------------|-----------------------------|-----------------|-----------------|-----------------------------|-----------------|-----------------|-------|-----------|
| | | | | | | Pollutants emission, t/year | | | Total costs, million €/year | | | | Unit cost |
| | | | | | | Dust | NO _x | SO ₂ | Dust | NO _x | SO ₂ | Total | €/kWh |
| 1 | 2 | Kosovo A4 | L | 200 | 590 | 2,969 | 2,802 | 2,374 | 2.4 | 24.3 | 19.8 | 46 | 7.9 |
| 2 | 3 | Kosovo A5 | L | 210 | 606 | 189 | 2,850 | 2,481 | 0.2 | 24.7 | 20.7 | 46 | 7.5 |
| 3 | 1 | Kosovo A3 | L | 200 | 590 | 200 | 2,651 | 2,443 | 0.2 | 23.0 | 20.4 | 43 | 7.4 |
| 4 | 4 | Kosovo B1 | L | 339 | 1,083 | 2,537 | 4,777 | | 2.2 | 42.2 | 30.8 | 75 | 6.9 |
| 5 | 5 | Kosovo B2 | L | 339 | 1,083 | 2,688 | 4,873 | 3,699 | 2.1 | 41.4 | 31.5 | 75 | 6.9 |

NB: "0" Appears in case that no data are available or if the TPP is lying up

A4.2. Cost-Benefit Ranking for LCPD Scenario

Table A4-2.1: Albania - LCPs ranking related to the CBA implementation of LCPD

| Rank No | Code | Plant name | Fuel type | Power MW | Costs | | NPV | | | B/C |
|---------|------|------------|-----------|----------|-------------|----------|--------|--------|--------|-----|
| | | | | | Investments | O&M | C | B | B-C | |
| | | | | | Mil, € | Mil, €/y | Mil, € | Mil, € | Mil, € | |
| 1 | 1 | Vlora | NG | 100 | | | | 0.00 | | - |

Table A4-2.2: Bosnia and Herzegovina - LCPs ranking related to the CBA implementation of LCPD

| Rank No | Code | Plant Name | Fuel type | Power MW | Costs | | NPV | | | B/C |
|---------|------|------------|-----------|----------|-------------|----------|--------|--------|--------|------|
| | | | | | Investments | O&M | C | B | B-C | |
| | | | | | Mil, € | Mil, €/y | Mil, € | Mil, € | Mil, € | |
| 1 | 2 | Ugljevik | L | 300 | 107.9 | 12.7 | 243 | 14,463 | 14,220 | 59.5 |
| 2 | 9 | Kakanj 7 | L | 230 | 58.5 | 5.0 | 111 | 4,415 | 4,304 | 39.6 |
| 3 | 7 | Kakanj 5 | L | 110 | 29.4 | 2.1 | 52 | 1,769 | 1,717 | 33.9 |
| 4 | 8 | Kakanj 6 | L | 110 | 22.4 | 1.0 | 33 | 842 | 808 | 25.4 |
| 5 | 6 | Tuzla 6 | L | 215 | 46.6 | 2.8 | 76 | 1,453 | 1,377 | 19.0 |
| 6 | 4 | Tuzla 4 | L | 200 | 22.0 | 3.5 | 59 | 1,038 | 979 | 17.6 |
| 7 | 5 | Tuzla 5 | L | 200 | 17.0 | 2.2 | 41 | 680 | 639 | 16.7 |
| 8 | 1 | Gacko | L | 300 | 33.4 | 6.7 | 105 | 1,316 | 1,211 | 12.6 |
| 9 | 3 | Tuzla 3 | L | 110 | | | | | | |

Table A4-2.3: Croatia - LCPs ranking related to the CBA implementation of LCPD

| Rank No | Code | Plant name | Fuel type | Power MW | Costs | | NPV | | | B/C |
|---------|------|---------------------|-----------|----------|-------------|----------|--------|--------|--------|-----|
| | | | | | Investments | O&M | C | B | B-C | |
| | | | | | Mil, € | Mil, €/y | Mil, € | Mil, € | Mil, € | |
| 1 | 3 | TPP Rijeka | FO | 320 | 61.2 | 5.9 | 124 | 2,411 | 2,287 | 19 |
| 2 | 4 | TPP Sisak A | FO | 210 | 56.7 | 3.3 | 92 | 1,738 | 1,646 | 19 |
| 3 | 5 | TPP Sisak B | FO | 210 | 56.7 | 3.3 | 92 | 1,738 | 1,646 | 19 |
| 4 | 8 | CHP Zagreb C | NG | 120 | 24.5 | 1.3 | 38 | 409 | 371 | 11 |
| 5 | 12 | CHP Zagreb EL-TO K8 | NG | 30 | 4.4 | 0.2 | 7 | 62 | 55 | 9 |
| 6 | 11 | CHP Zagreb EL-TO K6 | NG | 11 | 4.5 | 0.1 | 5 | 24 | 19 | 5 |
| 7 | 2 | TPP Plomin 2 | HC | 210 | 20.0 | 1.6 | 37 | 115 | 78 | 3 |
| 8 | 1 | TPP Plomin 1 | HC | 125 | | | | | | |
| 9 | 6 | TPP Jertovac 1 | NG | 40 | 0.0 | 0.0 | 0 | 0 | 0 | |
| 10 | 7 | TPP Jertovac 2 | NG | 40 | 0.0 | 0.0 | 0 | 0 | 0 | |
| 11 | 9 | CHP Zagreb K | NG | 208 | 0.0 | 0.0 | 0 | 0 | 0 | |
| 12 | 10 | CHP Zagreb L | NG | 112 | 0.0 | 0.0 | 0 | 0 | 0 | |
| 13 | 13 | CHP Zagreb EL-TO H | NG | 25 | 0.0 | 0.0 | 0 | 0 | 0 | |
| 14 | 14 | CHP Zagreb EL-TO J | NG | 25 | 0.0 | 0.0 | 0 | 0 | 0 | |
| 15 | 15 | CHP Osijek A | NG | 46 | 0.0 | 0.0 | 0 | 0 | 0 | |
| 16 | 16 | CHP Osijek B | NG | 25 | 0.0 | 0.0 | 0 | 0 | 0 | |
| 17 | 17 | CHP Osijek C | NG | 25 | 0.0 | 0.0 | 0 | 0 | 0 | |

Table A4-2.4: FYR Macedonia - LCPs ranking related to the CBA implementation of LCPD

| Rank No | Code | Plant name | Fuel type | Power MW | Costs | | NPV | | | B/C |
|---------|------|------------|-----------|----------|-------------|----------|--------|--------|--------|-----|
| | | | | | Investments | O&M | C | B | B-C | |
| | | | | | Mil, € | Mil, €/y | Mil, € | Mil, € | Mil, € | |
| 1 | 1 | Bitola 1 | L | 233 | 63.9 | 3.7 | 103 | 3,210 | 3,107 | 31 |
| 2 | 2 | Bitola 2 | L | 233 | 63.9 | 3.4 | 100 | 2,627 | 2,527 | 26 |
| 3 | 3 | Bitola 3 | L | 233 | 63.9 | 3.4 | 100 | 2,627 | 2,527 | 26 |
| 4 | 4 | Oslomej | L | 125 | 38.0 | 1.5 | 54 | 886 | 832 | 16 |
| | 5 | Negotino | FO | 210 | | | | | | |
| | 6 | Skopje CHP | NG | 227 | | | | | | |
| | 7 | Kogel CHP | NG | 30 | | | | | | |

Table A4-2.5: Moldova - LCPs ranking related to the CBA implementation of LCPD

| Rank No | Code | Plant name | Fuel type | Power MW | Costs | | NPV | | | B/C |
|---------|------|-------------|-----------|----------|-------------|----------|--------|--------|--------|-----|
| | | | | | Investments | O&M | C | B | B-C | |
| | | | | | Mil, € | Mil, €/y | Mil, € | Mil, € | Mil, € | |
| 1 | 1 | CET-1, No 1 | NG | 12 | | | | | | - |
| 2 | 2 | CET-1, No 2 | NG | 12 | | | | | | |
| 3 | 3 | CET-1, No 3 | NG | 10 | | | | | | |
| 4 | 4 | CET-1, No 4 | NG | 27 | | | | | | |
| 5 | 5 | CET-1, No 5 | NG | 5 | | | | | | |
| 6 | 6 | CET-2, No 1 | NG | 80 | | | | | | |

| | | | | | | | | | |
|---|---|-------------|----|----|--|--|--|--|--|
| 7 | 7 | CET-2, No 2 | NG | 80 | | | | | |
| 8 | 8 | CET-2, No 3 | NG | 80 | | | | | |

Table A4-2.6: Montenegro - LCPs ranking related to the CBA implementation of LCPD

| Rank No | Code | Plant name | Fuel type | Power MW | COSTS | | NPV | | | B/C |
|---------|------|------------|-----------|----------|-------------|----------|--------|--------|--------|-----|
| | | | | | Investments | O&M | C | B | B-C | |
| | | | | | Mil, € | Mil, €/y | Mil, € | Mil, € | Mil, € | |
| 1 | 1 | Pljevlja | Lignite | 219 | 46,9 | 4,3 | 93 | 4725 | 4632 | 51 |

Table A4-2.7: Serbia - LCPs ranking related to the CBA implementation of LCPD

| Rank No | Code | Plant Name | Fuel Type | Power MW | COSTS | | NPV | | | B/C |
|---------|------|-----------------|-----------|----------|-------------|----------|--------|--------|--------|------|
| | | | | | Investments | O&M | C | B | B-C | |
| | | | | | Mil, € | Mil, €/y | Mil, € | Mil, € | Mil, € | |
| 1 | 16 | Kostolac A2 | L | 210 | 9.6 | 3.9 | 51 | 3,912 | 3,861 | 77.0 |
| 2 | 17 | Kostolac B1 | L | 348 | 70.8 | 7.7 | 152 | 6,355 | 6,203 | 41.7 |
| 3 | 18 | Kostolac B2 | L | 348 | 65.8 | 7.1 | 142 | 5,551 | 5,409 | 39.2 |
| 4 | 14 | Morava | L | 125 | 17.0 | 1.5 | 33 | 963 | 930 | 28.8 |
| 5 | 15 | Kostolac A1 | L | 100 | 47.5 | 1.5 | 63 | 1,689 | 1,626 | 26.7 |
| 6 | 1 | Nikola Tesla A1 | L | 210 | 21.7 | 3.0 | 53 | 1,179 | 1,126 | 22.2 |
| 7 | 13 | Kolubara 5 | L | 110 | 8.6 | 1.5 | 24 | 530 | 506 | 21.9 |
| 8 | 2 | Nikola Tesla A2 | L | 210 | 23.0 | 2.9 | 54 | 1,147 | 1,093 | 21.4 |
| 9 | 8 | Nikola Tesla B2 | L | 620 | 77.6 | 9.7 | 180 | 3,860 | 3,679 | 21.4 |
| 10 | 7 | Nikola Tesla B1 | L | 620 | 87.0 | 10.0 | 194 | 3,964 | 3,771 | 20.5 |
| 11 | 4 | Nikola Tesla A4 | L | 309 | 45.6 | 4.8 | 97 | 1,902 | 1,805 | 19.7 |
| 12 | 5 | Nikola Tesla A5 | L | 309 | 45.6 | 4.8 | 97 | 1,894 | 1,797 | 19.6 |
| 13 | 6 | Nikola Tesla A6 | L | 309 | 45.6 | 4.8 | 96 | 1,882 | 1,786 | 19.5 |
| 14 | 3 | Nikola Tesla A3 | L | 305 | 55.2 | 4.6 | 104 | 1,792 | 1,688 | 17.2 |
| 15 | 20 | Novi Sad 2 | NG | 110 | 3.3 | 0.1 | 5 | 57 | 52 | 12.4 |
| 16 | 19 | Novi Sad 1 | NG | 135 | 4.0 | 0.1 | 5 | 61 | 56 | 11.4 |
| 17 | 21 | Zrenjanin | NG | 110 | 3.3 | 0.0 | 4 | 23 | 20 | 6.2 |
| 18 | 11 | Kolubara 3 | L | 64 | 8.2 | 0.3 | 12 | 55 | 43 | 4.7 |
| 19 | 22 | Sr. Mitrovica 1 | NG | 32 | 1.0 | 0.1 | 2 | 8 | 6 | 4.3 |
| 20 | 9 | Kolubara 1 | L | 32 | | | | | | |
| 21 | 10 | Kolubara 2 | L | 32 | | | | | | |
| 22 | 12 | Kolubara 4 | L | 32 | | | | | | |

Table A4-2.8: Ukraine - LCPs ranking related to the CBA implementation of LCPD

| Rank No | Code | Plant nfname | Fuel type | PowerMW | Costs | | NPV | | | B/C |
|---------|------|------------------|-----------|---------|-------------|----------|--------|--------|--------|------|
| | | | | | Investments | O&M | C | B | B-C | |
| | | | | | Mil, € | Mil, €/y | Mil, € | Mil, € | Mil, € | |
| 1 | 106a | Kyivska CHP-6 | FO | 500 | 18.8 | 0.6 | 25.6 | 742 | 716.2 | 29.0 |
| 2 | 85 | Zuevskaya 4 | HC | 325 | 63.5 | 6.9 | 136.6 | 3,353 | 3,216 | 24.5 |
| 3 | 83 | Zuevskaya 2 | HC | 320 | 75.0 | 6.7 | 145.9 | 3,366 | 3,220 | 23.1 |
| 4 | 87 | Kurakhovskaya 4 | HC | 210 | 39.1 | 4.4 | 85.7 | 1,977 | 1,891 | 23.1 |
| 5 | 82 | Zuevskaya 1 | HC | 325 | 75.3 | 6.5 | 144.0 | 3,303 | 3,159 | 22.9 |
| 6 | 51 | Dobrotvirskaya 7 | HC | 150 | 35.4 | 2.8 | 65.7 | 1,484 | 1,418 | 22.6 |
| 7 | 113 | Kharkivska CHP-2 | HC | 74 | 12.6 | 1.2 | 25.2 | 567 | 542 | 22.5 |
| 8 | 86 | Kurakhovskaya 3 | HC | 200 | 40.2 | 4.4 | 86.5 | 1,920 | 1,834 | 22.2 |
| 9 | 88 | Kurakhovskaya 5 | HC | 222 | 42.8 | 4.3 | 88.1 | 1,935 | 1,847 | 22.0 |
| 10 | 84 | Zuevskaya 3 | HC | 300 | 72.0 | 6.3 | 139.4 | 3,034 | 2,895 | 21.8 |
| 11 | 92 | Kurakhovskaya 9 | HC | 221 | 42.2 | 4.4 | 88.7 | 1,918 | 1,830 | 21.6 |
| 12 | 49 | Dobrotvirskaya 5 | HC | 100 | 14.8 | 1.4 | 29.9 | 633 | 603 | 21.2 |
| 13 | 50 | Dobrotvirskaya 6 | HC | 100 | 14.8 | 1.4 | 29.9 | 633 | 603 | 21.2 |
| 14 | 91 | Kurakhovskaya 8 | HC | 210 | 30.9 | 2.9 | 62.0 | 1,305 | 1,243 | 21.0 |
| 15 | 98 | Luganskaya 14 | HC | 200 | 48.6 | 4.0 | 90.9 | 1,890 | 1,799 | 20.8 |
| 16 | 89 | Kurakhovskaya 6 | HC | 210 | 36.2 | 2.8 | 65.5 | 1,325 | 1,260 | 20.2 |
| 17 | 42 | Burshtynska 6 | HC | 185 | 33.6 | 4.1 | 76.7 | 1,546 | 1,470 | 20.2 |
| 18 | 90 | Kurakhovskaya 7 | HC | 225 | 43.1 | 4.2 | 87.9 | 1,761 | 1,673 | 20.0 |
| 19 | 99 | Luganskaya 15 | HC | 200 | 50.9 | 3.7 | 90.2 | 1,769 | 1,679 | 19.6 |
| 20 | 97 | Luganskaya 13 | HC | 175 | 43.3 | 3.2 | 76.9 | 1,500 | 1,423 | 19.5 |
| 21 | 93 | Luganskaya 9 | HC | 200 | 48.5 | 3.9 | 90.2 | 1,752 | 1,661 | 19.4 |
| 22 | 77 | Vuglegirska 3 | HC | 300 | 68.6 | 5.3 | 125.2 | 2,425 | 2,300 | 19.4 |
| 23 | 78 | Vuglegirska 4 | HC | 300 | 68.6 | 5.3 | 125.2 | 2,423 | 2,297 | 19.3 |
| 24 | 75 | Vuglegirska 1 | HC | 300 | 68.6 | 5.3 | 125.2 | 2,416 | 2,291 | 19.3 |
| 25 | 76 | Vuglegirska 2 | HC | 300 | 68.6 | 5.3 | 125.2 | 2,411 | 2,286 | 19.3 |
| 26 | 40 | Burshtynska 4 | HC | 195 | 35.5 | 3.7 | 74.6 | 1,407 | 1,332 | 18.9 |

| Rank No | Code | Plant nfname | Fuel type | PowerMW | Costs | | NPV | | | B/C |
|---------|------|--------------------|-----------|---------|-------------|----------|--------|--------|--------|------|
| | | | | | Investments | O&M | C | B | B-C | |
| | | | | | Mil, € | Mil, €/y | Mil, € | Mil, € | Mil, € | |
| 27 | 102 | Darnytska CHP 6-9 | HC | 110 | 4.5 | 1.3 | 18.6 | 346 | 327 | 18.6 |
| 28 | 52 | Dobrotvirska 8 | HC | 150 | 37.3 | 2.1 | 59.2 | 1,090 | 1,031 | 18.4 |
| 29 | 44 | Burshtynska 8 | HC | 195 | 39.0 | 3.4 | 75.6 | 1,355 | 1,279 | 17.9 |
| 30 | 21 | Zaporiska 3 | HC | 300 | 66.2 | 4.9 | 118.4 | 2,121 | 2,002 | 17.9 |
| 31 | 47 | Burshtynska 11 | HC | 195 | 35.1 | 4.0 | 77.5 | 1,387 | 1,309 | 17.9 |
| 32 | 46 | Burshtynska 10 | HC | 195 | 35.9 | 3.9 | 77.2 | 1,375 | 1,298 | 17.8 |
| 33 | 45 | Burshtynska 9 | HC | 195 | 35.9 | 4.0 | 78.4 | 1,392 | 1,313 | 17.8 |
| 34 | 72 | Zmiivska 8 | HC | 325 | 75.2 | 3.8 | 115.8 | 2,039 | 1,923 | 17.6 |
| 35 | 95 | Luganskaya 11 | HC | 200 | 51.6 | 3.6 | 89.9 | 1,583 | 1,493 | 17.6 |
| 36 | 37 | Burshtynska 1 | HC | 195 | 35.6 | 3.8 | 76.0 | 1,300 | 1,224 | 17.1 |
| 37 | 20 | Zaporiska 2 | HC | 300 | 70.0 | 4.8 | 120.7 | 2,020 | 1,899 | 16.7 |
| 38 | 107 | Kramatorska CHP | HC | 120 | 15.5 | 1.3 | 29.2 | 486 | 457 | 16.7 |
| 39 | 39 | Burshtynska 3 | HC | 185 | 33.6 | 2.7 | 62.6 | 1,041 | 978 | 16.6 |
| 40 | 18 | Kryvorizka 10 | HC | 282 | 64.4 | 4.4 | 111.7 | 1,850 | 1,739 | 16.6 |
| 41 | 22 | Zaporiska 4 | HC | 300 | 70.4 | 4.5 | 118.2 | 1,939 | 1,821 | 16.4 |
| 42 | 10 | Kryvorizka 2 | HC | 282 | 64.7 | 5.1 | 118.7 | 1,935 | 1,816 | 16.3 |
| 43 | 13 | Kryvorizka 5 | HC | 282 | 63.1 | 4.5 | 111.1 | 1,810 | 1,698 | 16.3 |
| 44 | 2 | Prydniprovskaya 8 | HC | 150 | 34.6 | 2.5 | 60.7 | 959 | 898 | 15.8 |
| 45 | 48 | Burshtynska 12 | HC | 195 | 32.4 | 2.7 | 61.1 | 964 | 903 | 15.8 |
| 46 | 19 | Zaporiska 1 | HC | 325 | 65.9 | 3.9 | 107.2 | 1,645 | 1,538 | 15.3 |
| 47 | 12 | Kryvorizka 4 | HC | 282 | 59.1 | 4.5 | 106.6 | 1,622 | 1,515 | 15.2 |
| 48 | 43 | Burshtynska 7 | HC | 185 | 33.7 | 2.2 | 56.6 | 858 | 801 | 15.2 |
| 49 | 71 | Zmiivska 7 | HC | 275 | 67.0 | 2.9 | 98.0 | 1,470 | 1,372 | 15.0 |
| 50 | 9 | Kryvorizka 1 | HC | 282 | 62.2 | 4.0 | 105.2 | 1,578 | 1,473 | 15.0 |
| 51 | 16 | Kryvorizka 8 | HC | 282 | 64.4 | 3.8 | 104.4 | 1,559 | 1,454 | 14.9 |
| 52 | 109 | Myronivska 9 | HC | 115 | 12.7 | 1.7 | 30.7 | 457 | 427 | 14.9 |
| 53 | 55 | Ladyzhinska 3 | HC | 300 | 63.9 | 4.6 | 112.3 | 1,639 | 1,526 | 14.6 |
| 54 | 94 | Luganskaya 10 | HC | 200 | 40.3 | 2.3 | 65.1 | 943 | 878 | 14.5 |
| 55 | 108 | Myronivska 4 | HC | 60 | 6.3 | 0.6 | 13.1 | 185 | 172 | 14.1 |
| 56 | 5 | Prydniprovskaya 11 | HC | 310 | 69.0 | 4.3 | 114.2 | 1,527 | 1,413 | 13.4 |
| 57 | 73 | Zmiivska 9 | HC | 275 | 65.0 | 2.9 | 95.9 | 1,281 | 1,185 | 13.4 |
| 58 | 4 | Prydniprovskaya 10 | HC | 150 | 34.3 | 2.1 | 56.3 | 746 | 689 | 13.2 |
| 59 | 41 | Burshtynska 5 | HC | 195 | 38.6 | 1.9 | 59.3 | 774 | 715 | 13.0 |
| 60 | 54 | Ladyzhinska 2 | HC | 300 | 63.9 | 3.9 | 105.4 | 1,371 | 1,265 | 13.0 |
| 61 | 74 | Zmiivska 10 | HC | 275 | 66.5 | 2.9 | 96.8 | 1,230 | 1,133 | 12.7 |
| 62 | 110 | Odeska CHP-2 | NG | 68 | 2.2 | 0.2 | 4.0 | 51 | 47 | 12.5 |
| 63 | 103 | Kaluska CHP 1, 2 | HC | 100 | 11.0 | 1.0 | 21.5 | 262 | 240 | 12.2 |
| 64 | 38 | Burshtynska 2 | HC | 185 | 33.7 | 1.6 | 51.2 | 613 | 562 | 12.0 |
| 65 | 14 | Kryvorizka 6 | HC | 282 | 65.1 | 2.6 | 93.3 | 1,112 | 1,018 | 11.9 |
| 66 | 1 | Prydniprovskaya 7 | HC | 150 | 34.6 | 1.6 | 51.1 | 596 | 545 | 11.7 |
| 67 | 66 | Zmiivska 2 | HC | 175 | 43.6 | 1.9 | 63.7 | 737 | 673 | 11.6 |
| 68 | 53 | Ladyzhinska 1 | HC | 300 | 65.1 | 3.1 | 98.1 | 1,107 | 1,008 | 11.3 |
| 69 | 68 | Zmiivska 4 | HC | 175 | 43.6 | 1.9 | 63.7 | 716 | 652 | 11.2 |
| 70 | 56 | Ladyzhinska 4 | HC | 300 | 63.9 | 2.7 | 92.4 | 968 | 876 | 10.5 |
| 71 | 7 | Prydniprovskaya 13 | HC | 285 | 68.3 | 2.7 | 97.5 | 1,020 | 922 | 10.5 |
| 72 | 65 | Zmiivska 1 | HC | 175 | 53.1 | 1.9 | 73.3 | 755 | 682 | 10.3 |
| 73 | 70 | Zmiivska 6 | HC | 175 | 43.6 | 1.9 | 63.4 | 649 | 585 | 10.2 |
| 74 | 69 | Zmiivska 5 | HC | 175 | 55.1 | 1.9 | 75.4 | 728 | 653 | 9.7 |
| 75 | 67 | Zmiivska 3 | HC | 175 | 55.1 | 1.9 | 75.3 | 726 | 651 | 9.7 |
| 76 | 57 | Ladyzhinska 5 | HC | 300 | 63.9 | 2.1 | 86.2 | 786 | 700 | 9.1 |
| 77 | 58 | Ladyzhinska 6 | HC | 300 | 63.9 | 2.0 | 85.2 | 756 | 671 | 8.9 |
| 78 | 60 | Trypilka 2 | HC | 300 | 63.0 | 4.3 | 108.5 | 668 | 559 | 6.2 |
| 79 | 61 | Trypilka 3 | HC | 300 | 63.8 | 4.3 | 109.0 | 441 | 332 | 4.0 |
| 80 | 62 | Trypilka 4 | HC | 300 | 63.8 | 4.3 | 109.1 | 431 | 322 | 4.0 |
| 81 | 59 | Trypilka 1 | HC | 300 | 63.8 | 4.3 | 109.1 | 408 | 299 | 3.7 |
| 82 | 104 | Kaluska CHP 3, 4 | NG | 100 | 0.4 | 0.1 | 1.8 | 6 | 4 | 3.4 |
| 83 | 106 | Kyivska CHP-6 | NG | 500 | 8.1 | 0.6 | 14.9 | 36 | 22 | 2.5 |
| 84 | 105 | Kyivska CHP-5 | NG | 540 | 8.5 | 0.7 | 15.8 | | | |
| 85 | 105a | Kyivska CHP-5 | FO | 540 | 8.5 | 0.7 | 15.8 | | | |
| 86 | 3 | Prydniprovskaya 9 | HC | 150 | 32.4 | 0.0 | 32.4 | | | |
| 87 | 6 | Prydniprovskaya 12 | HC | 285 | 65.4 | 0.0 | 65.4 | | | |
| 88 | 8 | Prydniprovskaya 14 | HC | 285 | 68.3 | 0.0 | 68.3 | | | |
| 89 | 11 | Kryvorizka 3 | HC | 282 | 57.9 | 0.0 | 57.9 | | | |

| Rank No | Code | Plant nfname | Fuel type | PowerMW | Costs | | NPV | | | B/C |
|---------|------|--------------------|-----------|---------|-------------|----------|--------|--------|--------|-----|
| | | | | | Investments | O&M | C | B | B-C | |
| | | | | | Mil, € | Mil, €/y | Mil, € | Mil, € | Mil, € | |
| 90 | 15 | Kryvorizka 7 | HC | 282 | 64.4 | 0.0 | 64.4 | | | |
| 91 | 17 | Kryvorizka 9 | HC | 282 | 63.3 | 0.0 | 63.3 | | | |
| 92 | 23 | Zaporiska 5 | NG | 800 | 24.0 | 0.0 | 24.0 | | | |
| 93 | 24 | Zaporiska 6 | NG | 800 | 25.0 | 0.0 | 25.0 | | | |
| 94 | 25 | Zaporiska 7 | NG | 800 | 25.6 | 0.0 | 25.6 | | | |
| 95 | 26 | Starobeshivska 4 | HC | 175 | 25.0 | 1.7 | 42.9 | | | |
| 96 | 27 | Starobeshivska 5 | HC | 175 | 40.0 | 2.2 | 63.2 | | | |
| 97 | 28 | Starobeshivska 6 | HC | 175 | 37.9 | 2.2 | 61.1 | | | |
| 98 | 29 | Starobeshivska 7 | HC | 175 | 37.2 | 2.2 | 60.4 | | | |
| 99 | 30 | Starobeshivska 8 | HC | 175 | 37.2 | 2.2 | 60.4 | | | |
| 100 | 31 | Starobeshivska 9 | HC | 175 | 38.2 | 2.2 | 61.4 | | | |
| 101 | 32 | Starobeshivska 10 | HC | 175 | 39.2 | 2.2 | 62.4 | | | |
| 102 | 33 | Starobeshivska 11 | HC | 175 | 39.2 | 2.2 | 62.4 | | | |
| 103 | 34 | Starobeshivska 12 | HC | 175 | 33.8 | 2.2 | 57.0 | | | |
| 104 | 35 | Starobeshivska 13 | HC | 175 | 31.6 | 2.2 | 54.8 | | | |
| 105 | 36 | Slovianska 7 | HC | 800 | 169.3 | 10.0 | 275.3 | | | |
| 106 | 63 | Trypilska 5 | NG | 300 | 22.3 | 0.0 | 22.3 | | | |
| 107 | 64 | Trypilska 6 | NG | 300 | 22.3 | 0.0 | 22.3 | | | |
| 108 | 79 | Vuglegirska 5 | NG | 800 | 65.0 | 0.0 | 65.0 | | | |
| 109 | 80 | Vuglegirska 6 | NG | 800 | 65.0 | 0.0 | 65.0 | | | |
| 110 | 81 | Vuglegirska 7 | NG | 800 | 65.0 | 0.0 | 65.0 | | | |
| 111 | 96 | Luganskaya 12 | HC | 175 | 29.3 | 0.0 | 29.3 | | | |
| 112 | 100 | Bilotserkivska CHP | NG | 120 | 0.0 | 0.0 | 0.0 | | | |
| 113 | 101 | Darnytska CHP 5,10 | NG | 50 | 0.0 | 0.0 | 0.0 | | | |
| 114 | 111 | Sevastopolska CHP | NG | 55 | 0.0 | 0.0 | 0.0 | | | |
| 115 | 112 | Simferopilska CHP | NG | 278 | 0.0 | 0.0 | 0.0 | | | |

Table A4-2.9: Kosovo* - LCPs ranking related to the CBA implementation of LCPD

| Rank No | Code | Plant name | Fuel type | Power MW | Costs | | NPV | | | B/C |
|---------|------|------------|-----------|----------|-------------|----------|--------|--------|--------|-----|
| | | | | | Investments | O&M | C | B | B-C | |
| | | | | | Mil, € | Mil, €/y | Mil, € | Mil, € | Mil, € | |
| 1 | 5 | Kosovo B2 | L | 339 | 39,0 | 3,7 | 78 | 600 | 521 | 7,7 |
| 2 | 4 | Kosovo B1 | L | 339 | 39,0 | 3,7 | 78 | 594 | 516 | 7,6 |
| 3 | 1 | Kosovo A3 | L | 200 | | | | | | |
| 4 | 2 | Kosovo A4 | L | 200 | | | | | | |
| 5 | 3 | Kosovo A5 | L | 210 | | | | | | |

NB: "0" Appears in case that no data are available or if the TPP is lying up

A4.3. Benefit-Cost Ranking for IED Scenario

Table A4-3.1: Albania - LCPs ranking related to the CBA implementation of IED

| Rank No | Code | Plant name | Fuel type | Power MW | Costs | | PV | | | B/C |
|---------|------|------------|-----------|----------|-------------|----------|--------|--------|--------|-----|
| | | | | | Investments | O&M | C | B | B-C | |
| | | | | | Mil, € | Mil, €/y | Mil, € | Mil, € | Mil, € | |
| 1 | 1 | Vlora | NG | 100 | | | | | | - |

Table A4-3.2: BiH - LCPs ranking related to the CBA implementation of IED

| Rank No | Code | Plant Name | Fuel type | Power MW | Costs | | PV | | | B/C |
|---------|------|------------|-----------|----------|-------------|----------|--------|--------|--------|------|
| | | | | | Investments | O&M | C | B | B-C | |
| | | | | | Mil, € | Mil, €/y | Mil, € | Mil, € | Mil, € | |
| 1 | 2 | Ugljevik | L | 300 | 118.4 | 12.7 | 254 | 17,847 | 17,594 | 70.4 |
| 2 | 9 | Kakanj 7 | L | 230 | 63.5 | 6.0 | 127 | 5,242 | 5,115 | 41.2 |
| 3 | 7 | Kakanj 5 | L | 110 | 36.2 | 2.7 | 65 | 2,323 | 2,257 | 35.5 |
| 4 | 8 | Kakanj 6 | L | 110 | 27.7 | 1.4 | 42 | 1,155 | 1,112 | 27.3 |
| 5 | 6 | Tuzla 6 | L | 215 | 46.6 | 2.8 | 76 | 1,814 | 1,738 | 23.7 |
| 6 | 5 | Tuzla 5 | L | 200 | 20.0 | 2.2 | 44 | 966 | 922 | 22.1 |
| 7 | 4 | Tuzla 4 | L | 200 | 25.0 | 3.5 | 62 | 1,343 | 1,281 | 21.7 |
| 8 | 1 | Gacko | L | 300 | 37.3 | 6.7 | 108 | 1,592 | 1,483 | 14.7 |
| 9 | 3 | Tuzla 3 | L | 110 | | | | | | |

Table A4-3.3: Croatia - LCPs ranking related to the CBA implementation of IED

| Rank No | Code | Plant name | Fuel type | Power MW | Costs | | PV | | | B/C |
|---------|------|---------------------|-----------|----------|-------------|----------|--------|---------|---------|------|
| | | | | | Investments | O&M | C | B | B-C | |
| | | | | | Mil, € | Mil, €/y | Mil, € | Mil, € | Mil, € | |
| 1 | 3 | TPP Rijeka | FO | 320 | 89 | 6 | 152 | 2,686.2 | 2,534.0 | 17.6 |
| 2 | 4 | TPP Sisak A | FO | 210 | 76 | 4 | 116 | 1,972.4 | 1,856.0 | 16.9 |
| 3 | 5 | TPP Sisak B | FO | 210 | 76 | 4 | 116 | 1,972.4 | 1,856.0 | 16.9 |
| 4 | 8 | CHP Zagreb C | NG | 120 | 37 | 2 | 53 | 582.4 | 529.3 | 11.0 |
| 5 | 12 | CHP Zagreb EL-TOK8 | NG | 30 | 8 | 0 | 10 | 100.3 | 90.0 | 9.7 |
| 6 | 13 | CHP Zagreb EL-TOH | NG | 25 | 1 | 0 | 2 | 15.2 | 13.5 | 8.8 |
| 7 | 14 | CHP Zagreb EL-TOJ | NG | 25 | 1 | 0 | 2 | 12.1 | 10.4 | 7.0 |
| 8 | 15 | CHP Osijek A | NG | 46 | 1 | 0 | 3 | 18.5 | 15.5 | 6.3 |
| 9 | 11 | CHP Zagreb EL-TO K6 | NG | 11 | 7 | 0 | 8 | 40.1 | 32.5 | 5.2 |
| 10 | 16 | CHP Osijek B | NG | 25 | 1 | 0 | 1 | 3.0 | 2.0 | 3.1 |
| 11 | 2 | TPP Plomin 2 | HC | 210 | 20 | 2 | 41 | 115.0 | 74.2 | 2.8 |
| 12 | 7 | TPP Jertovac 2 | NG | 40 | 1 | 0 | 1 | 2.8 | 1.5 | 2.2 |
| 13 | 6 | TPP Jertovac 1 | NG | 40 | 1 | 0 | 1 | 2.7 | 1.4 | 2.1 |
| 14 | 17 | CHP Osijek C | NG | 25 | 1 | 0 | 1 | 1.5 | 0.7 | 1.8 |
| 15 | 1 | TPP Plomin 1 | HC | 125 | | | | | | |
| 16 | 9 | CHP Zagreb K | NG | 208 | | | | | | |
| 17 | 10 | CHP Zagreb L | NG | 112 | | | | | | |

Table A4-3.4: FYR Macedonia - LCPs ranking related to the CBA implementation of IED

| Rank No | Code | Plant Name | Fuel type | Power MW | COSTS | | PV | | | B/C |
|---------|------|------------|-----------|----------|-------------|----------|--------|--------|--------|------|
| | | | | | Investments | O&M | C | B | B-C | |
| | | | | | Mil, € | Mil, €/y | Mil, € | Mil, € | Mil, € | |
| 1 | 1 | Bitola 1 | L | 233 | 78 | 5 | 135 | 3,345 | 3,209 | 24.7 |
| 2 | 2 | Bitola 2 | L | 233 | 78 | 5 | 133 | 2,761 | 2,629 | 20.8 |
| 3 | 3 | Bitola 3 | L | 233 | 78 | 5 | 133 | 2,761 | 2,629 | 20.8 |
| 4 | 4 | Oslomej | L | 125 | 37 | 2 | 55 | 1,168 | 1,112 | 21.1 |
| 5 | 5 | Negotino | FO | 210 | | | | | | |
| | 6 | Skopje CHP | NG | 227 | | | | | | |
| | 7 | Kogel CHP | NG | 30 | | | | | | |

Table A4-3.5: Moldova - LCPs ranking related to the CBA implementation of IED

| Rank No | Code | Plant Name | Fuel type | Power MW | Costs | | PV | | | B/C |
|---------|------|-------------|-----------|----------|-------------|----------|--------|--------|--------|-----|
| | | | | | Investments | O&M | C | B | B-C | |
| | | | | | Mil, € | Mil, €/y | Mil, € | Mil, € | Mil, € | |
| 1 | 7 | CET-2, No 2 | NG | 80 | 0.6 | 0.1 | 1.8 | 7.3 | 5.5 | 4.1 |
| 2 | 8 | CET-2, No 3 | NG | 80 | 0.6 | 0.1 | 1.8 | 5.6 | 3.8 | 3.1 |
| 3 | 6 | CET-2, No 1 | NG | 80 | 0.6 | 0.1 | 1.9 | 5.3 | 3.4 | 2.8 |
| 4 | 3 | CET-1, No 3 | NG | 10 | 0.1 | 0.0 | 0.2 | 0.3 | 0.1 | 1.5 |
| 5 | 2 | CET-1, No 2 | NG | 12 | 0.1 | 0.0 | 0.2 | 0.3 | 0.1 | 1.3 |
| 6 | 1 | CET-1, No 1 | NG | 12 | | | | | | |
| 7 | 4 | CET-1, No 4 | NG | 27 | | | | | | |
| 8 | 5 | CET-1, No 5 | NG | 5 | | | | | | |

Table A4-3.6: Montenegro - LCPs ranking related to the CBA implementation of IED

| Rank No | Code | Plant Name | Fuel type | Power MW | Costs | | PV | | | B/C |
|---------|------|------------|-----------|----------|-------------|----------|--------|--------|--------|-----|
| | | | | | Investments | O&M | C | B | B-C | |
| | | | | | Mil, € | Mil, €/y | Mil, € | Mil, € | Mil, € | |
| 1 | 1 | Pljevlja | Lignite | 219 | 51 | 4.3 | 96.8 | 4,886 | 4,789 | 50 |

Table A4-3.7: Serbia - LCPs ranking related to the CBA implementation of IED

| Rank No | Code | Plant Name | Fuel type | Power MW | COSTS | | PV | | | B/C |
|---------|------|-----------------|-----------|----------|-------------|----------|--------|--------|--------|-----|
| | | | | | Investments | O&M | C | B | B-C | |
| | | | | | Mil, € | Mil, €/y | Mil, € | Mil, € | Mil, € | |
| 1 | 16 | Kostolac A2 | L | 210 | 10.1 | 4 | 51 | 4,044 | 3,993 | 79 |
| 2 | 17 | Kostolac B1 | L | 348 | 75.8 | 5 | 131 | 6,557 | 6,426 | 50 |
| 3 | 18 | Kostolac B2 | L | 348 | 70.6 | 7 | 147 | 5,748 | 5,601 | 39 |
| 4 | 14 | Morava | L | 125 | 22.4 | 1 | 36 | 1,285 | 1,249 | 36 |
| 5 | 13 | Kolubara 5 | L | 110 | 12.1 | 2 | 29 | 870 | 841 | 30 |
| 6 | 15 | Kostolac A1 | L | 100 | 54.8 | 2 | 74 | 2,094 | 2,019 | 28 |
| 7 | 1 | Nikola Tesla A1 | L | 210 | 24.9 | 3 | 56 | 1,311 | 1,254 | 23 |
| 8 | 2 | Nikola Tesla A2 | L | 210 | 24.7 | 3 | 55 | 1,275 | 1,220 | 23 |
| 9 | 8 | Nikola Tesla B2 | L | 620 | 84.6 | 10 | 187 | 4,259 | 4,071 | 23 |
| 10 | 7 | Nikola Tesla B1 | L | 620 | 94.0 | 10 | 201 | 4,374 | 4,173 | 22 |
| 11 | 4 | Nikola Tesla A4 | L | 309 | 49.6 | 5 | 101 | 2,106 | 2,005 | 21 |
| 12 | 5 | Nikola Tesla A5 | L | 309 | 49.6 | 5 | 101 | 2,097 | 1,996 | 21 |
| 13 | 6 | Nikola Tesla A6 | L | 309 | 49.6 | 5 | 100 | 2,084 | 1,984 | 21 |
| 14 | 3 | Nikola Tesla A3 | L | 305 | 59.2 | 5 | 108 | 1,992 | 1,884 | 18 |
| 15 | 11 | Kolubara 3 | L | 64 | 9.4 | 0 | 13 | 221 | 208 | 18 |
| 16 | 20 | Novi Sad 2 | NG | 110 | 4.8 | 1 | 10 | 144 | 134 | 14 |
| 17 | 19 | Novi Sad 1 | NG | 135 | 5.9 | 1 | 12 | 156 | 144 | 13 |
| 18 | 22 | Sr. Mitrovica 1 | NG | 32 | 1.8 | 0 | 3 | 21 | 18 | 8 |
| 19 | 21 | Zrenjanin | NG | 110 | 4.8 | 0 | 6 | 30 | 24 | 5 |
| | 9 | Kolubara 1 | L | 32 | | | | | | |
| | 10 | Kolubara 2 | L | 32 | | | | | | |
| | 12 | Kolubara 4 | L | 32 | | | | | | |

Table A4-3.8: Ukraine - LCPs ranking related to the CBA implementation of IED

| Rank No | Code | Plant Name | Fuel type | Power MW | COSTS | | PV | | | B/C |
|---------|------|------------------|-----------|----------|-------------|----------|--------|--------|--------|------|
| | | | | | Investments | O&M | C | B | B-C | |
| | | | | | Mil, € | Mil, €/y | Mil, € | Mil, € | Mil, € | |
| 1 | 50 | Dobrotvirskaya 6 | HC | 100 | 13.7 | 1 | 29 | 780 | 751 | 26.7 |
| 2 | 52 | Dobrotvirskaya 8 | HC | 150 | 21.0 | 2 | 44 | 1,132 | 1,088 | 25.9 |
| 3 | 113 | Kharkivska CHP-2 | HC | 74 | 14.7 | 1 | 30 | 745 | 715 | 24.8 |
| 4 | 85 | Zuevskaya 4 | HC | 325 | 67.3 | 8 | 148 | 3,476 | 3,328 | 23.5 |
| 5 | 83 | Zuevskaya 2 | HC | 320 | 69.3 | 7 | 148 | 3,481 | 3,333 | 23.5 |
| 6 | 82 | Zuevskaya 1 | HC | 325 | 69.6 | 7 | 146 | 3,416 | 3,269 | 23.4 |
| 7 | 87 | Kurakhovskaya 4 | HC | 210 | 43.6 | 4 | 90 | 2,053 | 1,963 | 22.8 |
| 8 | 84 | Zuevskaya 3 | HC | 300 | 66.1 | 7 | 140 | 3,146 | 3,006 | 22.5 |
| 9 | 88 | Kurakhovskaya 5 | HC | 222 | 46.8 | 4 | 92 | 2,009 | 1,916 | 21.8 |
| 10 | 86 | Kurakhovskaya 3 | HC | 200 | 47.0 | 4 | 93 | 1,996 | 1,903 | 21.4 |
| 11 | 92 | Kurakhovskaya 9 | HC | 221 | 47.4 | 4 | 94 | 1,995 | 1,901 | 21.2 |
| 12 | 98 | Luganskaya 14 | HC | 200 | 50.1 | 4 | 95 | 1,972 | 1,878 | 20.8 |
| 13 | 42 | Burshtynska 6 | HC | 185 | 36.4 | 4 | 80 | 1,617 | 1,538 | 20.3 |
| 14 | 97 | Luganskaya 13 | HC | 175 | 44.8 | 4 | 84 | 1,710 | 1,626 | 20.3 |

| Rank No | Code | Plant Name | Fuel type | Power MW | COSTS | | PV | | | B/C |
|---------|------|-------------------|-----------|----------|-------------|----------|--------|--------|--------|------|
| | | | | | Investments | O&M | C | B | B-C | |
| | | | | | Mil, € | Mil, €/y | Mil, € | Mil, € | Mil, € | |
| 15 | 91 | Kurakhovskaya 8 | HC | 210 | 36.0 | 3 | 67 | 1,356 | 1,289 | 20.2 |
| 16 | 89 | Kurakhovskaya 6 | HC | 210 | 40.1 | 3 | 69 | 1,376 | 1,306 | 19.8 |
| 17 | 93 | Luganskaya 9 | HC | 200 | 50.0 | 4 | 93 | 1,834 | 1,741 | 19.7 |
| 18 | 90 | Kurakhovskaya 7 | HC | 225 | 48.1 | 4 | 93 | 1,835 | 1,742 | 19.7 |
| 19 | 99 | Luganskaya 15 | HC | 200 | 53.0 | 4 | 94 | 1,846 | 1,752 | 19.6 |
| 20 | 40 | Burshtynska 4 | HC | 195 | 38.5 | 4 | 78 | 1,471 | 1,393 | 19.0 |
| 21 | 77 | Vuglegirska 3 | HC | 300 | 73.7 | 6 | 133 | 2,522 | 2,389 | 19.0 |
| 22 | 78 | Vuglegirska 4 | HC | 300 | 73.7 | 6 | 133 | 2,519 | 2,386 | 18.9 |
| 23 | 75 | Vuglegirska 1 | HC | 300 | 73.7 | 6 | 133 | 2,512 | 2,379 | 18.9 |
| 24 | 76 | Vuglegirska 2 | HC | 300 | 73.7 | 6 | 133 | 2,508 | 2,375 | 18.8 |
| 25 | 107 | Kramatorska CHP | HC | 120 | 23.2 | 1 | 37 | 675 | 638 | 18.3 |
| 26 | 47 | Burshtynska 11 | HC | 195 | 38.1 | 4 | 81 | 1,456 | 1,376 | 18.1 |
| 27 | 46 | Burshtynska 10 | HC | 195 | 38.9 | 4 | 80 | 1,441 | 1,361 | 18.0 |
| 28 | 45 | Burshtynska 9 | HC | 195 | 38.9 | 4 | 81 | 1,460 | 1,378 | 17.9 |
| 29 | 44 | Burshtynska 8 | HC | 195 | 42.4 | 3 | 79 | 1,412 | 1,333 | 17.9 |
| 30 | 95 | Luganskaya 11 | HC | 200 | 53.9 | 4 | 94 | 1,657 | 1,563 | 17.7 |
| 31 | 51 | Dobrotvirska 7 | HC | 150 | 56.4 | 3 | 88 | 1,541 | 1,453 | 17.6 |
| 32 | 21 | Zaporiska 3 | HC | 300 | 70.3 | 5 | 127 | 2,211 | 2,084 | 17.4 |
| 33 | 37 | Burshtynska 1 | HC | 195 | 38.6 | 4 | 79 | 1,360 | 1,281 | 17.2 |
| 34 | 39 | Burshtynska 3 | HC | 185 | 36.4 | 3 | 65 | 1,089 | 1,023 | 16.7 |
| 35 | 72 | Zmiivska 8 | HC | 325 | 81.2 | 4 | 127 | 2,103 | 1,976 | 16.5 |
| 36 | 20 | Zaporiska 2 | HC | 300 | 74.4 | 5 | 130 | 2,108 | 1,979 | 16.3 |
| 37 | 108 | Myronivska 4 | HC | 60 | 11.0 | 1 | 21 | 347 | 326 | 16.3 |
| 38 | 103 | Kaluska CHP 1, 2 | HC | 100 | 15.0 | 1 | 26 | 410 | 384 | 16.1 |
| 39 | 18 | Kryvorizka 10 | HC | 282 | 69.1 | 5 | 121 | 1,930 | 1,808 | 15.9 |
| 40 | 109 | Myronivska 9 | HC | 115 | 20.8 | 2 | 46 | 732 | 686 | 15.9 |
| 41 | 22 | Zaporiska 4 | HC | 300 | 74.8 | 5 | 127 | 2,023 | 1,895 | 15.9 |
| 42 | 48 | Burshtynska 12 | HC | 195 | 35.1 | 3 | 64 | 1,012 | 948 | 15.9 |
| 43 | 10 | Kryvorizka 2 | HC | 282 | 69.5 | 5 | 128 | 2,024 | 1,897 | 15.8 |
| 44 | 13 | Kryvorizka 5 | HC | 282 | 67.5 | 5 | 120 | 1,889 | 1,769 | 15.8 |
| 45 | 2 | Prydniprovska 8 | HC | 150 | 38.4 | 3 | 66 | 1,008 | 942 | 15.3 |
| 46 | 94 | Luganskaya 10 | HC | 200 | 40.3 | 2 | 65 | 993 | 928 | 15.2 |
| 47 | 43 | Burshtynska 7 | HC | 185 | 36.5 | 2 | 59 | 895 | 835 | 15.1 |
| 48 | 19 | Zaporiska 1 | HC | 325 | 70.1 | 4 | 115 | 1,718 | 1,602 | 14.9 |
| 49 | 12 | Kryvorizka 4 | HC | 282 | 62.8 | 5 | 114 | 1,700 | 1,586 | 14.9 |
| 50 | 9 | Kryvorizka 1 | HC | 282 | 66.6 | 4 | 113 | 1,651 | 1,539 | 14.6 |
| 51 | 49 | Dobrotvirska 5 | HC | 100 | 37.9 | 1 | 53 | 780 | 727 | 14.6 |
| 52 | 16 | Kryvorizka 8 | HC | 282 | 69.1 | 4 | 113 | 1,626 | 1,513 | 14.4 |
| 53 | 71 | Zmiivska 7 | HC | 275 | 72.3 | 3 | 107 | 1,532 | 1,425 | 14.4 |
| 54 | 55 | Ladyzhinska 3 | HC | 300 | 70.0 | 5 | 121 | 1,724 | 1,603 | 14.2 |
| 55 | 41 | Burshtynska 5 | HC | 195 | 40.9 | 2 | 62 | 808 | 746 | 13.1 |
| 56 | 73 | Zmiivska 9 | HC | 275 | 70.3 | 3 | 104 | 1,337 | 1,234 | 12.9 |
| 57 | 5 | Prydniprovska 11 | HC | 310 | 76.8 | 5 | 125 | 1,606 | 1,481 | 12.9 |
| 58 | 102 | Darnytska CHP 6-9 | HC | 110 | 27.1 | 2 | 43 | 555 | 512 | 12.9 |
| 59 | 4 | Prydniprovska 10 | HC | 150 | 38.4 | 2 | 61 | 788 | 727 | 12.8 |
| 60 | 54 | Ladyzhinska 2 | HC | 300 | 70.0 | 4 | 114 | 1,445 | 1,330 | 12.7 |
| 61 | 74 | Zmiivska 10 | HC | 275 | 72.0 | 3 | 105 | 1,288 | 1,183 | 12.3 |
| 62 | 66 | Zmiivska 2 | HC | 175 | 45.5 | 2 | 65 | 779 | 714 | 12.0 |
| 63 | 38 | Burshtynska 2 | HC | 185 | 36.5 | 2 | 54 | 642 | 588 | 11.9 |
| 64 | 68 | Zmiivska 4 | HC | 175 | 45.5 | 2 | 65 | 758 | 693 | 11.7 |
| 65 | 14 | Kryvorizka 6 | HC | 282 | 69.9 | 3 | 101 | 1,159 | 1,058 | 11.5 |
| 66 | 1 | Prydniprovska 7 | HC | 150 | 38.4 | 2 | 56 | 629 | 574 | 11.3 |
| 67 | 53 | Ladyzhinska 1 | HC | 300 | 71.5 | 3 | 107 | 1,166 | 1,059 | 10.9 |
| 68 | 70 | Zmiivska 6 | HC | 175 | 45.5 | 2 | 64 | 691 | 627 | 10.9 |
| 69 | 65 | Zmiivska 1 | HC | 175 | 57.3 | 2 | 77 | 798 | 721 | 10.4 |
| 70 | 7 | Prydniprovska 13 | HC | 285 | 74.0 | 3 | 105 | 1,074 | 969 | 10.2 |
| 71 | 56 | Ladyzhinska 4 | HC | 300 | 70.0 | 3 | 100 | 1,019 | 919 | 10.2 |
| 72 | 69 | Zmiivska 5 | HC | 175 | 59.8 | 2 | 79 | 770 | 691 | 9.7 |
| 73 | 67 | Zmiivska 3 | HC | 175 | 59.8 | 2 | 79 | 768 | 689 | 9.7 |
| 74 | 57 | Ladyzhinska 5 | HC | 300 | 70.0 | 2 | 94 | 826 | 732 | 8.8 |
| 75 | 58 | Ladyzhinska 6 | HC | 300 | 70.0 | 2 | 93 | 794 | 701 | 8.6 |
| 76 | 106a | Kyivska CHP-6 | FO | 500 | 87.1 | 4 | 127 | 843 | 717 | 6.7 |

| Rank No | Code | Plant Name | Fuel type | Power MW | COSTS | | PV | | | B/C |
|---------|------|--------------------|-----------|----------|-------------|----------|--------|--------|--------|-----|
| | | | | | Investments | O&M | C | B | B-C | |
| | | | | | Mil, € | Mil, €/y | Mil, € | Mil, € | Mil, € | - |
| 77 | 60 | Trypilska 2 | HC | 300 | 68.3 | 4 | 114 | 757 | 643 | 6.6 |
| 78 | 110 | Odeska CHP-2 | NG | 68 | 7.8 | 0 | 11 | 65 | 54 | 6.0 |
| 79 | 61 | Trypilska 3 | HC | 300 | 69.5 | 4 | 110 | 531 | 420 | 4.8 |
| 80 | 62 | Trypilska 4 | HC | 300 | 69.5 | 4 | 110 | 521 | 411 | 4.7 |
| 81 | 59 | Trypilska 1 | HC | 300 | 69.5 | 4 | 110 | 497 | 387 | 4.5 |
| 82 | 100 | Bilotserkijska CHP | NG | 120 | 3.6 | 0 | 7 | 24 | 17 | 3.5 |
| 83 | 111 | Sevastopolska CHP | NG | 55 | 1.2 | 0 | 3 | 7 | 4 | 2.6 |
| 84 | 104 | Kaluska CHP 3, 4 | NG | 100 | 9.5 | 0 | 14 | 26 | 12 | 1.9 |
| 85 | 101 | Darnytska CHP 5,10 | NG | 50 | 4.5 | 0 | 7 | 11 | 4 | 1.6 |
| 86 | 112 | Simferopilska CHP | NG | 278 | 1.4 | 0 | 5 | 7 | 2 | 1.4 |
| 87 | 106 | Kyivska CHP-6 | NG | 500 | 32.6 | 1 | 44 | 59 | 15 | 1.4 |
| 88 | 3 | Prydniprovskya 9 | HC | 150 | 35.6 | 0 | 36 | | | |
| 89 | 6 | Prydniprovskya 12 | HC | 285 | 70.4 | 0 | 70 | | | |
| 90 | 8 | Prydniprovskya 14 | HC | 285 | 74.0 | 0 | 74 | | | |
| 91 | 11 | Kryvorizka 3 | HC | 282 | 60.5 | 0 | 61 | | | |
| 92 | 15 | Kryvorizka 7 | HC | 282 | 69.1 | 0 | 69 | | | |
| 93 | 17 | Kryvorizka 9 | HC | 282 | 67.1 | 0 | 67 | | | |
| 94 | 23 | Zaporiska 5 | NG | 800 | 24.0 | 0 | 24 | | | |
| 95 | 24 | Zaporiska 6 | NG | 800 | 25.0 | 0 | 25 | | | |
| 96 | 25 | Zaporiska 7 | NG | 800 | 25.6 | 0 | 26 | | | |
| 97 | 26 | Starobeshivska 4 | HC | 175 | 56.5 | 2 | 80 | | | |
| 98 | 27 | Starobeshivska 5 | HC | 175 | 68.0 | 2 | 91 | | | |
| 99 | 28 | Starobeshivska 6 | HC | 175 | 65.6 | 2 | 89 | | | |
| 100 | 29 | Starobeshivska 7 | HC | 175 | 64.9 | 2 | 88 | | | |
| 101 | 30 | Starobeshivska 8 | HC | 175 | 64.9 | 2 | 88 | | | |
| 102 | 31 | Starobeshivska 9 | HC | 175 | 66.0 | 2 | 89 | | | |
| 103 | 32 | Starobeshivska 10 | HC | 175 | 66.5 | 2 | 90 | | | |
| 104 | 33 | Starobeshivska 11 | HC | 175 | 66.5 | 2 | 90 | | | |
| 105 | 34 | Starobeshivska 12 | HC | 175 | 61.1 | 2 | 84 | | | |
| 106 | 35 | Starobeshivska 13 | HC | 175 | 58.7 | 2 | 82 | | | |
| 107 | 36 | Slovianska 7 | HC | 800 | 180.8 | 10 | 287 | | | |
| 108 | 63 | Trypilska 5 | NG | 300 | 22.3 | 0 | 22 | | | |
| 109 | 64 | Trypilska 6 | NG | 300 | 22.3 | 0 | 22 | | | |
| 110 | 79 | Vuglegirska 5 | NG | 800 | 65.0 | 0 | 65 | | | |
| 111 | 80 | Vuglegirska 6 | NG | 800 | 65.0 | 0 | 65 | | | |
| 112 | 81 | Vuglegirska 7 | NG | 800 | 65.0 | 0 | 65 | | | |
| 113 | 96 | Luganskaya 12 | HC | 175 | 42.3 | 0 | 42 | | | |
| 114 | 105 | Kyivska CHP-5 | NG | 540 | 35.0 | 1 | 47 | | | |
| 115 | 105a | Kyivska CHP-5 | FO | 540 | 94.0 | 3 | 128 | | | |

Table A.4-3.9: Kosovo* - LCPs ranking related to the CBA implementation of IED

| Rank No | Code | Plant Name | Fuel type | Power MW | COSTS | | PV | | | B/C |
|---------|------|------------|-----------|----------|-------------|----------|--------|--------|--------|-----|
| | | | | | Investments | O&M | C | B | B-C | |
| | | | | | Mil, € | Mil, €/y | Mil, € | Mil, € | Mil, € | - |
| 1 | 4 | Kosovo B1 | L | 339 | 42.1 | 4 | 81 | 728 | 647 | 9 |
| 2 | 5 | Kosovo B2 | L | 339 | 42.1 | 4 | 81 | 733 | 652 | 9 |
| 3 | 1 | Kosovo A3 | L | 200 | | | | | | |
| 4 | 2 | Kosovo A4 | L | 200 | | | | | | |
| 5 | 3 | Kosovo A5 | L | 210 | | | | | | |


Annex 5 Requirements of LCP Directive and IE Directive

Requirements from the LCP Directive

EMISSION LIMIT VALUES FOR SO₂

Solid fuel

A, SO₂ emission limit values expressed in mg/Nm³ (O₂ content 6 %) to be applied by new and existing plants pursuant to Article 4(1) and 4(3) respectively:



NB, Where the emission limit values above cannot be met due to the characteristics of the fuel, a rate of desulphurization of at least 60 % shall be achieved in the case of plants with a rated thermal input of less than or equal to 100 MWth, 75 % for plants greater than 100 MWth and less than or equal to 300 MWth and 90 % for plants greater than 300 MWth, For plants greater than 500 MWth, a desulphurization rate of at least 94 % shall apply or a desulphurization rate of at least 92 % where a contract for the fitting of flue gas desulphurization or lime injection equipment has been entered into, and work on its installation has commenced, before 1 January 2001,

B, SO₂ emission limit values expressed in mg/Nm³ (O₂ content 6 %) to be applied by new plants pursuant to Article 4(2) with the exception of gas turbines,


| Type of fuel | 50 to 100 MWth | 100 to 300 MWth | > 300 MWth |
|--------------|----------------|--------------------|------------|
| Biomass | 200 | 200 | 200 |
| General case | 850 | 200 ⁽¹⁾ | 200 |

⁽¹⁾ Except in the case of the "Outermost Regions" where 850 to 200 mg/Nm³ (linear decrease) shall apply,

NB, Where the emission limit values above cannot be met due to the characteristics of the fuel, installations shall achieve 300 mg/Nm³ SO₂, or a rate of desulphurisation of at least 92 % shall be achieved in the case of plants with a rated thermal input of less than or equal to 300 MWth and in the case of plants with a rated thermal input greater than 300 MWth a rate of desulphurisation of at least 95 % together with a maximum permissible emission limit value of 400 mg/Nm³ shall apply,

EMISSION LIMIT VALUES FOR SO₂ Liquid fuels

A, SO₂ emission limit values expressed in mg/Nm³ (O₂ content 3 %) to be applied by new and existing plants pursuant to Article 4(1) and 4(3), respectively:



B, SO₂ emission limit values expressed in mg/Nm³ (O₂ content 3 %) to be applied by new plants pursuant to Article 4(2) with the exception of gas turbines

| 50 to 100 MWth | 100 to 300 MWth | > 300 MWth |
|----------------|-------------------------------------|------------|
| 850 | 400 to 200 (linear decrease) (1) | 200 |

(1) Except in the case of the 'Outermost Regions' where 850 to 200 mg/Nm³ (linear decrease) shall apply,

In the case of two installations with a rated thermal input of 250 MWth on Crete and Rhodes to be licensed before 31 December 2007 the emission limit value of 1 700 mg/Nm³ shall apply,

EMISSION LIMIT VALUES FOR SO₂
Gaseous fuels

A, SO₂ emission limit values expressed in mg/Nm³ (O₂ content 3 %) to be applied by new and existing plants pursuant to Article 4(1) and 4(3), respectively:

| Type of fuel | Limit values (mg/Nm ³) |
|--|---------------------------------------|
| Gaseous fuels in general | 35 |
| Liquefied gas | 5 |
| Low calorific gases from gasification of refinery residues, coke oven gas, blast-furnace gas | 800 |
| Gas from gasification of coal | (1) |
| ⁽¹⁾ The Council will fix the emission limit values applicable to such gas at a later stage on the basis of proposals from the Commission to be made in the light of further technical experience, | |

B, SO₂ emission limit values expressed in mg/Nm³ (O₂ content 3 %) to be applied by new plants pursuant to Article 4(2):

| | |
|--------------------------------------|-----|
| Gaseous fuels in general | 35 |
| Liquefied gas | 5 |
| Low calorific gases from coke oven | 400 |
| Low caloric gases from blast furnace | 200 |

EMISSION LIMIT VALUES FOR NO_x (MEASURED AS NO₂)

A, NO_x emission limit values expressed in mg/Nm³ (O₂ content 6 % for solid fuels, 3 % for liquid and gaseous fuels) to be applied by new and existing plants pursuant to Article 4(1) and 4(3), respectively:

| Type of fuel: Limit | values ⁽¹⁾ (mg/Nm ³) |
|---|--|
| Solid ^{(2), (3)} : | |
| 50 to 500 MWth: | 600 |
| >500 MWth: | 500 |
| From 1 January 2016 | 600 |
| 50 to 500 MWth: | 200 |
| >500 MWth: | |
| Liquid: | |
| 50 to 500 MWth: | 450 |
| >500 MWth: | 400 |
| Gaseous: | |
| 50 to 500 MWth: | 300 |
| >500 MWth: | 200 |
| ⁽¹⁾ Except in the case of the ‘Outermost Regions’ where the following values shall apply: Solid in general: 650 Solid with < 10 % vol comps: 1 300 Liquid: 450 Gaseous: 350 | |
| ⁽²⁾ Until 31 December 2015 plants of a rated thermal input greater than 500 MW, which from 2008 onwards do not operate more than 2 000 hours a year (rolling average over a period of five years), shall: <ul style="list-style-type: none"> - , in the case of plant licensed in accordance with Article 4(3)(a), be subject to a limit value for nitrogen oxide emissions (measured as NO₂) of 600 mg/Nm³; - , In the case of plant subject to a national plan under Article 4(6), have their contribution to the national plan assessed on the basis of a limit value of 600 mg/Nm³, From 1 January 2016 such plants, which do not operate more than 1 500 hours a year (rolling average over a period of five years), shall be subject to a limit value for nitrogen oxide emissions (measured as NO ₂) of 450 mg/Nm ³ , | |
| ⁽³⁾ Until 1 January 2018 in the case of plants that in the 12 month period ending on 1 January 2001 operated on, and continue to operate on, solid fuels whose volatile content is less than 10 %, 1 200 mg/Nm ³ shall apply, | |

B, NO_x emission limit values expressed in mg/Nm³ to be applied by new plants pursuant to Article 4(2) with the exception of gas turbines

Solid fuels (O₂ content 6 %)

| Type of fuel | 50 to 100 MWth | 100 to 300 MWth | > 300 MWth |
|--------------|----------------|-----------------|------------|
| Biomass | 400 | 300 | 200 |
| General case | 400 | 200 (1) | 200 |

(1) Except in the case of the “Outermost Regions” where 300 mg/Nm³ shall apply,

Liquid fuels (O₂ content 3 %)

| 50 to 100 MWth | 100 to 300 MWth | > 300 MWth |
|--|-----------------|------------|
| 400 | 200 (1) | 200 |
| (1) Except in the case of the “ Outermost Regions” where 300 mg/Nm ³ shall apply, | | |

In the case of two installations with a rated thermal input of 250 MWth on Crete and Rhodes to be licensed before 31 December 2007 the emission limit value of 400 mg/Nm³ shall apply,

Gaseous fuels (O₂ content 3 %)

| | 50 to 300 MWth | > 300 MWth |
|----------------------|----------------|------------|
| Natural gas (Note 1) | 150 | 100 |
| Other gases | 200 | 200 |

Gas Turbines

NO_x emissions limit values expressed in mg/Nm³ (O₂ content 15 %) to be applied by a single gas turbine unit pursuant to Article 4(2) (the limit values apply only above 70 % load):

| | > 50 MWth (thermal input at ISO conditions) |
|--|--|
| Natural gas (Note 1) | 50 (Note 2) |
| Liquid fuels (Note 3) | 120 |
| Gaseous fuels (other than natural gas) | 120 |

Gas turbines for emergency use that operate less than 500 hours per year are excluded from these limit values, The operator of such plants is required to submit each year to the competent authority a record of such used time,

Note 1: Natural gas is naturally occurring methane with not more than 20 % (by volume) of inerts and other constituents,

Note 2: 75 mg/Nm³ in the following cases, where the efficiency of the gas turbine is determined at ISO base load conditions:

- gas turbines, used in combined heat and power systems having an overall efficiency greater than 75 %;
- gas turbines used in combined cycle plants having an annual average overall electrical efficiency greater than 55 %;
- gas turbines for mechanical drives,

For single cycle gas turbines not falling into any of the above categories, but having an efficiency greater than 35 % - determined at ISO base load conditions - the emission limit value shall be 50*g/35 where g is the gas turbine efficiency expressed as a percentage (and at ISO base load conditions),

Note 3: This emission limit value only applies to gas turbines firing light and middle distillates,

EMISSION LIMIT VALUES FOR DUST

A, Dust emission limit values expressed in mg/Nm³ (O₂ content 6 % for solid fuels, 3 % for liquid and gaseous fuels) to be applied by new and existing plants pursuant to Article 4(1) and 4(3), respectively:

| Type of fuel | Rated thermal input (MW) | Emission limit values (mg/Nm ³) |
|--|--------------------------|--|
| Solid | ≥500 | 50 (2) |
| | < 500 | 100 |
| Liquid (1) | all plants | 50 |
| Gaseous | all plants | 5 as a rule 10 for blast furnace gas 50 for gases produced by the steel industry which can be used elsewhere |
| <p>(1) A limit value of 100 mg/Nm³ may be applied to plants with a rated thermal input of less than 500 MWth burning liquid fuel with an ash content of more than 0,06 %,</p> <p>(2) A limit value of 100 mg/Nm³ may be applied to plants licensed pursuant to Article 4(3) with a rated thermal input greater than or equal to 500 MWth burning solid fuel with a heat content of less than 5 800 kJ/kg (net calorific value), a moisture content greater than 45 % by weight, a combined moisture and ash content greater than 60 % by weight and a calcium oxide content greater than 10 %,</p> | | |

B, Dust emission limit values expressed in mg/Nm³ to be applied by new plants, pursuant to Article 4(2) with the exception of gas turbines:

Solid fuels (O₂ content 6 %)

| | |
|----------------|------------|
| 50 to 100 MWth | > 100 MWth |
| 50 | 30 |

Liquid fuels (O₂ content 3 %)

| | |
|----------------|------------|
| 50 to 100 MWth | > 100 MWth |
| 50 | 30 |

In the case of two installations with a rated thermal input of 250 MWth on Crete and Rhodes to be licensed before 31 December 2007 the emission limit value of 50 mg/Nm³ shall apply,

Gaseous fuels (O₂ content 3 %)

| | |
|--|----|
| As a rule | 5 |
| For blast furnace gas | 10 |
| For gases produced by the steel industry which can be used elsewhere | 30 |

METHODS OF MEASUREMENT OF EMISSIONS

A, Procedures for measuring and evaluating emissions from combustion plants,

1, Until 27 November 2004

Concentrations of SO₂, dust, NO_x shall be measured continuously in the case of new plants for which a license is granted pursuant to Article 4(1) with a rated thermal input of more than 300 MW, However, monitoring of SO₂ and dust may be confined to discontinuous measurements or other appropriate determination procedures in cases where such measurements or procedures, which must be verified and approved by the competent authorities, may be used to obtain concentration,

In the case of new plants for which a license is granted pursuant to Article 4(1) not covered by the first subparagraph, the competent authorities may require continuous measurements of those three pollutants to be carried out where considered necessary, Where continuous measurements are not required, discontinuous measurements or appropriate determination procedures as approved by the competent authorities shall be used regularly to evaluate the quantity of the above-mentioned substances present in the emissions,

2, From 27 November 2002 and without prejudice to Article 18(2)

The competent authorities shall require continuous measurements of concentrations of SO₂, NO_x, and dust from waste gases from each combustion plant with a rated thermal input of 100 MW or more,

By way of derogation from the first subparagraph, continuous measurements may not be required in the following cases:

- for combustion plants with a life span of less than 10 000 operational hours;
- for SO₂ and dust from natural gas burning boilers or from gas turbines firing natural gas;
- for SO₂ from gas turbines or boilers firing oil with known sulphur content in cases where there is no desulphurization equipment;
- for SO₂ from biomass firing boilers if the operator can prove that the SO₂ emissions can under no circumstances be higher than the prescribed emission limit values,

Where continuous measurements are not required, discontinuous measurements shall be required at least every six months, As an alternative, appropriate determination procedures, which must be verified and approved by the competent authorities, may be used to evaluate the quantity of the above mentioned pollutants present in the emissions, Such procedures shall use relevant CEN standards as soon as they are available, If CEN standards are not available ISO standards, national or international standards which will ensure the provision of data of an equivalent scientific quality shall apply,

3, In the case of plants which must comply with the desulphurization rates fixed by Article 5(2) and Annex III, the requirements concerning SO₂ emission measurements established under paragraph 2 of this point shall apply, Moreover, the sulphur content of the fuel which is introduced into the combustion plant facilities must be regularly monitored,

- 4, The competent authorities shall be informed of substantial changes in the type of fuel used or in the mode of operation of the plant, They shall decide whether the monitoring requirements laid down in paragraph 2 are still adequate or require adaptation,
- 5, The continuous measurements carried out in compliance with paragraph 2 shall include the relevant process operation parameters of oxygen content, temperature, pressure and water vapor content, The continuous measurement of the water vapour content of the exhaust gases shall not be necessary, provided that the sampled exhaust gas is dried before the emissions are analyzed,

Representative measurements, i.e, sampling and analysis, of relevant pollutants and process parameters as well as reference measurement methods to calibrate automated measurement systems shall be carried out in accordance with CEN standards as soon as they are available, If CEN standards are not available ISO standards, national or international standards which will ensure the provision of data of an equivalent scientific quality shall apply,

Continuous measuring systems shall be subject to control by means of parallel measurements with the reference methods at least every year,

- 6, The values of the 95 % confidence intervals of a single measured result shall not exceed the following percentages of the emission limit values:

| | |
|-----------------|------|
| Sulphur dioxide | 20 % |
| Nitrogen oxides | 20 % |
| Dust | 30 % |

The validated hourly and daily average values shall be determined from the measured valid hourly average values after having subtracted the value of the confidence interval specified above,

Any day in which more than three hourly average values are invalid due to malfunction or maintenance of the continuous measurement system shall be invalidated, If more than ten days over a year are invalidated for such situations the competent authority shall require the operator to take adequate measures to improve the reliability of the continuous monitoring system,

B, Determination of total annual emissions of combustion plants

Until and including 2003 the competent authorities shall obtain determination of the total annual emissions of SO₂ and NO_x from new combustion plants, When continuous monitoring is used, the operator of the combustion plant shall add up separately for each pollutant the mass of pollutant emitted each day, on the basis of the volumetric flow rates of waste gases, Where continuous monitoring is not in use, estimates of the total annual emissions shall be determined by the operator on the basis of paragraph A,1 to the satisfaction of the competent authorities,

Member States shall communicate to the Commission the total annual SO₂ and NO_x emissions of new combustion plants at the same time as the communication required under paragraph C,3 concerning the total annual emissions of existing plants,

Member States shall establish, starting in 2004 and for each subsequent year, an inventory of SO₂, NO_x and dust emissions from all combustion plants with a rated thermal input of 50 MW or more. The competent authority shall obtain for each plant operated under the control of one operator at a given location the following data:

- the total annual emissions of SO₂, NO_x and dust (as total suspended particles),
- the total annual amount of energy input, related to the net calorific value, broken down in terms of the five categories of fuel: biomass, other solid fuels, liquid fuels, natural gas, other gases,

A summary of the results of this inventory that shows the emissions from refineries separately shall be communicated to the Commission every three years within twelve months from the end of the three-year period considered. The yearly plant-by-plant data shall be made available to the Commission upon request. The Commission shall make available to the Member States a summary of the comparison and evaluation of the national inventories within twelve months of receipt of the national inventories,

Commencing on 1 January 2008 Member States shall report annually to the Commission on those existing plants declared for eligibility under Article 4(4) along with the record of the used and unused time allowed for the plants' remaining operational life,

C, Determination of the total annual emissions of existing plants until and including 2003,

1. Member States shall establish, starting in 1990 and for each subsequent year until and including 2003, a complete emission inventory for existing plants covering SO₂ and NO_x:
 - on a plant by plant basis for plants above 300 MWth and for refineries;
 - on an overall basis for other combustion plants to which this Directive applies,
2. The methodology used for these inventories shall be consistent with that used to determine SO₂ and NO_x emissions from combustion plants in 1980,
3. The results of this inventory shall be communicated to the Commission in a conveniently aggregated form within nine months from the end of the year considered. The methodology used for establishing such emission inventories and the detailed base information shall be made available to the Commission at its request,
4. The Commission shall organize a systematic comparison of such national inventories and, if appropriate, shall submit proposals to the Council aiming at harmonizing emission inventory methodologies, for the needs of an effective implementation of this Directive,

Requirements from the IE Directive

ANNEX V

Technical provisions relating to combustion plants

PART 1

Emission limit values for combustion plants referred to in Article 30(2)1,

1. All emission limit values shall be calculated at a temperature of 273,15 K, a pressure of 101,3 kPa and after correction for the water vapour content of the waste gases and at a standardised O₂ content of 6 % for solid fuels, 3 % for combustion plants, other than gas turbines and gas engines using liquid and gaseous fuels and 15 % for gas turbines and gas engines, 2,
2. Emission limit values (mg/Nm³) for SO₂ for combustion plants using solid or liquid fuels with the exception of gas turbines and gas engines

| Total rated thermal input (MW) | Coal and lignite and other solid fuels | Biomass | Peat | Liquid fuels |
|--------------------------------|--|---------|------|--------------|
| 50-100 | 400 | 200 | 300 | 350 |
| 100-300 | 250 | 200 | 300 | 250 |
| > 300 | 200 | 200 | 200 | 200 |

Combustion plants, using solid fuels which were granted a permit before 27 November 2002 or the operators of which had submitted a complete application for a permit before that date, provided that the plant was put into operation no later than 27 November 2003, and which do not operate more than 1 500 operating hours per year as a rolling average over a period of 5 years, shall be subject to an emission limit value for SO₂ of 800 mg/Nm³,

Combustion plants using liquid fuels, which were granted a permit before 27 November 2002 or the operators of which had submitted a complete application for a permit before that date, provided that the plant was put into operation no later than 27 November 2003, and which do not operate more than 1 500 operating hours per year as a rolling average over a period of 5 years, shall be subject to an emission limit value for SO₂ of 850 mg/Nm³ in case of plants with a total rated thermal input not exceeding 300 MW and of 400 mg/Nm³ in case of plants with a total rated thermal input greater than 300 MW,

A part of a combustion plant discharging its waste gases through one or more separate flues within a common stack, and which does not operate more than 1 500 operating hours per year as a rolling average over a period of 5 years, may be subject to the emission limit values set out in the preceding two paragraphs in relation to the total rated thermal input of the entire combustion plant, In such cases the emissions through each of those flues shall be monitored separately,

3. Emission limit values (mg/Nm³) for SO₂ for combustion plants using gaseous fuels with the exception of gas turbines and gas engines

| | |
|--|-----|
| In general | 35 |
| Liquefied gas | 5 |
| Low calorific gases from coke oven | 400 |
| Low calorific gases from blast furnace | 200 |

Combustion plants, firing low calorific gases from gasification of refinery residues, which were granted a permit before 27 November 2002 or the operators of which had submitted a complete application for a permit before that date, provided that the plant was put into operation no later than 27 November 2003, shall be subject to an emission limit value for SO₂ of 800 mg/Nm³,

4. Emission limit values (mg/Nm³) for NO_x for combustion plants using solid or liquid fuels with the exception of gas turbines and gas engines

| Total rated thermal input (MW) | Coal and lignite and other solid fuels | Biomass and peat | Liquid fuels |
|--------------------------------|---|------------------|--------------|
| 50-100 | 300 450 in case of pulverised lignite combustion | 300 | 450 |
| 100-300 | 200 | 250 | 200 (1) |
| > 300 | 200 | 200 | 150 (1) |

Note: (1) The emission limit value is 450 mg/Nm³ for the firing of distillation and conversion residues from the refining of crude-oil for own consumption in combustion plants with a total rated thermal input not exceeding 500 MW which were granted a permit before 27 November 2002 or the operators of which had submitted a complete application for a permit before that date, provided that the plant was put into operation no later than 27 November 2003,

Combustion plants in chemical installations using liquid production residues as non-commercial fuel for own consumption with a total rated thermal input not exceeding 500 MW which were granted a permit before 27 November 2002 or the operators of which had submitted a complete application for a permit before that date, provided that the plant was put into operation no later than 27 November 2003, shall be subject to an emission limit value for NO_x of 450 mg/Nm³,

Combustion plants using solid or liquid fuels with a total rated thermal input not exceeding 500 MW which were granted a permit before 27 November 2002 or the operators of which had submitted a complete application for a permit before that date, provided that the plant was put into operation no later than 27 November 2003, and which do not operate more than 1 500 operating hours per year as a rolling average over a period of 5 years, shall be subject to an emission limit value for NO_x of 450 mg/Nm³,

Combustion plants using solid fuels with a total rated thermal input greater than 500 MW, which were granted a permit before 1 July 1987 and which do not operate more than 1 500 operating hours per year as a rolling average over a period of 5 years, shall be subject to an emission limit value for NO_x of 450 mg/Nm³,

Combustion plants using liquid fuels, with a total rated thermal input greater than 500 MW which were granted a permit before 27 November 2002 or the operators of which had submitted a complete application for a permit before that date, provided that the plant was put into operation no later than 27 November 2003, and which do not operate more than 1 500 operating hours per year as a rolling average over a period of 5 years, shall be subject to an emission limit value for NO_x of 400 mg/Nm³,

A part of a combustion plant discharging its waste gases through one or more separate flues within a common stack, and which does not operate more than 1 500 operating hours per year as a rolling average over a period of 5 years, may be subject to the emission limit values set out in the preceding three paragraphs in relation to the total rated thermal input of the entire combustion plant, In such cases the emissions through each of those flues shall be monitored separately,

5. Gas turbines (including combined cycle gas turbines (CCGT)) using light and middle distillates as liquid fuels shall be subject to an emission limit value for NO_x of 90 mg/Nm³ and for CO of 100 mg/Nm³,

Gas turbines for emergency use that operate less than 500 operating hours per year are not covered by the emission limit values set out in this point, The operator of such plants shall record the used operating hours,

6. Emission limit values (mg/Nm³) for NO_x and CO for gas fired combustion plants

| | NO _x | CO |
|--|-----------------|-----|
| Combustion plants firing natural gas with the exception of gas turbines and gas engines | 100 | 100 |
| Combustion plants firing blast furnace gas, coke oven gas or low calorific gases from gasification of refinery residues, with the exception of gas turbines and gas engines | 200 (4) | — |
| Combustion plants firing other gases, with the exception of gas turbines and gas engines | 200 (4) | — |
| Gas turbines (including CCGT), using natural gas (1) as fuel | 50 (2) (3) | 100 |
| Gas turbines (including CCGT), using other gases as fuel | 120 | — |
| Gas engines | 100 | 100 |
| <p>Notes:</p> <p>(1) Natural gas is naturally occurring methane with not more than 20 % (by volume) of inerts and other constituents,</p> <p>(2) 75 mg/Nm³ in the following cases, where the efficiency of the gas turbine is determined at ISO base load conditions:</p> <ol style="list-style-type: none"> I. Gas turbine, used in combined heat and power systems having an overall efficiency greater than 75 %, II. Gas turbine, used in combined cycle plants having an annual average overall electrical efficiency greater than 55 %, III. Gas turbine for mechanical drives, <p>(3) For single cycle gas turbines not falling into any of the categories mentioned under note (2), but having an efficient greater than 35 % - determined at ISO base load conditions – the emission limit value for NO_x shall be 50 η/35 where η is the gas turbine efficiency at ISO base load conditions expressed as a percentage,</p> <p>(4) 300 mg/Nm³ for such combustion plants with a total rated thermal input not exceeded 50 MW which were granted a permit before 27 November 2002 or the operators of which had submitted a complete application for a permit before that date provided that the plant was put into operation no later than 27 November 2003,</p> | | |

For gas turbines (including CCGT), the NO_x and CO emission limit values set out in the table contained in this point apply only above 70 % load,

For gas turbines (including CCGT) which were granted a permit before 27 November 2002 or the operators of which had submitted a complete application for a permit before that date, provided that the plant was put into operation no later than 27 November 2003, and which do not operate more than 1 500 operating hours per year as a rolling average over a period of 5 years, the emission limit value for NO_x is 150 mg/Nm³ when firing natural gas and 200 mg/Nm³ when firing other gases or liquid fuels,

A part of a combustion plant discharging its waste gases through one or more separate flues within a common stack, and which does not operate more than 1 500 operating hours per year as a rolling average over a period of 5 years, may be subject to the emission limit values set out in the preceding paragraph in relation to the total rated thermal input of the entire combustion plant, In such cases the emissions through each of those flues shall be monitored separately,

Gas turbines and gas engines for emergency use that operate less than 500 operating hours per year are not covered by the emission limit values set out in this point, The operator of such plants shall record the used operating hours,

7. Emission limit values (mg/Nm³) for dust for combustion plants using solid or liquid fuels with the exception of gas turbines and gas engines

| Total rated thermal input (MW) | Coal and lignite and other solid fuels | Biomass and peat | Liquid fuels (1) |
|--------------------------------|--|------------------|------------------|
| 50-100 | 30 | 30 | 30 |
| 100-300 | 25 | 20 | 25 |
| > 300 | 20 | 20 | 20 |

Note:

- (1) The emission limit value is 50 mg/Nm³ for the firing of distillation and conversion residues from the refining of crude oil for own consumption in combustion plants which were granted a permit before 27 November 2002 or the operators of which had submitted a complete application for a permit before that date, provided that the plant was put into operation no later than 27 November 2003.

8. Emission limit values (mg/Nm³) for dust for combustion plants using gaseous fuels with the exception of gas turbines and gas engines

| | |
|--|----|
| In general | 5 |
| Blast furnace gas | 10 |
| Gases produced by the steel industry which can be used elsewhere | 30 |

PART 2

Emission limit values for combustion plants referred to in Article 30(3)1,

- All emission limit values shall be calculated at a temperature of 273,15 K, a pressure of 101,3 kPa and after correction for the water vapor content of the waste gases and at a standardized O₂ content of 6 % for solid fuels, 3 % for combustion plants other than gas turbines and gas engines using liquid and gaseous fuels and 15 % for gas turbines and gas engines,

In case of combined cycle gas turbines with supplementary firing, the standardized O₂ content may be defined by the competent authority, taking into account the specific characteristics of the installation concerned,

- Emission limit values (mg/Nm³) for SO₂ for combustion plants using solid or liquid fuels with the exception of gas turbines and gas engines

| Total rated thermal input (MW) | Coal and lignite and other solid fuels | Biomass | Peat | Liquid fuels |
|--------------------------------|---|---------|--|--------------|
| 50-100 | 400 | 200 | 300 | 350 |
| 100-300 | 200 | 200 | 300 250 in case of fluidized bed combustion | 200 |
| > 300 | 150 200 in case of circulating or pressurized fluidized bed combustion | 150 | 150 200 in case of fluidized bed combustion | 150 |

- Emission limit values (mg/Nm³) for SO₂ for combustion plants using gaseous fuels with the exception of gas turbines and gas engines

| | |
|--|-----|
| In general | 35 |
| Liquefied gas | 5 |
| Low calorific gases from coke oven | 400 |
| Low calorific gases from blast furnace | 200 |

- Emission limit values (mg/Nm³) for NO^x for combustion plants using solid or liquid fuels with the exception of gas turbines and gas engines

| Total rated thermal input (MW) | Coal and lignite and other solid fuels | Biomass and peat | Liquid fuels |
|--------------------------------|---|------------------|--------------|
| 50-100 | 300 400 in case of pulverized lignite combustion | 250 | 300 |
| 100-300 | 200 | 200 | 150 |
| > 300 | 150 200 in case of pulverized lignite combustion | 150 | 100 |

5. Gas turbines (including CCGT) using light and middle distillates as liquid fuels shall be subject to an emission limit value for NO_x of 50 mg/Nm³ and for CO of 100 mg/Nm³

Gas turbines for emergency use that operate less than 500 operating hours per year are not covered by the emission limit values set out in this point, The operator of such plants shall record the used operating hours,

6. Emission limit values (mg/Nm³) for NO_x and CO for gas fired combustion plants

| | NO _x | CO |
|---|-----------------|-----|
| Combustion plants other than gas turbines and gas engines | 100 | 100 |
| Gas turbines (including CCGT) | 50 (1) | 100 |
| Gas engines | 75 | 100 |

Note:

- (1) For single cycle gas turbines having efficiency greater than 35 % - determined at ISO base load conditions – the emission limit value of NO_x, shall be $50 \times \eta / 35$ where η is the gas turbine efficiency at ISO base load conditions expressed as percentage,

For gas turbines (including CCGT), the NO_x and CO emission limit values set out in this point apply only above 70 % load,

Gas turbines and gas engines for emergency use that operate less than 500 operating hours per year are not covered by the emission limit values set out in this point, The operator of such plants shall record the used operating hours,

7. Emission limit values (mg/Nm³) for dust for combustion plants using solid or liquid fuels with the exception of gas turbines and gas engines

| Total rated thermal input (MW) | |
|--------------------------------|-------------------------------|
| 50-300 | 20 |
| > 300 | 10 20 for biomass and peat |

8. Emission limit values (mg/Nm³) for dust for combustion plants using gaseous fuels with the exception of gas turbines and gas engines

| | |
|--|----|
| In general | 5 |
| Blast furnace gas | 10 |
| Gases produced by the steel industry which can be used elsewhere | 30 |

PART 3

Emission monitoring

1. The concentrations of SO₂, NO_x and dust in waste gases from each combustion plant with a total rated thermal input of 100 MW or more shall be measured continuously,
The concentration of CO in waste gases from each combustion plant firing gaseous fuels with a total rated thermal input of 100 MW or more shall be measured continuously, 2,
2. The competent authority may decide not to require the continuous measurements referred to in point 1 in the following cases:
 - (a) for combustion plants with a life span of less than 10 000 operational hours;
 - (b) for SO₂ and dust from combustion plants firing natural gas;
 - (c) for SO₂ from combustion plants firing oil with known sulphur content in cases where there is no waste gas desulphurisation equipment;
 - (d) for SO₂ from combustion plants firing biomass if the operator can prove that the SO₂ emissions can under no circumstances be higher than the prescribed emission limit values,
3. Where continuous measurements are not required, measurements of SO₂, NO_x, dust and, for gas fired plants, also of CO shall be required at least once every 6 months,
4. For combustion plants firing coal or lignite, the emissions of total mercury shall be measured at least once per year,
5. As an alternative to the measurements of SO₂ and NO_x referred to in point 3, other procedures, verified and approved by the competent authority, may be used to determine the SO₂ and NO_x emissions, Such procedures shall use relevant CEN standards or, if CEN standards are not available, ISO, national or other international standards which ensure the provision of data of an equivalent scientific quality,
6. The competent authority shall be informed of significant changes in the type of fuel used or in the mode of operation of the plant, The competent authority shall decide whether the monitoring requirements laid down in points 1 to 4 are still adequate or require adaptation,
7. The continuous measurements carried out in accordance with point 1 shall include the measurement of the oxygen content, temperature, pressure and water vapor content of the waste gases, The continuous measurement of the water vapor content of the waste gases shall not be necessary, provided that the sampled waste gas is dried before the emissions are analyzed,
8. Sampling and analysis of relevant polluting substances and measurements of process parameters as well as the quality assurance of automated measuring systems and the reference measurement methods to calibrate those systems shall be carried out in accordance with CEN standards, If CEN standards are not available, ISO, national or other international standards which ensure the provision of data of an equivalent scientific quality shall apply,
The automated measuring systems shall be subject to control by means of parallel measurements with the reference methods at least once per year,
The operator shall inform the competent authority about the results of the checking of the automated measuring systems,
9. At the emission limit value level, the values of the 95 % confidence intervals of a single measured result shall not exceed the following percentages of the emission limit values:

| | |
|-----------------|------|
| Carbon monoxide | 10 % |
| Sulphur dioxide | 20 % |
| Nitrogen oxides | 20 % |
| Dust | 30 % |

10. The validated hourly and daily average values shall be determined from the measured valid hourly average values after having subtracted the value of the confidence interval specified in point 9, Any day in which more than three hourly average values are invalid due to malfunction or maintenance of the automated measuring system shall be invalidated, If more than 10 days over a year are invalidated for such situations the competent authority shall require the operator to take adequate measures to improve the reliability of the automated measuring system,
11. In the case of plants which must comply with the rates of desulphurisation referred to in Article 31, the sulphur content of the fuel which is fired in the combustion plant shall also be regularly monitored, The competent authorities shall be informed of substantial changes in the type of fuel used,

PART 4

Assessment of compliance with emission limit values 1,

1. In the case of continuous measurements, the emission limit values set out in Parts 1 and 2 shall be regarded as having been complied with if the evaluation of the measurement results indicates, for operating hours within a calendar year, that all of the following conditions have been met:
 - (a) no validated monthly average value exceeds the relevant emission limit values set out in Parts 1 and 2;
 - (b) no validated daily average value exceeds 110 % of the relevant emission limit values set out in Parts 1 and 2;
 - (c) in cases of combustion plants composed only of boilers using coal with a total rated thermal input below 50 MW, no validated daily average value exceeds 150 % of the relevant emission limit values set out in Parts 1 and 2,
 - (d) 95 % of all the validated hourly average values over the year do not exceed 200 % of the relevant emission limit values set out in Parts 1 and 2,

The validated average values are determined as set out in point 10 of Part 3,

For the purpose of the calculation of the average emission values, the values measured during the periods referred to in Article 30(5) and (6) and Article 37 as well as during the start-up and shut-down periods shall be disregarded,

2. Where continuous measurements are not required, the emission limit values set out in Parts 1 and 2 shall be regarded as having been complied with if the results of each of the series of measurements or of the other procedures defined and determined according to the rules laid down by the competent authorities do not exceed the emission limit values,

PART 5

Minimum rate of desulphurisation

1. Minimum rate of desulphurisation for combustion plants referred to in Article 30(2)

| Total rated thermal input (MW) | Minimum rate of desulphurisation | |
|--------------------------------|--|--------------|
| | Plants which were granted a permit before 27 November 2002 or the operators of which had submitted a complete application for a permit before that date, provided that the plant was put into operation no later than 27 November 2003 | Other plants |
| 50-100 | 80 % | 92 % |
| 100-300 | 90 % | 92 % |
| > 300 | 96 % (1) | 96 % |

Note:

- (1) For combustion plants firing oil shale, the minimum rate of desulphurisation is 95 %,

2. Minimum rate of desulphurisation for combustion plants referred to in Article 30(3)

| Total rated thermal input (MW) | Minimum rate of desulphurisation |
|--------------------------------|----------------------------------|
| 50-100 | 93 % |
| 100-300 | 93 % |
| > 300 | 97 % |

PART 6

Compliance with rate of desulphurisation

The minimum rates of desulphurisation set out in Part 5 of this Annex shall apply as a monthly average limit value.

PART 7

Average emission limit values for multi-fuel firing combustion plants within a refinery

Average emission limit values (mg/Nm^3) for SO_2 for multi-fuel firing combustion plants within a refinery, with the exception of gas turbines and gas engines, which use the distillation and conversion residues from the refining of crude-oil for own consumption, alone or with other fuels:

- for combustion plants which were granted a permit before 27 November 2002 or the operators of which had submitted a complete application for a permit before that date, provided that the plant was put into operation no later than 27 November 2003: $1\ 000\ \text{mg}/\text{Nm}^3$;
- for other combustion plants: $600\ \text{mg}/\text{Nm}^3$,

These emission limit values shall be calculated at a temperature of 273,15 K, a pressure of 101,3 kPa and after correction for the water vapor content of the waste gases and at a standardized O_2 content of 6 % for solid fuels and 3 % for liquid and gaseous fuels.